

Minutes

Of the meeting of the:

Strathfield Independent Hearing and Assessment Panel Meeting

Held on:

Thursday, 3 August 2017

Commencing at 10:30am at Council Town Hall (Supper Room), 65 Homebush Road, Strathfield

TABLE OF CONTENTS

Item	Page No.
SIHAP AGENDA ITEMS	
SIHAP - Report No. 1	
DA2017/059- 47-48 Loftus Crescent and 12-18 Bridge Road Homebush Lots 1 and 2 DP841916, Lots A,B,C and D DP313831	4
SIHAP - Report No. 2	
DA2017/061- 15 Homebush Road, Strathfield Lot 5 DP31394.....	42
SIHAP - Report No. 3	
DA2017/066- 88-92A Parramatta Road, Homebush Lot A DP 419617, Lot 1,2 and 3 of DP 201120	69
SIHAP - Report No. 4	
DA2017/067- 2 Subway Lane, Homebush Lot 7 DP 18702 and Lot B DP403083	82

The meeting of the Strathfield Independent Hearing and Assessment Panel Meeting was held in the Council Town Hall (Supper Room), 65 Homebush Road, Strathfield on Thursday 3 August 2017.

The meeting commenced at 10:30am.

PRESENT

The Hon Paul Stein QC AM – Chair

Graham Atkins- Expert

John Evernden- Expert

Peter Smith- Community

ALSO PRESENT

Silvio Falato, Manager in Planning

Louise Mansfield, Planning Officer

Lily Lam, Administration Assistant

DECLARATIONS OF PECUNIARY INTEREST / CONFLICT OF INTEREST

Nil

TO: Strathfield Independent Hearing and Assessment Panel Meeting - 3 August 2017

REPORT: SIHAP – Report No. 1

SUBJECT: 47-48 LOFTUS CRESCENT AND 12-18 BRIDGE ROAD HOMEBUSH
LOTS 1 AND 2 DP841916, LOTS A,B,C AND D DP313831

DA NO. 2017/059

RECOMMENDATION

In consideration of the written request made by the applicant pursuant to Clause 4.6 of the Strathfield Local Environmental Plan 2012, the consent authority is satisfied that compliance with the development standard contained in Clause 4.3A of the SLEP 2012 is well founded and that there are sufficient environmental planning grounds to justify contravening the development standard.

That Development Application No. 2017/059 for demolition of existing structures and construction of a part six (6) storey and part seven (7) storey residential flat building containing (70) units over two (2) levels of basement car parking at 47-48 Loftus Crescent and 12-18 Bridge Road, Homebush be granted **DEFERRED COMMENCEMENT CONSENT**, subject to the following conditions:

DEFERRED COMMENCEMENT CONDITIONS

DEFERRED COMMENCEMENT APPROVAL

This is a Deferred Commencement Consent under Section 80(3) of the Environmental Planning and Assessment (EP&A Act, 1979. This consent does not become operative until the applicant has satisfied the conditions listed under Schedule A below. All conditions shall be satisfactorily resolved within a period of twelve (12) months from the Determination Date that is shown on this consent. Upon compliance with the conditions under SCHEDULE A and written confirmation of this from Council, the consent shall become operative from the 'Date of Endorsement' (to be included on the written notice of determination).

(Reason: A deferred commencement consent stipulates conditions that must be satisfied before the consent operates in accordance with Section 80(3) of the EP&A Act 1979)

SCHEDULE A

D1 Sydney Trains

This consent is not to operate until the Applicant satisfies the Council, within 12 months of that date of this consent, that it has obtained approval/certification from Sydney Trains as to the following matters and the approval/certification has been forwarded to the Council:

The Applicant shall prepare and provide to Sydney Trains for approval/certification the following items:

- (a) Geotechnical and Structural report/drawings that meet Sydney Trains requirements. The Geotechnical Report must be based on actual borehole testing conducted on the site closest to the rail corridor.
- (b) Construction methodology with construction details pertaining to structural support during excavation. The Applicant is to be aware that Sydney Trains will not permit any

- rock anchors/bolts (whether temporary or permanent) within its land or easements.
- (c) Cross sectional drawings showing the rail corridor, sub soil profile, proposed basement excavation and structural design of sub ground support adjacent to the rail corridor. All measurements are to be verified by a Registered Surveyor.
 - (d) Detailed Survey Plan showing the relationship of the proposed development with respect to Sydney Trains, an FE analysis which assesses the different stages of loading-unloading of the site and its effect on the rock mass surrounding the rail corridor.

Any conditions issued as part of Sydney Trains approval/certification of the above documents will also form part of the consent conditions that the Applicant is required to comply with.

SPECIAL CONDITIONS (SC)

1. SYDNEY TRAINS (SC)

- If required by Sydney Trains, prior to the commencement of works, prior to the issue of the Occupation Certificate, or at any time during the excavation and construction period deemed necessary by Sydney Trains, a joint inspection of the rail infrastructure and property in the vicinity of the project is to be carried out by representatives from Sydney Trains and the Applicant. The dilapidation surveys will establish the extent of any existing damage and enable any deterioration during construction to be observed. The submission of a detailed dilapidation report will be required unless otherwise notified by Sydney Trains.
- An acoustic assessment is to be submitted to Council prior to the issue of a construction certificate demonstrating how the proposed development will comply with the Department of Planning's document titled "Development Near Rail Corridor and Busy Roads – Interim Guidelines".
- Prior to the issue of a Construction Certificate the Applicant is to engage an Electrolysis Expert to prepare a report on the Electrolysis Risk to the development from stray currents. The Applicant must incorporate in the development all the measures recommended in the report to control that risk. A copy of the report is to be provided to the Principal Certifying Authority with the application for a Construction Certificate.
- The design, installation and use of lights, signs and reflective materials, whether permanent or temporary, which are (or from which reflected light might be) visible from the rail corridor must limit glare and reflectivity to the satisfaction of Sydney Trains. The Principal Certifying Authority is not to issue the Construction Certificate until written confirmation has been received from Sydney Trains confirming that this condition has been satisfied.
- If required by Sydney Trains, prior to the issue of a Construction Certificate a Risk Assessment/Management Plan and detailed Safe Work Method Statements (SWMS) for the proposed works are to be submitted to Sydney Trains for review and comment on the impacts on rail corridor. The Principal Certifying Authority is not to issue the Construction Certificate until written confirmation has been received from Sydney Trains confirming that this condition has been satisfied.
- If required by Sydney Trains, a track monitoring plan (including instrumentation and the monitoring regime during excavation and construction phase) is to be submitted to Sydney Trains for review and endorsement prior to the issuing of a Construction Certificate. The Principal Certifying Authority is not to issue a Construction Certificate until written confirmation has been received from Sydney Trains advising of the need to undertake the track monitoring plan, and is required, that it has been endorsed.

- Unless advised by Sydney Trains in writing, all excavation, shoring and piling works within 25m of the rail corridor are to be supervised by a geotechnical engineer experienced with such excavation projects.
- No rock anchors/bolts are to be installed into Sydney Trains property or easements.
- Prior to the issuing of an Occupation Certificate the Applicant is to submit as-built drawings to Sydney Trains and Council. The as-built drawings are to be endorsed by a Registered Surveyor confirming that there has been no encroachment into Sydney Trains property or easements, unless agreed to be these authorities. The Principal Certifying Authority is not to issue the final Occupation Certificate until written confirmation has been received from Sydney Trains confirming that this condition has been satisfied.
- Prior to the issue of a Construction Certificate the Applicant is to contact Sydney Trains Rail Corridor Management Group to determine the need for public liability insurance cover. If insurance cover is deemed necessary this insurance be for sum as determined by Sydney Trains and shall not contain any exclusion in relation to works on or near the rail corridor, rail infrastructure. The Applicant is to contact Sydney Trains Rail Corridor Management Group to obtain the level of insurance required for this particular proposal. Prior to issuing the Construction Certificate the Principal Certifying Authority must witness written proof of this insurance in conjunction with Sydney Trains written advice to the Applicant on the level of insurance required.
- Prior to the issue of a Construction Certificate the Applicant is to contact Sydney Trains Rail Corridor Management Group to determine the need for the lodgement of a Bond or Bank Guarantee for the duration of the works. The Bond/Bank Guarantee shall be for the sum determined by Sydney Trains. Prior to the issuing of the Construction Certificate the Principal Certifying Authority must witness written advice from Sydney Trains confirming the lodgement of this Bond/Bank Guarantee.
- Sydney Trains or Transport for NSW (TfNSW), and persons authorised by those entities for the purpose of this condition, are entitled to inspect the site of the development and all structures to enable it to consider whether those structures have been or are being constructed and maintained in accordance with the approved plans and these conditions of consent, on giving reasonable notice to the principal contractor for the development or the owner or occupier of the part of the site to which access is sought.
- Prior to the issuing of a Construction Certificate the Applicant is to submit to Sydney Trains a plan showing all craneage and other aerial operations for the development and must comply with all Sydney Trains requirements. If required by Sydney Trains, the Applicant must amend the plan showing all craneage and other aerial operations to comply with all Sydney Trains requirements. The Principal Certifying Authority is not to issue the Construction Certificate until written confirmation has been received from the Sydney Trains confirming that this condition has been satisfied.
- Copies of any certificates, drawings, approvals/certification or documents endorsed by, given to or issued by Sydney Trains must be submitted to Council for its records prior to the issuing of a Construction Certificate.
- Any conditions issued as part of Sydney Trains approval/certification of any documentation for compliance with the Sydney Trains conditions of consent, those approval/certification conditions will also form part of the consent conditions that the

Applicant is required to comply with.

(Reason: Integrated development)

2. OFFICE OF WATER (SC)

NSW Office of Water

- An authorisation shall be obtained for the take of groundwater as part of the activity. Groundwater shall not be pumped or extracted for any purpose other than temporary construction dewatering at the site identified in the development application. The authorisation shall be subject to a currency period of 12 months from the date of issue and will be limited to the volume of groundwater take identified.
- The design and construction of the building must prevent any take of groundwater after the authorisation has lapsed by making any below-ground levels that may be impacted by any water table watertight for the anticipated life of the building. Waterproofing of below-ground levels must be sufficiently extensive to incorporate adequate provision for unforeseen high water table elevations to prevent potential future inundation.
- Sufficient permanent drainage shall be provided beneath and around the outside of the watertight structure to ensure that natural groundwater flow is not impeded and:
 - (a) any groundwater mounding at the edge of the structure shall be at a level not greater than 10 % above the level to which the water table might naturally rise in the location immediately prior to the construction of the structure; and
 - (b) any elevated water table is more than 1.0 m below the natural ground surface existent at the location immediately prior to the construction of the structure; and
 - (c) where the habitable part of the structure (not being footings or foundations) is founded in bedrock or impermeable natural soil then the requirement to maintain groundwater flows beneath the structure is not applicable.
- Construction methods and material used in and for construction shall be designed to account for the likely range of salinity and pollutants which may be dissolved in groundwater, and shall not themselves cause pollution of the groundwater.
- DPI Water requires documentation (referred to as 'report') comprising measurements, maps, bore logs, calculations, results, discussion and justification for various matters related to the dewatering process. Information will be required at several stages: prior to construction commencing (initial report - which will accompany the application for the authorisation), at any time when an authorisation renewal is required or a significant change in activities occurs (intermediate report); and at the completion of dewatering and related operations (completion report). Reports need to be submitted to DPI Water at Parramatta Office, in a format consistent with electronic retrieval without editing restrictions; raw data should be presented in Excel spreadsheets without editing restrictions.

Prior to excavation

- The following shall be included in the initial report:
 - (a) measurements of groundwater levels beneath the site from a minimum of three relevant monitoring bores, together with details of the bores used in the assessment including bore logs and three-dimensional identification information.
 - (b) a map of the site and its immediate environs depicting the water table (baseline

conditions) shown relative to the topography and approved construction footprint from the surface level and below. An assessment of the potential variation in the water table during the life of the proposed building together with a discussion of the methodology and information on which this assessment is based.

- (c) details of the present and potential groundwater flow paths and hydraulic gradients in and around the site; the latter in response to the final volumetric emplacement of the construction.
- (d) a schedule for the ongoing water level monitoring and description of the methodology to be used, from the date of consent until at least two months after the cessation of pumping. [DPI Water prefers that monitoring be undertaken on a continuous basis using automatic loggers in boreholes.]
- The Applicant shall assess the likely impacts of the dewatering activities on other groundwater users or structures or public infrastructure; this assessment will include an appropriate bore, spring or groundwater seep census and considerations relevant to potential subsidence or excessive settlement induced in nearby buildings and property, and be documented together with all calculations and information to support the basis of these in the initial report.
 - Groundwater quality testing of samples taken from outside the footprint of the proposed construction, with the intent of ensuring that as far as possible the natural and contaminant hydrochemistry of the potential dewatered groundwater is understood, shall be conducted on a suitable number of samples and tested by a NATA-certified laboratory. Details of the sampling locations and the protocol used, together with the test results accompanied by laboratory test certificates shall be included in the initial report. An assessment of results must be done by suitably qualified persons with the intent of identifying the presence of any contaminants and comparison of the data against accepted water quality objectives or criteria for the intended dewatering purpose. In the event of adverse quality findings, the Applicant must develop a plan to mitigate the impacts of the hydrochemistry on the dewatered groundwater and present the details of all assessments and plans in the initial report.
 - Groundwater quality testing generally in accordance with Clause 8, shall be undertaken on any anniversary or other renewal or alteration of any dewatering authorisation.
 - A reasonable estimate of the total volume of groundwater to be extracted shall be calculated and included in the initial report; together with details and calculation methods for the parameters and supporting information to confirm their development or measurement (e.g. permeability predicted by slug-testing, pump-testing or other means).
 - A copy of a valid consent for the development shall be provided in the initial report.
 - The method of disposal of pumped water shall be nominated (i.e. reinjection, drainage to the stormwater system or discharge to sewer) and a copy of the written permission from the relevant controlling authority shall be provided in the initial report. The disposal of any contaminated pumped groundwater (sometimes called “tailwater”) must comply with the provisions of the *Protection of the Environment Operations Act 1997* and any requirements of the relevant controlling authority.
 - Contaminated groundwater (i.e. above appropriate NEPM 2013 thresholds) shall not be reinjected into any aquifer. The reinjection system design and treatment methods to remove contaminants shall be nominated and included in the initial report and any subsequent intermediate report as necessary. The quality of any pumped water that is to be reinjected must be demonstrated to be compatible with, or improve, the intrinsic or ambient groundwater in the vicinity of the reinjection site.

During excavation

- Engineering measures designed to transfer groundwater around and beneath the basement shall be incorporated into the basement construction to prevent the completed infrastructure from restricting pre-existing groundwater flows.
- Piping, piling or other structures used in the management of pumped groundwater shall not create a flooding hazard or induce mounding of groundwater. Control of pumped groundwater is to be maintained at all times during dewatering to prevent unregulated off-site discharge.
- Measurement and monitoring arrangements to the satisfaction of DPI Water are to be implemented. Weekly records of the volumes of all groundwater pumped and the quality of any water discharged are to be kept and a completion report provided after dewatering has ceased. Records of groundwater levels are to be kept and a summary showing daily or weekly levels in all monitoring bores provided in the completion report.

(Reason: Integrated Development)

3. STREET TREE REMOVAL (SC)

Consent is given for the removal of the Tree 13 *Lophostemon confertus* street tree subject to the following:

- (a) A minimum of one (1) replacement *Lophostemon confertus* shall be provided within the nearby street scape in as directed by Council's tree Co-ordinator .
- (b) Trees are to conform to the *NATSPEC guide* and *Guide for assessing the quality of and purchasing of landscape trees* by Ross Clarke, 2003.
- (c) Replacement trees shall be minimum 50 litre container size. Trees are to be true to type, healthy and vigorous at time of delivery and planting, shall be pest and disease free, free from injury and wounds and self-supporting. Supplied trees are to have an appropriate stem taper. Roots shall generally grow in an outwards (radial) or downwards direction.
- (d) All trees are to be staked and tied with a minimum of three (3) hardwood stakes. Ties are to be hessian and fixed firmly to the stakes, one tie at half the height of the main stem, others as necessary to stabilise the plant.
- (e) Root deflection barriers having a minimum depth of 600mm are to be installed adjacent to all footpaths and driveways.
- (f) Minimum 75mm depth of organic mulch shall be placed within an area 0.5m radius from the base of the tree.

(Reason: Tree removal and replacement)

4. AMENDED LANDSCAPE PLAN (SC)

Prior to the issue of a construction certificate the applicant shall submit and have approved by the Principal Certifying Authority (PCA) a detailed landscape implementation report certifying that landscaping has been provided generally in accordance with the landscape plan prepared by Discount landscape Plans (Drawing No. L/01) dated 4/3/2017 and the Landscape provisions contained within section 10.0 of Part A of the Strathfield Council Development Control Plan. The plans shall include the following:

- (a) A minimum 1.5m wide garden is to be established to the full width of the property frontage (except for vehicular crossings and pedestrian ways). The garden bed is to be planted with suitable shrubs and ground cover plants;

- (b) A detailed planting schedule for all garden areas indicating the species type, height, number and size;
- (c) Soft landscaping shall account for no less than **300m²** of the site;
- (d) Details of all hard and soft surfaces such as turf, gravel, paving, stepping stones and the like shall be shown;
- (e) Gardens should feature a mix of trees, shrubs, grasses and ground covers. A minimum of 25% of all plantings shall be locally indigenous species;
- (f) Evergreen shrubs with a minimum 5 litre container size achieving a minimum mature height of 3m shall be planted along side and rear boundaries to provide privacy screening; and
- (g) The plan shall demonstrate compliance with any other landscape condition of consent.

Should Council not act as the Certifying Authority a copy of the plan shall be forwarded to Council as part of the Construction Certificate.

(Reason: Ensure landscaping is appropriate for the site)

4a. **DRIVEWAY ENTRY (SC)**

The columns attached to the entry driveway on the northern boundary shall be entirely infilled with solid masonry the details of which shall be submitted to the Principal Certifying Authority for approval prior to the issue of the Construction Certificate.

A 1.8m high northern boundary fence shall be constructed for a distance of 2.5m from the column located closest to the front boundary, then dropping down to a horizontal height of 600mm to the Bridge Road boundary.

(Reason: to protect the neighbour's acoustic amenity and for pedestrian safety)

GENERAL CONDITIONS (GC)

5. **APPROVED PLANS AND REFERENCE DOCUMENTATION (GC)**

The development, except where modified by a condition(s) of consent, is to be carried out in accordance with the following plans and reference documentation:

Plans affixed with Council's 'Development Consent' stamp relating to Development Consent No. 2017/059:

Drawing No.	Title/Description	Prepared by	Issue / Revision & Date	Date received by Council
DA1002_A	Site Plan	Urbanlink	B	4 May 2017
DA1003_A	Demolition Site Plan	Urbanlink	B	4 May 2017
DA2001_A	Basement Floor Plan	Urbanlink	B	4 May 2017
DA2001_A	Basement Floor Plan	Urbanlink	B	4 May 2017
DA2002_A	Ground Floor Plan	Urbanlink	B	4 May 2017
DA2004_A	First Floor Plan	Urbanlink	B	4 May 2017
DA2005_A	Floor Plan	Urbanlink	B	4 May 2017
DA2006_A	Floor Plan	Urbanlink	B	4 May 2017

MINUTES

DA2007_A	Roof Floor Plan	Urbanlink	B	4 May 2017
DA3001_A	Elevations	Urbanlink	B	4 May 2017
DA3002_A	Elevations	Urbanlink	B	4 May 2017
DA4001_A	Sections	Urbanlink	B	4 May 2017
DA4002_A	Sections	Urbanlink	B	4 May 2017
DA4003_A	Sections	Urbanlink	B	4 May 2017
DA6301_A	External Finishes	Urbanlink	B	4 May 2017
DA6302_A	External Finishes	Urbanlink	B	4 May 2017
DA5007-A	Compliance & Diagrams- Pre and post adaptations	Urbanlink	B	4 May 2017
L/01	Proposed Landscape Plan – Ground Level	Discount Landscape Plans		4 May 2017
L/02	Proposed Landscape Plan – Level 5	Discount Landscape Plans		4 May 2017
L/03	Proposed Landscape Plan – Level 6	Discount Landscape Plans		4 May 2017
L/04	Landscape Details	Discount Landscape Plans		4 May 2017
L/05	Landscape Specification	Discount Landscape Plans		4 May 2017
A7079 Cover	General Notes	Alpha Engineering & Development	B	4 May 2017
A7079 SW01	Sediment and Erosion Control Plan	Alpha Engineering & Development	B	4 May 2017
A7079 SW02	Basement 2 Drainage Plan	Alpha Engineering & Development	B	4 May 2017
A7079 SW03	Basement 1 Drainage Plan	Alpha Engineering & Development	B	4 May 2017
A7079 SW04	Ground Floor Drainage Plan	Alpha Engineering & Development	B	4 May 2017
A7079 SW05	Stormwater Section Details & Filtration Chamber Sections	Alpha Engineering & Development	B	4 May 2017
A7079 SW06	Music model catchment plan	Alpha Engineering & Development	B	4 May 2017

Reference Documentation affixed with Council's 'Development Consent' stamp relating to Development Consent No.2017/059:

Title / Description	Prepared by	Issue/Revision & Date	Date received by Council
Statement of Environmental Effects	Planning Ingenuity	A	4 May 2017
Access Compliance Report	Vista Access Architects	A	4 May 2017
Acoustic Report	Acoustic Noise & Vibration Solutions	18 April 2017	4 May 2017
Arborist Report	Redgum Horticultural	A	4 May 2017
BASIX Certificate		Cert No: 812715M	4 May 2017
Geotechnical & Hydrogeological Investigation	JK Geotechnics	A	4 May 2017
Traffic Assessment	TTM	A	4 May 2017
Waste Management Plan	Urban Link Pty Limites	A	4 May 2017

In the event of any inconsistency, the conditions of this consent shall prevail.

(Reason: To ensure that the form of the development undertaken is in accordance with the determination of Council.)

6. BUILDING HEIGHT - MAXIMUM RL TO BE COMPLIED WITH (GC)

The height of the building measured to Australian Height Datum (AHD) must not exceed Relative Level (RL) 40.50m AHD to the ridge of the lift overrun structure of the building.

(Reason: To ensure the approved building height is complied with.)

7. CONSTRUCTION HOURS (GC)

No construction or any other work related activities shall be carried out on the site outside the hours of 7.00 am to 5.00 pm Mondays to Fridays and 8am to 1pm Saturdays.

No building activities are to be carried out at any time on a Sunday or public holiday.

Where the development involves the use of jackhammers/ rock breakers and the like or other heavy machinery, such equipment may only be used between the hours of 7.00 am - 5.00 pm Monday to Friday only.

(Reason: To maintain amenity to adjoining land owners.)

8. CONSTRUCTION WITHIN BOUNDARIES (GC)

The development including but not limited to footings, walls, roof barges and guttering must be constructed wholly within the boundary of the premises. No portion of the proposed structure shall encroach onto the adjoining properties. Gates must be installed so they do not open onto any footpath or adjoining land.

(Reason: Approved works are to be contained wholly within the subject site.)

9. DEMOLITION – GENERALLY (GC)

Alteration and demolition of the existing building is limited to that documented on the approved plans (by way of notation). No approval is given or implied for removal and/or rebuilding of any portion of the existing building which is not shown to be altered or demolished.

(Reason: To ensure compliance with the approved development.)

10. **DEMOLITION - SITE SAFETY FENCING (GC)**

Site fencing is to be erected to a minimum height of 1.8m complying with WorkCover Guidelines, to exclude public access to the site, prior to any demolition works occurring and maintained for the duration of the demolition works.

If applicable, a separate Hoarding Application for the erection of an A class (fence type) or B class (overhead type) hoarding along the street frontage(s) complying with WorkCover requirements must be obtained including:

payment to Council of a footpath occupancy fee based on the area of footpath to be occupied and Council's Schedule of Fees and Charges before the commencement of work; and

provision of a Public Risk Insurance Policy with a minimum cover of \$10 million in relation to the occupation of and works within Council's road reserve, for the full duration of the proposed works, must be obtained with a copy provided to Council.

(Reasons: Statutory requirement and health and safety.)

11. **FENCING - FRONT FENCE HEIGHT (GC)**

Solid fencing forward of the building line (including the building line to a secondary street frontage on a corner site) shall not exceed a height of 1m above natural ground level. The fence may be topped by an additional maximum 0.8m high open timber picket, wrought iron, palisade or similar element.

Brick piers over 1m in height are permitted to support the decorative elements, provided they are equally spaced along the street, and do not exceed a height of 1.8m. Plans demonstrating compliance with this condition are to be submitted to the

(Reason: To ensure a positive contribution to the streetscape in accordance with the Strathfield Consolidated DCP 2005.)

12. **LANDSCAPING - IRRIGATION OF COMMON AND PRIVATE LANDSCAPE AREAS (GC)**

All common and private landscape areas including all planters of new multi-unit, commercial, mixed-use and industrial development are to have full coverage by a fully automatic irrigation system. The design, materials and installation are to be in accordance with Sydney Water Codes and satisfy all relevant Australian Standards. Details demonstrating compliance shall be submitted to the Principal Certifying Authority, prior occupation of the premises.

(Reason: To ensure appropriate landscape maintenance.)

13. **LANDSCAPING - TREES PERMITTED TO BE REMOVED (GC)**

The following listed trees are permitted to be removed to accommodate the proposed development however, any of the trees listed below that are located on

adjoining properties must only be removed after consent from the tree's owner has been sought and obtained in writing:

<u>Tree</u>	<u>Height/ Spread (m)</u>	<u>Location</u>
3) Plumeria rubra	5 x 6	Subject property
4) Mangifera indica	4 x 4	Subject property
7) Cinnamomum camphora	10 x 8	Subject property
8)Cinnamomum camphora	7 x 4	Subject property
9)Cinnamomum camphora	6 x 2	Subject property
10) Tibouchina glandulosa	4 x 3	Subject property
13) Lophostemon confertus	8 x 6	Road reserve
14) Phoenix canariensis	5 x 5	Subject property
15) Archontophoenix cunninghamiana	8 x 3	Subject property
16) Ficus benjamina	7 x 5	Adjoining property to the North
17) Tibouchina glandulosa	7 x 5	Subject property
18) Ilex sp.	6 x 5	Subject property
19) Plumeria rubra	5 x 5	Subject property

All trees permitted to be removed by this consent shall be replaced by species selected from Council's Recommended Tree List.

Replacement trees shall be a minimum 50 litre container size and shall be maintained until maturity.

(a) all tree work must be undertaken by a minimum level 2 (AQF 2) qualified Arborist who is currently a member or eligible for membership to Arboriculture Australia (AA) or the Tree Contractors Association Australia (TCAA) and in accordance with AS4373 – Pruning of amenity trees.

(b) Root pruning/root barrier installation must be undertaken by a minimum level 4 (AQF 4) qualified Arborist who is currently a member or eligible for membership to the Arboriculture Australia (AA) of Tree Contractors Association Australia (TCAA) and in accordance with AS4373 – Pruning of amenity trees.

Trees are to conform to the NATSPEC guide and Guide for assessing the quality of and purchasing of landscape trees by Ross Clarke, 2003. Trees are to be true to type, healthy and vigorous at time of delivery and planting, shall be pest and disease free, free from injury and wounds and self-supporting; and shall be maintained until maturity.

All trees are to be staked and tied with a minimum of three (3) hardwood stakes. Ties are to be hessian and fixed firmly to the stakes, one tie at half the height of the main stem, others as necessary to stabilise the plant.

Root deflection barriers having a minimum depth of 600mm are to be installed adjacent to all footpaths and driveways.

Soil conditioner/fertilizer/moisture retention additive/s are to be applied in accordance with manufacturer's recommendations, and mixed into the backfilling soil after planting tree/s.

A minimum 75mm depth of organic mulch shall be placed within an area 0.5m from the base of the tree.

Details demonstrating compliance shall be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: To ensure appropriate planting back onto the site.)

14. LANDSCAPING - TREE PRESERVATION (GC)

All street trees and trees on private property that are protected under Council's controls, shall be retained except where Council's prior written consent has been obtained. The felling, lopping, topping, ringbarking, wilful destruction or removal of any tree/s unless in conformity with this approval or subsequent approval is prohibited.

All healthy trees and shrubs identified for retention on the approved drawings are to be suitably protected in accordance with Australian Standard AS4970 – Protection of Trees on Development Sites, prior to the commencement of any works (including any demolition and excavation) and maintained for the duration of the works.

(Reason: To ensure the protection of trees to be retained on the site.)

15. LIGHTING (GC)

Any lighting of the premises shall be installed and maintained in accordance with Australian Standard AS 4282-1997: Control of the Obtrusive Effects of Outdoor Lighting so as to avoid annoyance to the occupants of adjoining premises or glare to motorists on nearby roads.

No flashing, moving or intermittent lighting, visible from any public place may be installed on the premises or external signage associated with the development, without the prior approval of Council.

(Reason: To protect the amenity of surrounding development and protect public safety.)

16. MATERIALS – CONSISTENT WITH SUBMITTED SCHEDULE (GC)

All external materials, finishes and colours are to be consistent with the schedule submitted and approved by Council with the development application.

(Reason: To ensure compliance with this consent.)

17. PRINCIPAL CERTIFYING AUTHORITY (PCA) IDENTIFICATION SIGN (GC)

Prior to commencement of any work, signage must be erected in a prominent position on the work site identifying:

- i) the Principal Certifying Authority (PCA) by showing the name, address and telephone number of the PCA;
- ii) the Principal Contractor by showing the Principal Contractor's name, address and telephone number (outside of work hours) for that person; and
- iii) the sign must state that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the work is being carried out, but must be removed when the work has been completed.

This clause does not apply to building work, subdivision work or demolition work that is carried out inside an existing building that does not affect the external walls of the building.

(Reason: Statutory requirement.)

18. PRIVACY - SCREEN PLANTING TO SIDE AND REAR BOUNDARIES (GC)

Evergreen shrubs with a minimum 5 litre container size achieving a minimum mature height of 3m shall be planted along the side and rear boundaries to provide suitable privacy screening. Screen planting shall be maintained at all times. Details of the selected plants shall be submitted to and approved by the Principal Certifying Authority. Compliance with this condition shall be certified by the Principal Certifying Authority, prior to occupation of the premises.

(Reason: To maintain privacy amenity to neighbouring residences.)

19. SITE MANAGEMENT (DURING DEMOLITION AND CONSTRUCTION WORKS)

All of the following are to be satisfied/complied with during demolition, construction and any other site works:

- i) All demolition is to be carried out in accordance with Australian Standard AS 2601-2001.
- ii) Demolition must be carried out by a registered demolition contractor.
- iii) A single entrance is permitted to service the site for demolition and construction. The footway and nature strip at the service entrance must be planked out.
- iv) No blasting is to be carried out at any time during construction of the building.
- v) Care must be taken during demolition/ excavation/ building/ construction to prevent any damage to adjoining buildings.
- vi) Adjoining owner property rights and the need for owner's permission must be observed at all times, including the entering onto land for the purpose of undertaking works.
- vii) Any demolition and excess construction materials are to be recycled wherever practicable.
- viii) The disposal of construction and demolition waste must be in accordance with the requirements of the Protection of the Environment Operations Act 1997.
- ix) All waste on the site is to be stored, handled and disposed of in such a manner as to not create air pollution (including odour), offensive noise or pollution of land and/or water as defined by the Protection of the Environment Operations Act 1997. All excavated material should be removed from the site in an approved manner and be disposed of lawfully to a tip or other authorised disposal area.
- x) All waste must be contained entirely within the site.
- xi) Section 143 of the Protection of the Environment Operations Act 1997 requires waste to be transported to a place which can lawfully accept it. All non-recyclable demolition materials are to be disposed of at an approved waste disposal depot in accordance with legislation.
- xii) All materials on site or being delivered to the site are to generally be contained within the site. The requirements of the Protection of the Environment Operations Act 1997 must be complied with when placing/stockpiling loose material, disposing of concrete waste, or other activities likely to pollute drains or water courses.
- xiii) Details as to the method and location of disposal of demolition materials (weight dockets, receipts, etc.) should be kept on site as evidence of approved methods of disposal or recycling.
- xiv) Any materials stored on site must be stored out of view or in such a manner so as not to cause unsightliness when viewed from nearby lands or roadways.
- xv) Public footways and roadways adjacent to the site must be maintained and cleared of obstructions during construction. No building materials, waste containers or skips

- may be stored on the road reserve or footpath without prior separate approval from Council, including payment of relevant fees.
- xvi) Building operations such as brick-cutting, washing tools or paint brushes, and mixing mortar not be performed on the roadway or public footway or any other locations which could lead to the discharge of materials into the stormwater drainage system.
 - xvii) All site waters during excavation and construction must be contained on site in an approved manner to avoid pollutants entering into waterways or Council's stormwater drainage system.
 - xviii) Any work must not prohibit or divert any natural overland flow of water.
 - xix) Toilet facilities for employees must be provided in accordance with WorkCover NSW.
 - xx) Protection pads are to be installed to the kerb and gutter where trucks and vehicles enter the site.

(Reason: To ensure that demolition, building and any other site works are undertaken in accordance with relevant legislation and policy and in a manner which will be non-disruptive to the local area.)

20. **STORMWATER MANAGEMENT PLAN - CERTIFICATION REQUIREMENT (GC)**

A detailed Stormwater Management Plan (SWMP) in line with Council's Stormwater Management Code is to be prepared and certified by a practicing Chartered Professional Engineer on the National Professional Engineer's Register (NPER) at Engineers Australia and submitted to the Principal Certifying Authority and Council, prior to the issue of a Construction Certificate. The SWMP is to be based on the approved development as modified by any conditions of consent.

(Reason: To ensure appropriate provision is made for the disposal and management of stormwater generated by the development, and to ensure public infrastructure in Council's care and control is not overloaded.)

21. **SYDNEY WATER - STAMPED PLANS PRIOR TO COMMENCEMENT (GC)**

The approved plans must be submitted to a Sydney Water Quick Check agent or Customer Centre to determine whether the development will affect Sydney Water's sewer and water mains, stormwater drains and/or easements, and if further requirements need to be met. Plans will be appropriately stamped.

For Quick Check agent details please refer to the web site www.sydneywater.com.au (see Building Developing and Plumbing then Quick Check) or telephone 13 20 92. The consent authority or a Certifying Authority must ensure that a Quick Check agent/Sydney Water has stamped the plans before the commencement of work.

(Reason: Compliance with Sydney Water requirements.)

22. **UTILITIES AND SERVICES - PROTECTION OF (GC)**

Any footings or excavation to be located or undertaken adjacent to Council's stormwater must be designed to address the following requirements:

- i) all footings and excavation must be located wholly within the site and clear of any easement boundaries;
- ii) all footings and excavation must be located a minimum of 1000mm from the centreline of the pipeline or 500mm from the outside of the pipeline, whichever is the greater distance from the centreline; and
- iii) footings must extend to at least the depth of the invert of the pipeline unless the

footings are to be placed on competent bedrock.

If permanent excavation is proposed beneath the overtop of the pipeline, suitable means to protect the excavation and proposed retaining structures from seepage or other water flow from the pipeline and surrounding subsoil, must be provided. The design must be prepared by a qualified practicing Structural/Civil Engineer.

Construction plans must be approved by the appropriate utility's office (e.g. council, Sydney Water Corporation) to demonstrate that the development complies with the utility's requirements.

The applicant must provide written evidence (e.g. compliance certificate, formal advice) of compliance with the requirements of all relevant utility providers (e.g. Water, Energy, Telecommunications, Gas).

(Reason: To ensure protection of Council assets.)

23. **WASTE – TRACKABLE (GC)**

Removal of trackable waste (as defined by the NSW Environment Protection Authority) from the site must comply with the Protection of the Environment Operations (Waste) Regulation 2005 for the transportation, treatment and disposal of waste materials. Waste materials must not be disposed on land without permission of the land owner and must with the provisions of the Protection of the Environment and Operations Act 1997.

(Reason: To ensure compliance with legislation.)

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF A CONSTRUCTION CERTIFICATE (CC)

24. **ACCESS - ACCESS FOR PEOPLE WITH DISABILITIES (CC)**

Access for people with disabilities must be provided in accordance with the requirements of the Building Code of Australia, relevant Australian Standards and with regard to the Disability Discrimination Act 1992. The applicant shall comply with the Access Compliance Report prepared by Vista Access architect dated 4 May 2017.

Plans shall be notated demonstrating compliance and approved by the Principal Certifying Authority, prior to the issue of a Construction Certificate.

Note: Disability (Access to Premises - Buildings) Standards 2010 - As of 1 May 2011, if access is provided to the extent covered by this Standard, then such access cannot be viewed as unlawful under the Disability Discrimination Act 1992.

(Reason: To provide equitable access for people(s) with disabilities in accordance with the relevant legislation and Australian Standards.)

25. **BASIX COMMITMENTS (CC)**

The approved BASIX Certificate shall be submitted to the Principal Certifying Authority with the application for a Construction Certificate.

Where a change or changes are proposed in the BASIX commitments, the applicant must submit a new BASIX Certificate to the Principal Certifying Authority and Council. If any proposed change in the BASIX commitments is inconsistent with the development consent

the applicant will be required to submit a modification to the development consent to Council under Section 96 of the Environmental Planning and Assessment Act 1979.

All commitments in the BASIX Certificate must be shown on the plans accompanying the Construction Certificate.

(Reason: Statutory compliance.)

26. BICYCLE STORAGE PROVISION (CC)

On-site provision for bicycle storage facilities shall be in accordance with the Strathfield Consolidated Development Control Plan 2005. Details demonstrating compliance shall be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Compliance with SCDCP 2005 and to encourage sustainable transport options.)

27. BUILDING CODE OF AUSTRALIA - COMPLIANCE WITH (CC)

All architectural drawings, specifications and related documentation shall comply with the Building Code of Australia (BCA). All work must be carried out in accordance with the requirements of the Building Code of Australia (BCA).

In the case of residential building work for which the Home Building Act 1989 requires there to be a contract of insurance in force in accordance with Part 6 of that Act, such a contract of insurance is to be in force before any building work authorised to be carried out by the consent commences.

Details demonstrating compliance with this condition are to be submitted to the Principle Certifying Authority, prior to issue of the Construction Certificate.

(Reason: This is a 'prescribed' condition under clause 98(1) of the Environmental Planning and Assessment Regulation 2000.)

28. CAR PARKING - REQUIREMENTS FOR MULTIPLE USE BUILDINGS (CC)

The following car parking and service vehicle requirements apply:-

- i) (73) car spaces shall be provided on the development site. This shall consist of:
 - (59) residential spaces;
 - (14) visitor spaces;
- ii) All car spaces shall be allocated and marked according to this requirement.
- iii) If the development is to be strata subdivided, the car park layout must reflect the above allocation and thereafter be regarded as part of the entitlement of that strata lot.
- iv) Under no circumstances shall parking spaces be sold, let or otherwise disposed of for use other than in accordance with this condition.
- v) Each car parking space shall have minimum dimensions in accordance with the relevant Australian Standard and be provided on-site in accordance with the approved plans.
- vi) The parking bays shall be delineated by line marking.
- vii) Visitor spaces shall be clearly line marked and/or signposted and shall only be used by persons visiting residents of the property or commercial/business/retail premises located within the development. Visitor spaces shall not be allocated as permanent residential parking spaces. Access to visitor parking spaces shall not be restricted

without development approval and a sign shall be erected at the vehicular entrance indicating the availability of visitor parking.

viii) The following traffic control measures shall be implemented on site:-

- Signage indicating 'Entry Only' shall be prominently displayed at the entrance to the development.
- Signage indicating 'Exit Only' shall be prominently displayed at the exit to the development.
- One-Way directional arrows shall be painted on the driveway pavement to indicate the required vehicular directional movement through the car parking area.

Details demonstrating compliance with this condition shall be submitted to and approved by the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: To ensure car parking provision in accordance with this consent.)

29. **CAR PARKING - COMPLIANCE WITH AS/NZS 2890.1:2004 (CC)**

Car parking dimensions must comply with the Australian/New Zealand Standard AS/NZS 2890.1:2004 - Parking facilities - Off-street car parking. Details demonstrating compliance are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: To ensure compliance with Australian Standards relating to parking of vehicles.)

30. **COMMENCEMENT OF WORKS (NO WORKS UNTIL A CC IS OBTAINED)**

Building work, demolition or excavation must not be carried out until a Construction Certificate has been issued by either Strathfield Council or a Principal Certifying Authority.

Demolition of any part of a building triggers 'commencement of erection of building' pursuant of section 81A(2) of the EP&A Act 1979. Accordingly, demolition works must not commence until a Construction Certificate has been issued, a Principal Certifying Authority has been appointed and a Notice of Commencement has been issued.

(Reason: To ensure compliance with statutory provisions.)

31. **CONSTRUCTION AND ENVIRONMENTAL MANAGEMENT PLAN (CC)**

The applicant must prepare and submit a Construction and Environmental Management Plan (CEMP) to the Principal Certifying Authority, including:

- i) Detailed information on any approvals required from other authorities prior to or during construction.
- ii) Traffic management, including details of:
 - ingress and egress of vehicles to the site;
 - management of loading and unloading of materials;
 - the location of heavy vehicle parking off-site; and
 - designated routes for vehicles to the site.
- iii) The proposed areas within the site to be used for a builder's site office and amenities, the storage of excavated material, construction materials and waste containers during the construction period.
- iv) Erosion and sediment control, detailing measures and procedures consistent with the requirements of Council's guidelines for managing stormwater, including:

-
- the collection and treatment of stormwater and wastewater generated on site prior to discharge; and
 - procedures to prevent run-off of solid material and waste from the site.
- v) Waste management, including:
- details of the types and estimated volumes of waste materials that will be generated;
 - procedures for maximising reuse and recycling of construction materials; and
 - details of the off-site disposal or recycling facilities for construction waste.
- vi) Dust control, outlining measures to minimise the generation and off-site transmission of dust and fine particles, such as watering or damp cloth fences.
- vii) A soil and water management plan, which includes:
- measures to minimise the area of soils exposed at any one time and conserve top soil;
 - identification and protection of proposed stockpile locations;
 - preservation of existing vegetation and revegetation;
 - measures to prevent soil, sand, sediments leaving the site in an uncontrolled manner;
 - measures to control surface water flows through the site in a manner that diverts clean run-off around disturbed areas, minimises slope gradient and flow distance within disturbed areas, ensures surface run-off occurs at non-erodible velocities, and ensures disturbed areas are promptly rehabilitated;
 - details of sediment and erosion control measures in place before work commences;
 - measures to ensure materials are not tracked onto the road by vehicles entering or leaving the site; and
 - details of drainage to protect and drain the site during works.
- viii) Asbestos management procedures:
- Anyone who removes, repairs or disturbs bonded or a friable asbestos material must hold a current removal licence from Workcover NSW holding either a Friable (Class A) or a Non- Friable (Class B) Asbestos Removal License which ever applies and a current WorkCover Demolition License where works involve demolition. To find a licensed asbestos removalist please see www.workcover.nsw.gov.au
 - Removal of asbestos by a person who does not hold a Class A or Class B asbestos removal license is permitted if the asbestos being removed is 10m² or less of non-friable asbestos (approximately the size of a small bathroom). Friable asbestos materials must only be removed by a person who holds a current Class A asbestos license.
 - Before starting work, a work site-specific permit approving each asbestos project must be obtained from Workcover NSW. A permit will not be granted without a current Workcover licence. All removal, repair or disturbance of or to asbestos material must comply with the following:
 - The Work Health and Safety Act 2011;
 - The Work Health and Safety Regulation 2011;
 - How to Safety Remove Asbestos Code of Practice – WorkCover 2011; and
 - Safe Work Australia Code of Practice for the Management and Control of Asbestos in the Workplace.
 - Following completion of asbestos removal works undertaken by a licensed asbestos removalist re-occupation of a workplace must not occur until an independent and suitably licensed asbestos removalist undertakes a clearance inspection and issues a clearance certificate.
 - The developer or demolition contractor must notify adjoining residents at least two (2) working days (i.e. Monday to Friday exclusive of public holidays) prior to the commencement of asbestos removal works. Notification is to include, at a minimum:

- the date and time when asbestos removal works will commence;
- the name, address and business hours contact telephone number of the demolisher, contractor and/or developer;
- the full name and license number of the asbestos removalist/s; and
- the telephone number of WorkCover's Hotline 13 10 50
- warning signs informing all people nearby that asbestos removal work is taking place in the area. Signs should be placed at all of the main entry points to the asbestos removal work area where asbestos is present. These signs should be weatherproof, constructed of light-weight material and adequately secured so they remain in prominent locations. The signs should be in accordance with AS 1319-1994 Safety signs for the occupational environment for size, illumination, location and maintenance; and
- appropriate barricades installed as appropriate to prevent public access and prevent the escape of asbestos fibres. Barricades must be installed prior to the commencement of asbestos removal works and remain in place until works are completed.

(Reason: Safety, amenity and protection of public infrastructure and the environment.)

32. **COUNCIL PERMITS – FOR ALL ACTIVITIES ON COUNCIL LAND (CC)**

Works Permit

(as per Section 68 of the Local Government Act 1993 and Section 138 and 139 of the Roads Act 1993)

A Works Permit is required for construction of a vehicular crossing (driveway), new stormwater down pipe connection to kerb and gutter, new footpath and/or stormwater connection. A Works Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Standing Plant Permit

This permit must be applied for where it is intended to park a concrete pump, crane or other plant on the roadway or footpath. A Standing Plant Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Skip Bin Permit

This permit must be applied for if you intend to place a skip bin on the roadway or footpath. A Skip Bin Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Temporary Full or Part Road Closure Permit

This permit must be applied for if you require a full or a part road closure to take place to assist in your construction works. Please use the Works Permit Application Form, which is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Hoarding Permit

This permit must be applied for if you intend to erect a Class A (fence type) or Class B (overhead type) hoarding along the street frontage(s). A Hoarding Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's

website. The applicable fees and charges are located on Council's website.

Work Zone Permit

This permit must be applied for if you require permanent parking along the kerbside at the front of the site during construction works. A Work Zone Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Ground Anchoring Permit

This permit must be applied for, for the installation of ground anchors under Council's footway/road reserve. It does not cover ground anchors under private properties. A separate approval is required to be obtained from Roads and Maritime Services (RMS) if it is proposed to install ground anchors under a State or Classified Regional Road (please refer to the end of this application form for more information).

(Reason: Council requirement)

33. EROSION AND SEDIMENTATION CONTROL PLAN (CC)

An Erosion and Sediment Control Plan is to be prepared where construction or excavation activity requires the disturbance of the soil surface and existing vegetation. Details including drawings and specifications must provide adequate measures for erosion and sediment control to ensure:

- i) Compliance with the approved Soil and Water Management Plan.
- ii) Removal or disturbance of vegetation and top soil is confined to within 3m of the approved building area (no trees to be removed without approval).
- iii) All uncontaminated run-off is diverted around cleared or disturbed areas.
- iv) Silt fences or other devices are installed to prevent sediment and other debris escaping from the cleared or disturbed areas into drainage systems or waterways.
- v) All erosion and sediment controls are fully maintained for the duration of demolition/development works.
- vi) Controls are put into place to prevent tracking of sediment by vehicles onto adjoining roadways.
- vii) All disturbed areas are rendered erosion-resistant by turfing, mulching, paving or similar.
- viii) All water pumped or otherwise removed from excavations or basement areas is filtered to achieve suspended solids/non filterable residue levels complying with the Australian Water Quality guidelines for Fresh and Marine Waters.
- ix) Pumped or overland flows of water are discharged so as not to cause, permit or allow erosion before the commencement of work (and until issue of the occupation certificate).

Details of the proposed soil erosion and sedimentation controls are to be submitted to the Principal Certifying Authority with the Construction Certificate Application. Under no circumstances are any works to commence, prior to these details being approved by the Principal Certifying Authority and the controls being in place on the site.

(Reason: Environmental protection.)

34. EXCAVATION - AFFECTING ADJOINING LAND (CC)

If an excavation associated with the approved development extends below the level of the base of the footings of a building on an adjoining allotment of land, the person having the benefit of the development consent must, at the person's own expense, comply with the requirements of clause 98E of the Environmental Planning and Assessment Regulation

2000, including:

- i) protect and support the adjoining premises from possible damage from the excavation, and
- ii) where necessary, underpin the adjoining premises to prevent any such damage.

The condition referred to in subclause (i) does not apply if the person having the benefit of the development consent owns the adjoining land or the owner of the adjoining land has given consent in writing to that condition not applying. Details shall be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Structural safety.)

35. EXCAVATION – SHORING (CC)

Where any shoring for excavation is to be located on or is supporting Council's property, or any adjoining private property, engineering drawings and specifications certifying the shoring will be adequate for their intended purpose and must be submitted to the Council/Principal Certifying Authority for approval with the Construction Certificate. The documentation prepared and certified by an appropriately qualified and practicing structural engineer is to show all details, including the extent of encroachment and the method of removal and de-stressing of shoring elements. A copy of this documentation must be provided to the Council for record purposes at the time of Construction Certificate application.

(Reason: To ensure the protection of existing public infrastructure and adjoining properties.)

36. FIRE SAFETY SCHEDULE (CC)

A Fire Safety Schedule specifying the fire safety measures (both current and proposed) which should be implemented in the building premises must be submitted with the Construction Certificate application, in accordance with Part 9 of Clause 168 of the Environmental Planning and Assessment Regulation 2000.

Note: A Construction Certificate cannot be issued until a Fire Safety Schedule is received.

(Reason: Compliance with the Environmental Planning and Assessment Act 1979.)

37. LANDSCAPING - MAINTENANCE STRATEGY (CC)

To ensure the survival of landscaping following works, a landscape maintenance strategy for the owner/occupier to administer over a 12 month establishment period following the issue of the Occupation Certificate shall be prepared and provided to the satisfaction of the Principal Certifying Authority with the Construction Certificate application. The strategy is to address maintenance issues such as, but not limited to plant survival, irrigation, soil testing, weeding, staking, fertilizing, remedial pruning and plant replacement.

(Reason: Ensure landscape survival.)

38. LANDSCAPING ON SLAB (CC)

To ensure the site landscaping thrives, the on slab landscaping shown on the approved landscaping plan is to be designed to include a minimum soil depth of 650mm for shrubs and trees; and 300mm for grass and ground covers. Adequate drainage provision and a permanent, automatic irrigation system conforming to Sydney Water requirements shall be included. Details demonstrating compliance shall be submitted to the Principal Certifying

Authority with the Construction Certificate application.

(Reason: Ensure landscape survival.)

39. NOISE AND VIBRATION MANAGEMENT PLAN (CC)

Prior to the issue of a Construction Certificate, a Noise and Vibration Management Plan is to be prepared by a suitably qualified person addressing the likely noise and vibration from demolition, excavation and construction of the proposed development and provided to Council or the Principal Certifying Authority.

The Plan is to identify amelioration measures to ensure the noise and vibration levels will be in compliance with:

- a. Construction noise management levels established using the *Interim Construction Noise Guideline (DECC, 2009)*;
- b. Vibration criteria established using the assessing vibration: *Technical guideline (DEC, 2006)* (for human exposure); and
- c. The vibration limits set out in the German Standard DIN 4150-3: *Structural Vibration-effects of vibration on structures* (for structural damage)

The report that itemises equipment to be used for excavation works. The Plan shall address, but shall not be limited to, the following matters:

- i) identification of activities carried out and associated noise sources;
- ii) identification of potentially affected sensitive receivers, including residences, churches, commercial premises, schools and properties containing noise sensitive equipment;
- iii) determination of appropriate noise and vibration objectives for each identified sensitive receiver;
- iv) noise and vibration monitoring, reporting and response procedures;
- v) assessment of potential noise and vibration from the proposed demolition, excavation and construction activities, including noise from construction vehicles;
- vi) description of specific mitigation treatments, management methods and procedures to be implemented to control noise and vibration during construction;
- vii) construction timetabling to minimise noise impacts including time and duration restrictions, respite periods and frequency;
- viii) procedures for notifying residents of construction activities likely to affect their amenity through noise and vibration; and
- ix) contingency plans to be implemented in the event of non-compliances and/or noise complaints. A register should be kept of complaints received, and the action taken to remediate the issue.

(Reason: To protect acoustic amenity of surrounding properties and the public.)

40. PRIVACY - OBSCURE GLAZING IN WET AREAS (CC)

All bathroom, ensuite and toilet windows shall be installed with obscure glazing. Plans shall be notated accordingly and details demonstrating compliance submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Privacy amenity.)

41. REMEDIAL WORKS - PRE-COMMENCEMENT ENVIRONMENTAL MANAGEMENT PLAN (CC)

A Construction Environmental Management Plan (CEMP) shall be prepared for the proposed remedial works in accordance with the requirements of the approved Remedial Action Plan.

The CEMP must be prepared by an appropriately qualified and experienced environmental consultant.

The CEMP for Remediation must include, but is not be limited to, the following:

- i) asbestos management plan;
- ii) project contact information;
- iii) site security details;
- iv) timing and sequencing information;
- v) site soil and water management plan;
- vi) noise and vibration control plan;
- vii) dust control plan;
- viii) air monitoring;
- ix) odour control plan;
- x) health and safety plan;
- xi) waste management plan;
- xii) incident management contingency; and
- xiii) unexpected finds protocol.

The CEMP must be prepared and implemented to the satisfaction of the supervising environmental consultant. The environmental site management measures must remain in place and be maintained throughout the period of the remediation works, until completion of site remediation and the site has been validated.

Note: An appropriately qualified and experienced environmental consultant certified under the Certified Environmental Practitioner" (CEnvP) Scheme or equivalent.

(Reason: To ensure compliance with statutory requirements.)

42. REMEDIAL WORKS - POST WORKS ENVIRONMENTAL MANAGEMENT PLAN (CC)

On completion of remedial works, an Environmental Management Plan (EMP) shall be prepared by an appropriately qualified and experienced environmental consultant. The EMP must be prepared in accordance with relevant NSW EPA Guidelines.

This Long-term EMP shall describe the nature and location of the contamination and prescribe how the contaminants will be managed and the responsible parties for this management in the long-term.

The Long-term EMP shall be submitted for review by a NSW EPA accredited site auditor prior to the commencement of construction and the issue of a construction certificate.

Any future intrusive ground works carried out that have the potential to conflict with any residual contamination remaining onsite must only be carried out in accordance with the Environmental Management Plan as referenced by the Site Auditor on the final Site Audit Statement and approved by the Council.

Note: A Long-term Environmental Management Plan (EMP) is also known as a Long-term

Site Management Plan (SMP).

(Reason: Environmental protection and safety.)

43. REMEDIATION - SITE AUDIT STATEMENT AND VALIDATION REPORT (CC)

Prior to the issue of a Construction Certificate:

All remediation work is to be carried out in accordance with State Environmental Planning Policy No. 55 – Remediation of Land, any contaminated land planning guidelines issued under Section 145C of the Act, any guidelines in force under the Contaminated Land Management Act 1997, and the remediation plan approved under this consent.

- i) A Site Audit Statement (SAS) is to be obtained from a NSW EPA Accredited Site Auditor and submitted to Council. The SAS must confirm that the site has been remediated in accordance with the approved Remediation Action Plan and clearly state that the site is suitable for the proposed use. Where the SAS is subject to conditions that require ongoing review by the Auditor or Council these should be reviewed and approved by Council before the SAS is issued. In circumstances where the SAS conditions (if applicable) are not consistent with the consent, a Section 96 application pursuant to the Environmental Planning & Assessment Act 1979 shall be submitted to ensure that they form part of the consent conditions.
- ii) A Site Validation Report is to be forwarded to Council for approval on completion of the remedial works. The validation report is to be prepared by a NSW EPA accredited site auditor. The report is to satisfactorily document the following:
 - the extent of validation sampling and the results of the validation testing;
 - that the remediation and validation of the site has been undertaken in accordance with Remedial Action Plan, prepared by <insert>, dated <insert>, with reference <insert>; and
 - that the site is suitable for the proposed use.

The applicant must engage an appropriately qualified and experienced supervising environmental consultant to supervise all aspects of site remediation and validation.

(Reason: To ensure compliance with statutory requirements in relation to site remediation works.)

44. SECTION 94 CONTRIBUTION PAYMENT - DIRECT CONTRIBUTIONS PLAN (CC)

In accordance with the provisions of Section 94(1)(b) of the Environmental Planning and Assessment Act 1979 and the Strathfield Direct Development Contributions Plan 2010-2030, a contribution in the form of cash, cheque or credit card (financial transaction fee applies) shall be paid to Council for the following purposes:

Provision of Community Facilities	\$124,090.64
Provision of Major Open Space	\$564,575.27
Provision of Local Open Space	\$368,110.80
Provision Roads and traffic Management	\$34,114.58
Administration	\$10,700.03
TOTAL	\$1,101,591.33

The total amount of the contribution is valid as at the date of determination and is subject to quarterly indexation. Contributions shall be indexed at the time of payment in accordance with clause 2.14 of the Strathfield Direct Development Contributions Plan 2010-2030.

Contributions must be receipted by Council and submitted to the Accredited Certifier, prior

to the issue of any Construction Certificate.

Please present a copy of this condition when paying the contribution at the Customer Service Centre so that it can be recalculated.

Note: A copy of Strathfield Council's Section 94 Direct Development Contributions Plan may be downloaded from Council's website.

(Reason: To enable the provision of public amenities and services required/anticipated as a consequence of increased demand resulting from the development.)

45. **SECURITY PAYMENT - DAMAGE DEPOSIT FOR COUNCIL INFRASTRUCTURE (CC)**

A security (damage deposit) of **\$33,000.00** (calculated in accordance with Council's adopted Fees and Charges) shall be paid to Council, prior to the issue of a Construction Certificate.

The deposit is required as security against any damage to Council property during works on the site. The applicant must bear the cost of all restoration works to Council's property damaged during the course of this development. All building work must be carried out in accordance with the Building Code of Australia.

Payment may be accepted in the form of cash, bank guarantee, cheque or credit card (financial transactions fees apply). Note: Additional fees apply for the lodgement of a bank guarantee in lieu of cash bond applies in accordance with Council's adopted Fees and Charges.

Any costs associated with works necessary to be carried out to rectify any damages caused by the development, shall be deducted from the Damage Deposit.

Note: Should Council property adjoining the site be defective e.g. cracked footpath, broken kerb etc., this should be reported in writing, or by photographic record, submitted to Council at least seven (7) days prior to the commencement of any work on site. This documentation will be used to resolve any dispute over damage to infrastructure. It is in the applicant's interest for it to be as full and detailed as possible.

The damage deposit shall be refunded upon completion of all works upon receipt of a Final Occupation Certificate stage and inspection by Council.

(Reason: Protection of Council infrastructure.)

46. **STORMWATER - RAINWATER RE-USE (CC)**

A rainwater re-use system shall be provided in accordance with either the BASIX minimum requirements, any relevant Council Rainwater Policy and/or specification of the management of stormwater, whichever is applicable. A detailed stormwater plan showing the proposed re-use system shall be submitted to and approved by the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Compliance and amenity.)

47. **STORMWATER DRAINAGE (CC)**

The following stormwater precautions are required to be provided on the site:

- i) Grated drains shall be provided along the basement entry at the vehicular

- crossing(s) and are to connect to the internal drainage system.
- ii) Overflow paths shall be provided to allow for flows in excess of the capacity of the pipe/drainage system draining the site.
 - iii) Allowance shall be made for surface runoff from adjacent properties, and to retain existing surface flow path systems through the site. Any redirection or treatment of these flows shall not adversely affect any other properties
 - iv) Boundary fencing shall be erected in such a manner as not to interfere with the natural flow of ground and surface water to the detriment of any other party.

(Reason: To ensure the site is drained appropriately and does not interfere with the natural flow of flood waters.)

48. **STORMWATER - SILT ARRESTORS AND GROSS POLLUTANT TRAPS (CC)**

Silt and gross pollutant traps shall be fitted in all new stormwater pits and designed in accordance with Council's specification for the management of stormwater. Details demonstrating compliance are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Environmental protection.)

49. **TRAFFIC - CONSTRUCTION TRAFFIC MANAGEMENT PLAN (CC)**

A Construction Traffic Management Plan (CTMP) is to be prepared by an appropriately qualified Traffic Management Consultant and submitted to and approved by Council's Engineering Section, prior to the commencement of any works including demolition.

The following matters should be addressed in the CTMP (where applicable):

- i) description of the demolition, excavation and construction works;
- ii) site plan/s showing the site, roads, footpaths, site access points and vehicular movements;
- iii) size, type and estimated number of vehicular movements (including removal of excavated materials, delivery of materials and concrete to the site);
- iv) proposed route(s) from the arterial (state) road network to the site and the proposed route from the site back to the arterial road network;
- v) impacts of the work and vehicular movements on the road network, traffic and pedestrians and proposed methods to safely manage pedestrians and construction related vehicles in the frontage roadways;
- vi) any Traffic Control Plans (TCP's) proposed to regulate traffic and pedestrian movements for construction activities (such as concrete pours, crane installation/removal etc.);
- vii) proposed hours of construction related activities and vehicular movements to and from the site;
- viii) current/proposed approvals from other Agencies and Authorities (including Roads and Maritime Services, Police and State Transit Authority);
- ix) any activities proposed to be located or impact upon Council's road, footways or any public place;
- x) measures to maintain public safety and convenience;
- xi) any proposed road and/or footpath closures;
- xii) turning areas within the site for construction and spoil removal vehicles, allowing a forward egress for all construction vehicles on the site;
- xiii) locations of work zones (where it is not possible for loading/unloading to occur on the site) in the frontage roadways accompanied by supporting documentation that such work zones have been approved by the Local Traffic Committee and Council;
- xiv) location of any proposed crane and concrete pump and truck standing areas on and

- off the site (and relevant approvals from Council for plant on road);
- xv) a dedicated unloading and loading point within the site for all construction vehicles, plant and deliveries;
 - xvi) material, plant and spoil bin storage areas within the site, where all materials are to be dropped off and collected;
 - xvii) on-site parking area for employees, tradespersons and construction vehicles as far as possible;
 - xviii) proposed areas within the site to be used for the storage of excavated material, construction materials and waste and recycling containers during the construction period; and
 - xix) how it is proposed to ensure that soil/excavated material is not transported onto surrounding footpaths and roadways.

(Reason: To mitigate traffic impacts on the surrounding area during the construction period.)

50. TREE BONDS (CC)

A tree bond of **\$46,200.00** (calculated in accordance with Council's adopted Fees and Charges) shall be paid to Council, prior to the issue of a Construction Certificate.

The deposit is required as security against any damage to existing trees to be retained on Council's road reserve, during works on the site. The applicant must bear the cost of all restoration works to Council's property damaged during the course of this development.

Payment may be accepted in the form of cash, bank guarantee, cheque or credit card (financial transactions fees apply). Note: Additional fees apply for the lodgement of a bank guarantee in lieu of cash bond applies in accordance with Council's adopted Fees and Charges.

(Reason: To ensure the protection of trees to be retained on Council's Road Reserve.)

51. UTILITIES AND TELECOMMUNICATIONS - ELECTRICITY CONNECTION (CC)

Provision must be made for connection to future underground distributions mains. This must be achieved by installing:

- i) an underground service line to a suitable existing street pole; or
- ii) sheathed underground consumers mains to a customer pole erected near the front property boundary (within 1 metre).

Note: A limit of one (1) pole per site will apply.

Any costs associated with the relocation of the above are at the requestor's expense. Any disturbance to public land as a result of the undergrounding of services shall be restored at no cost to Council.

Details are to be submitted to the Principal Certifying Authority with the Construction Certificate Application.

(Reason: Environmental amenity.)

52. UTILITIES AND TELECOMMUNICATIONS - ELECTRICITY SUBSTATION (CC)

Any required electricity substation must be located within the boundaries of the site. Documentary evidence of compliance with the energy authority's requirements, including

correspondence from the energy authority is to be provided to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

Note: Where an electricity substation is required but no provision has been made to place it within the approved building or its site and no details are provided on the approved development consent plans, a section 96 application is required to be submitted to Council for approval of an appropriate location for the required electricity substation.

(Reason: Access to utility.)

53. UTILITIES AND TELECOMMUNICATIONS - TELECOMMUNICATIONS ASSETS (CC)

Provision must be made for relocation of telecommunications network assets including underground placement of any existing aerial cables and infrastructure. Any costs associated with the relocation of the above are at the requestor's expense. Any disturbance to public land as a result of the undergrounding of services shall be restored at no cost to Council.

Details are to be submitted to the Principal Certifying Authority with the Construction Certificate application.

(Reason: To ensure suitable relocation of telecommunications infrastructure if required.)

54. VEHICULAR CROSSINGS - WORKS PERMIT FOR CONSTRUCTION OF (CC)

Full-width, heavy-duty concrete vehicular crossing(s) shall be provided across the footpath at the entrance(s) and/or exit(s) to the site and designed in accordance with Council's guidelines and specifications. In this regard, a Works Permit is to be obtained (available from Council's Customer Services Centre or downloaded from Council's website), and the appropriate fees and charges paid, prior to the lodgement of a Construction Certificate.

(Reason: To ensure appropriate access to the site can be achieved.)

55. VENTILATION SYSTEMS – MECHANICAL (CC)

The mechanical ventilation system is to comply with the following:

- i) The Building Code of Australia;
- ii) Protection of the Environment Operations Act 1997; and
- iii) Australian Standard AS1668-1991.

In addition, odour control measures, such as activated carbon or catalytic oxidisers, must be used to treat ventilation gases prior to discharge. The method of odour control must be designed by a suitably qualified mechanical ventilation engineer.

Details demonstrating compliance with the above are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: To ensure the mechanical ventilation system complies with the relevant requirements/standards.)

56. WASTE - GARBAGE ROOMS OR GREASE ARRESTOR ROOMS (CC)

Garbage rooms or grease arrester rooms must be constructed of solid material: cement rendered and steel trowelled to a smooth even surface. The door to the garbage room is to be designed and constructed to ensure the room is vermin proof and can be opened from

the inside at all times. The garbage room is to be ventilated to the external air by natural ventilation or an approved air handling exhaust system.

(Reason: To keep garbage rooms in a clean and sanitary condition to protect public health.)

57. WASTEWATER CONTROL (CC)

The applicant shall contact Sydney Water, to determine the requirements for the disposal of wastewater and liquid trade waste (including grease traps or grease arrestors). The applicant must provide a copy of the Authority to connect to the sewer system prior to the issue of a Construction Certificate.

There is to be no discharge of wastewater to the stormwater system.

(Reason: To ensure suitable disposal of waste water.)

58. WATER SUSTAINABILITY - WATER SENSITIVE URBAN DESIGN (CC)

Details of the Water Sensitive Urban Design (WSUD) components (stormwater treatment measures) shall be submitted to and approved by the Principal Certifying Authority prior to the issue of a Construction Certificate. Details shall demonstrate compliance with the water conservation and stormwater quality targets set out under Sections 3.1 and 3.2 respectively under Part N of the SCDCP 2005, and be prepared by a suitably qualified professional engineer.

(Reason: To promote Water Sensitive Urban Design.)

59. WATER SUSTAINABILITY – GENERALLY (CC)

Water collected in the rainwater tank must comprise roof water only and not surface water. Water from the rainwater tank must only be used for following purposes and not for human consumption:

- i) toilet flushing;
- ii) clothes washing;
- iii) garden irrigation;
- iv) car washing and similar outdoor uses;
- v) filling swimming pools, spa pools and ornamental ponds; and
- vi) fire fighting.

(Reason: To promote sustainable water management practice.)

60. WATER HEATING SYSTEMS - LOCATION OF (CC)

Water heating systems shall be located so as not to be visible from public places and the ground level of adjoining properties. Details (type and location) of the water heaters shall be submitted to and approved by the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: To maintain streetscape character.)

61. WORKS WITHIN THE ROAD RESERVE (CC)

Detailed drawings including long and short sections and specifications of all works within existing roads (including but not limited to structures, road works, driveway crossings,

footpaths and stormwater drainage) shall be submitted to and approved by Council under Section 138 of the Roads Act 1993 and all fees and charges paid, prior to the issue of a Construction Certificate.

Detailed drawings and specifications are to be prepared and certified by an appropriately qualified Civil Engineer.

Upon completion of the works, the Applicant is to provide to Council with electronic copies of 'Work as Executed Plans'. The plans are to show relevant dimensions and finished levels and are to be certified by a surveyor.

The Applicant is to provide to Council, in an approved format, details of all public infrastructure created as part of the works.

All civil engineering works adjacent/near/outside <insert address> are to be fully supervised by Council. A maintenance period of six (6) months shall apply to the work, after it has been completed and approved. In that period the Applicant shall be liable for any part of the work which fails to perform in the manner outlined in Council's specifications, or as would reasonably be expected under the design conditions.

(Reason: To ensure compliance of engineering works/Council assets are constructed to acceptable standards for engineering works.)

62. **WORKS ZONE - APPROVAL BY COUNCIL'S TRAFFIC COMMITTEEM (CC)**

An application for a 'Works Zone' must be submitted to and approved by the Strathfield Council Traffic Committee prior to the commencement of any site work (including demolition).

The suitability of the proposed length and duration of the Works Zone is to be demonstrated in the application for the Works Zone. The application for the Works Zone must be submitted to Council at least six (6) weeks prior to the commencement of work on the site to allow for assessment and tabling of agenda for the Strathfield Council Traffic Committee.

The requirement for a Works Zone may be varied or waived only if it can be demonstrated in the Construction Traffic Management Plan (to the satisfaction of Council) that all construction related activities (including all loading and unloading operations) can and will be undertaken wholly within the site. The written approval of Council must be obtained to provide a Works Zone or to waive the requirement to provide a Works Zone prior to the commencement of any site work.

(Reason: Council requirement.)

CONDITIONS TO BE SATISFIED PRIOR TO THE COMMENCEMENT OF WORKS (CW)

63. **APPOINTMENT OF A PRINCIPAL CERTIFYING AUTHORITY (PCA) (CW)**

No work shall commence in connection with this Development Consent until:

- i) A construction certificate for the building work has been issued by the consent authority or a Principal Certifying Authority.
- ii) The person having the benefit of the development consent has appointed a principal certifying authority for the building work, and notified the principal certifying authority that the person will carry out the building work as an owner/builder, if that is the case.
- iii) The principal certifying authority has, no later than 2 days before the building work

commences:

- notified the Council of his or her appointment, and
 - notified the person having the benefit of the development consent of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- iv) The person having the benefit of the development consent, if not carrying out the work as an owner-builder, has:
- appointed a principal contractor for the building work who must be the holder of a contractor licence if any residential building work is involved;
 - notified the principal certifying authority of such appointment; and
 - unless that person is the principal contractor, notified the principal contractor of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- v) The person having the person having the benefit of the development consent has given at least 2 days notice to the Council of the person's intention to commence the erection of the building.

Note: If the principal certifying authority is the Council, the nomination will be subject to the payment of a fee for the service to cover the cost of undertaking all necessary inspections and the issue of the appropriate certificates.

Under the Environment Planning and Assessment (Quality of Construction) Act, 2003, a sign must be erected in a prominent position on the work site showing the name, address and telephone number of the principal certifying authority; the name of the principal contractor (if any) for the building work and a telephone number at which that person may be contacted outside working hours. That sign must also state that unauthorised entry is prohibited. The sign must not be removed until all work has been completed.

(Reason: Statutory requirement.)

64. **NOTICE OF COMMENCEMENT (CW)**

No work shall commence until the following details are submitted to Council:

- i) a Notice of Commencement (form will be attached with issue of a Construction Certificate or available from our website) within two (2) days of the date on which it is proposed to commence works associated with the Development Consent;
- ii) details of the appointment of a Principal Certifying Authority (either Council or another Principal Certifying Authority); and
- iii) details of the name, address and licence details of the Builder.

(Reason: Statutory requirement.)

CONDITIONS TO BE SATISFIED DURING DEMOLITION AND BUILDING WORKS (DW)

65. **CONTAMINATED LAND UNEXPECTED FINDS (DW)**

In the instance works cause the generation of odours or uncovering of unexpected contaminants works are to immediately cease, Council is to be notified and a suitably qualified environmental scientist appointed to further assess the site.

The contaminated land situation is to be evaluated by the supervising environmental consultant and an appropriate response determined in consultation with the applicant, which is agreed to by Strathfield Council's Environmental Services Manager.

Note: Council may also request that a NSW EPA accredited site auditor is involved to assist

with the assessment of the contaminated land situation and review any new contamination information. The applicant must also adhere to any additional conditions which may be imposed by the accredited site auditor.

(Reason: To ensure compliance with statutory requirements.)

66. FILL MATERIAL (DW)

The only waste derived material which may be received at the development site is:

- i) Virgin excavated material (within the meaning of the Protection of the Environment Operations Act 1997), and
- ii) any other waste-derived material the subject of a resource recovery exemption under cl.51A of the Protection of the Environment Operations (Waste) Regulation 2005 that is permitted to be used as fill material.

Any (b)-type material received at the development site must be accompanied by documentation certifying by an appropriately qualified environmental consultant the materials compliance with the exemption conditions; and this documentation must be provided to the Principal Certifying Authority on request.

(Reason: To ensure imported fill is of an acceptable standard for environmental protection purposes.)

67. OBSTRUCTION OF PUBLIC WAY NOT PERMITTED DURING WORKS (DW)

The public way must not be obstructed by any materials, vehicles, refuse, skips or the like, under any circumstances, without the prior approval of Council.

(Reason: To maintain public access and safety.)

68. PUBLIC INFRASTRUCTURE AND SERVICES (DW)

The applicant must comply with the requirements (including financial costs) of any relevant utility provider (e.g. Energy Australia, Sydney Water, Telstra, RMS, Council etc.) in relation to any connections, works, repairs, relocation, replacements and/or adjustments to public infrastructure or services affected by the development.

(Reason: To maintain public infrastructure and/or services.)

69. SITE REQUIREMENTS DURING DEMOLITION AND CONSTRUCTION

All of the following are to be satisfied/complied with during demolition, construction and any other site works:

- i) All demolition is to be carried out in accordance with Australian Standards AS 2601-2001.
- ii) Demolition must be carried out by a registered demolition contractor.
- iii) A single entrance is permitted to service the site for demolition and construction. The footway and nature strip at the service entrance must be planked out with close boarded, hardwood timber footpath protection pads. The pad shall cover the entire width of the footpath opening for the full width of the fence.
- iv) No blasting is to be carried out at any time during construction of the building.
- v) Care must be taken during demolition/ excavation/ building/ construction to prevent any damage to adjoining buildings.
- vi) Adjoining owner property rights and the need for owner's permission must be

- observed at all times, including the entering onto land for the purpose of undertaking works.
- vii) Any demolition and excess construction materials are to be recycled wherever practicable.
 - viii) The disposal of construction and demolition waste must be in accordance with the requirements of the Protection of the Environment Operations Act 1997.
 - ix) All waste on the site is to be stored, handled and disposed of in such a manner as to not create air pollution (including odour), offensive noise or pollution of land and/or water as defined by the Protection of the Environment Operations Act 1997.
 - x) All excavated material should be removed from the site in the approved manner and be disposed of lawfully to a tip or other authorised disposal area.
 - xi) Section 143 of the Protection of the Environment Operations Act 1997 requires waste to be transported to a place which can lawfully accept it. All non-recyclable demolition materials are to be disposed of at an approved waste disposal depot in accordance with legislation.
 - xii) All materials on site or being delivered to the site are to generally be contained within the site. The requirements of the Protection of the Environment Operations Act 1997 must be complied with when placing/stockpiling loose material, disposing of concrete waste, or other activities likely to pollute drains or water courses.
 - xiii) Details as to the method and location of disposal of demolition materials (weight dockets, receipts etc.) should be kept on site as evidence of approved methods of disposal and recycling.
 - xiv) Any materials stored on site must be stored out of view or in such a manner so as not to cause unsightliness when viewed from nearby lands or roadways.
 - xv) Public footways and roadways adjacent to the site must be fully maintained and cleared of obstructions during construction unless prior separate approval from Council is obtained including payment of relevant fees.
 - xvi) Building operations such as brick cutting, washing tools or paint brushes, and mixing mortar not be performed on the roadway or public footway or any other locations which could lead to the discharge of materials into the stormwater drainage system.
 - xvii) All site waters during excavation and construction must be contained on site in an approved manner to avoid pollutants entering into waterways or Council's stormwater drainage system.
 - xviii) Stamped plans, specifications, documentation and the consent shall be available on site at all times during construction.

(Reason: To ensure that demolition, building and any other site works are undertaken in accordance with relevant legislation and policy and in a manner which will be non-disruptive to the local area.)

70. **SURVEY REPORT OF APPROVED LEVELS DURING AND POST CONSTRUCTION (DW)**

A Survey Certificate to Australian Height Datum shall be prepared by a Registered Surveyor as follows:

- i) At the completion of the first structural floor level prior to the pouring of concrete indicating the level of that floor and the relationship of the building to the boundaries.
- ii) At the completed height of the building, prior to the placement of concrete form work, or the laying of roofing materials.
- iii) At the completion of the development.

Progress certificates in response to points (1) through to (3) shall be provided to the Principal Certifying Authority at the time of carrying out relevant progress inspections. Under no circumstances is work allowed to proceed until such survey information is submitted to and approved by the Principal Certifying Authority.

(Reason: To ensure compliance with the approved plans.)

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF AN OCCUPATION CERTIFICATE (OC)

71. DELETED

72. CAR PARKING - SURPLUS VEHICULAR CROSSINGS (OC)

All surplus vehicular crossings and/or kerb laybacks must be removed and reinstated with concrete kerb and gutter or to the existing edging profile as specified by Council. The nature strip is to be restored and the footpath area reinstated. All of the above are to be restored to the satisfaction of Council's Engineer and at full cost to the applicant, prior to the issue of any Occupation Certificate.

(Reason: Maintenance of public infrastructure.)

73. CAR PARKING - VISITOR CAR PARKING SIGNAGE (OC)

A sign shall be erected in a suitable location on the property near the driveway entrance indicating where visitor parking is available on the site. Signage shall also be erected above the visitor parking itself. Details demonstrating compliance shall be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: Adequate access and egress.)

74. ENGINEERING WORKS (CERTIFICATION OF)

Prior to occupation of the premises, a Work As Executed (WAE) Plan of all engineering and/or drainage works is to be submitted to the Principal Certifying Authority. The WAE Plan is to be certified by a suitably Qualified Engineer, with Corporate Membership standing in the Institution of Engineers Australia and registered on the National Professional Engineers Register (NPER) under the appropriate professional category, demonstrating that:

- i) the stormwater drainage system; and/or
- ii) the car parking arrangement and area; and/or
- iii) any related footpath crossing works; and/or
- iv) the proposed basement pump and well system; and/or
- v) the proposed driveway and layback; and/or
- vi) any other civil works

have been constructed in accordance with the approved plans and any relevant Standards and Council policies/specifications.

For major works, such as subdivisions, works within the road reserve (requiring separate S138 approval) and as where specified by Council, a Part 4A Certificate will be required. It is strongly recommended that an Engineer supervise all engineering related works.

Where Council is not the Principal Certifying Authority, an electronic copy of the above documents is to be provided to Council, prior to the issue of any Occupation Certificate.

(Reason: Asset management.)

75. FIRE SAFETY CERTIFICATION (OC)

A fire safety certificate shall be obtained in accordance with Part 9, Division 4 of the Environmental Planning and Assessment Regulation 2000, prior to the issue of any Occupation Certificate.

An fire safety certificate is a certificate issued by the owner of a building to the effect that each essential fire safety measure specified in the current fire safety schedule for the part of the building to which the certificate relates:

- i) has been assessed by a properly qualified person; and
- ii) was found, when it was assessed, to be capable of performing to at least the standard required by the current fire safety schedule for the building for which the certificate is issued.

An interim fire safety certificate must be provided before an interim occupation certificate can be used for a building under Clause 153(2) of the Environmental Planning & Assessment Regulation 2000.

A final fire safety certificate must be provided before an interim occupation certificate can be used for a building under Clause 153(1) of the Environmental Planning & Assessment Regulation 2000.

A copy of the fire safety certificate and fire safety schedule shall be:

- i) submitted to Strathfield Council;
- ii) submitted to the Commissioner of the New South Wales Fire Brigade; and
- iii) prominently displayed in the building.

(Reason: Fire safety and statutory requirement.)

76. LANDSCAPING - ARBORIST'S FOLLOW UP REPORT OF TREE/S TO BE RETAINED (OC)

As part of the on-going assessment of the tree/s to be retained, the consulting arborist engaged by the applicant is to assess their health and any impacts suffered by them as a result of the proposed approved development, prior to the issue of an Occupation Certificate. Findings are to be compiled in a detailed report and submitted to the Principle Certifying Authority, which documents the following:

- i) methods of excavation or construction used to carry out the works;
- ii) any damage sustained by the tree/s as a result of the works;
- iii) any subsequent remedial works required to be carried out by the consulting arborist as a result of the damage; and
- iv) any future or on-going remedial work required to be carried out to ensure the long term retention of the tree/s.

(Reason: To ensure the survival of trees to be retained.)

77. LANDSCAPING - STREET TREE REMOVAL AND REPLACEMENT TREE COST (OC)

No existing street trees can be removed without Council approval. Where such approval is granted, the applicant shall meet the full cost to remove the tree and plant a replacement tree of 200 litre container size at the time of planning and selected from Council's Recommended Tree List. Specimens must be in accordance with NATSPEC specifications and guidelines and maintained for a twelve (12) month establishment phase. If the

specimen fails to thrive or is otherwise damaged it shall be replaced at full cost to the applicant and maintained for a further twelve (12) months.

The replacement tree is to be planted within one (1) week of Council's street tree being removed and undertaken prior to the issue of any Occupation Certificate.

(Reason: Tree preservation and environmental amenity.)

78. STORMWATER - CERTIFICATION OF THE CONSTRUCTED DRAINAGE SYSTEM (OC)

The constructed stormwater system shall be certified by a suitably qualified person, in accordance with Council's Stormwater Management Code, prior to the issue of any Occupation Certificate.

(Reason: Adequate stormwater management.)

79. STORMWATER - COVENANT AND RESTRICTION AS TO USER FOR STORMWATER CONTROLLED SYSTEMS (OC)

Prior to the issue of any Occupation Certificate, the applicant shall register a Positive Covenant and a Restriction as to User under section 88E and or section 88B of the Conveyancing Act as appropriate in favour of Council, ensuring the ongoing retention, maintenance and operation of the stormwater facility (on-site detention, pump-out, charged lines, etc.).

Where any drainage line or service conduit is to traverse any property other than that which it serves, an appropriate easement will be required. In this case, the applicant shall register an easement no less than 1200mm wide over the proposed drainage line or service concurrently with any subdivision registration.

The wording on the 88B Instrument is to make reference to the Council file where the Construction plans and the Work As Executed (as built), plans are held. Typical wording can be obtained from Council's Specification for the Management of Stormwater document.

(Reason: To ensure the on-site detention and/or pump system is maintained to an appropriate operational standard.)

80. SUBDIVISION - EVIDENCE OF CONSOLIDATION (OC)

The existing allotments shall be consolidated into a single lot. Evidence that the plan of consolidation has been registered as a deposited plan with the Land and Property Information Office must be submitted to Council, prior to occupation of the site.

(Reason: Proper management of land.)

81. SEPARATE APPLICATION FOR STRATA SUBDIVISION (SC)

This consent does not imply approval to create a separate title, by subdivision or otherwise. Should it be intended to subdivide the approved development into strata title allotments, Council will require the lodgement of a separate development application for consideration.

(Reason: To ensure compliance with the consent.)

CONDITIONS TO BE SATISFIED DURING ONGOING USE OF THE PREMISES (OU)**82. NOISE - COMPLIANCE WITH ACOUSTIC ASSESSMENT REPORT (OU)**

All recommendations contained in the approved Acoustic Assessment Report prepared by Acoustic Noise and Vibration Solutions Pty Ltd shall be adopted, implemented, and adhered to.

The Principal Certifying Authority (PCA) shall obtain a statement from an appropriately qualified acoustic consultant, certifying that the acoustic mitigation measures outlined in the above stated report have been suitably incorporated into the development and that relevant noise criteria have been satisfied prior to the issue of any Occupation Certificate.

Any changes made to the proposal that would alter the acoustic assessment will require a further acoustic assessment and a copy of this further report shall be provided to Council for approval prior to the commencement of works and any recommendations adopted, implemented, and adhered to.

(Reason: Noise control and amenity.)

83. POLLUTION - COMPLIANCE WITH PEOA 1997 GENERALLY (OU)

The activities carried out on site shall not constitute a nuisance in relation to noise, air or water pollution as specified under the Protection of the Environment Operations Act 1997.

(Reason: Environmental protection.)

84. WASTE AND RECYCLING COLLECTION HOURS (OU)

The collection of waste and recycling must only occur between 6.00am and 8.00pm weekdays and 9.00am and 5.00pm weekends and public holidays, to avoid noise disruption to the surrounding area.

Garbage and recycling must not be placed on the kerbside for collection more than one hour before the scheduled collection time. Bins and containers are to be removed from the kerbside within one (1) hour of collection and returned to the designated garbage storage area(s).

The garbage and recyclable storage area and bins must be adequate to contain the volume and type of garbage and recyclable matter of the food premises.

All garbage and recyclable matter must be enclosed in the waste bins with lids completely closed at all times.

(Reason: To regulate noise and garbage collection arrangements.)

RESOLUTION

We find Clause 4.6 well founded and approve this application as a **Deferred Commencement** subject to the conditions in the assessment report as amended by the panel.

For the Decision: Stein, Atkins, Evernden, Smith

Against the Decision: Nil

**** End Minutes - Report No. 1****

TO: Strathfield Independent Hearing and Assessment Panel Meeting - 3 August 2017

REPORT: SIHAP – Report No. 2

SUBJECT: 15 HOMEBUSH ROAD, STRATHFIELD
LOT 5 DP31394

DA NO. 2017/061

RECOMMENDATION

In consideration of the written request made by the applicant pursuant to Clause 4.6 of the Strathfield Local Environmental Plan 2012, the consent authority is satisfied that compliance with the development standard contained in Clause 4.3 Height of buildings of the SLEP 2012 is well founded and that there are sufficient environmental planning grounds to justify contravening the development standard.

That Development Application No. DA2017/061 for demolition of existing structures and construction of a four (4) storey residential flat building comprised of (14) units over a single level of basement car parking at 15 Homebush Road, Strathfield be **APPROVED**, subject to the following conditions:

SPECIAL CONDITIONS (SC)

1. FRONT FENCE (SC)

The metal infill component of the front fence is to be deleted to provide a low lying brick fence. Amended plans including such changes are to be submitted to and approved by the Principal Certifying Authority **prior to the issue of a Construction Certificate.**

(Reason: Streetscape)

2. COVERED WALKWAY (SC)

The covered walkway structure from the front boundary to the main entry door is to be deleted. Amended plans including such changes are to be submitted to and approved by the Principal Certifying Authority **prior to the issue of a Construction Certificate.**

(Reason: Streetscape and overshadowing)

3. UNIT 3.03 BALCONY (SC)

The northern and western portions of the glass balustrade to the balcony of unit 3.03 is to be setback an additional 1m from the position shown upon Roof & Site Plan Level 3 Floor Plan, Dwg No. DA.04, received by Council 23 June 2017. Amended plans including such changes are to be submitted to and approved by the Principal Certifying Authority **prior to the issue of a Construction Certificate.**

(Reason: Streetscape)

4. UNIT 1.01, 2.01 AND 3.01 BALCONIES (SC)

The internal configuration of units 1.01, 2.01 and 3.01 is to be amended to orientate the balconies to the sites western boundary. Amended plans including such changes are to be submitted to and approved by the Principal Certifying Authority **prior to the issue of a**

Construction Certificate.

(Reason: Visual privacy)

GENERAL CONDITIONS (GC)**5. APPROVED PLANS AND REFERENCE DOCUMENTATION (GC)**

The development, except where modified by a condition(s) of consent, is to be carried out in accordance with the following plans and reference documentation:

Plans affixed with Council's 'Development Consent' stamp relating to Development Consent No.2017/061:

Drawing No.	Title/Description	Prepared by	Issue / Revision & Date	Date received by Council
D.01	Demolition Plan	Bechara Chan & Associates	B	9 May 2017
DA.02	Ground Floor Plan	Bechara Chan & Associates	C	23 June 2017
DA.03	Level 1 & 2 Floor Plan	Bechara Chan & Associates	C	23 June 2017
DA.04	Roof & Site Plan Level 3 Floor Plan	Bechara Chan & Associates	C	23 June 2017
DA.05	Elevations	Bechara Chan & Associates	C	23 June 2017
DA.06	Sections	Bechara Chan & Associates	C	23 June 2017
L-01	Landscape Plan	Sussan Zindo Landscape Architect	A	9 May 2017
D00	Cover Sheet Legend and Drawing Schedule	Loka Consulting Engineers	A	9 May 2017
D01	Basement Stormwater Drainage Plan and Details	Loka Consulting Engineers	A	9 May 2017
D02	Ground Floor/ Site Stormwater Drainage Plan	Loka Consulting Engineers	A	9 May 2017
D03	Site Stormwater Drainage Details	Loka Consulting Engineers	A	9 May 2017
D04	Erosion and Sediment Control Plan and Details	Loka Consulting Engineers	A	9 May 2017

Reference Documentation affixed with Council's 'Development Consent' stamp relating to Development Consent No. 2017/061:

Title / Description	Prepared by	Issue/Revision & Date	Date received by Council
---------------------	-------------	-----------------------	--------------------------

Statement of Environmental Effects	Creative Planning Solutions	May 2017	9 May 2017
BASIX Certificate	Building Sustainability Assessments	808334M	9 May 2017
Traffic Management Plan	Loka Consulting Engineers	16NL243-T2	9 May 2017
Waste Management Plan	Gihad Bechara	23 March 2017	9 May 2017
Arboricultural Impact Assessment and Tree Management Plan	Horticultural Management Services	6 March 2017	9 May 2017

In the event of any inconsistency between the approved plans and supplementary documentation, the plans will prevail. However, the conditions of this consent shall prevail to the extent of any inconsistency.

(Reason: To ensure that the form of the development undertaken is in accordance with the determination of Council.)

6. BUILDING HEIGHT - MAXIMUM RL TO BE COMPLIED WITH (GC)

The height of the building measured to Australian Height Datum (AHD) must not exceed Relative Level (RL) 32.15AHD to the top of the lift over run structure of the building.

(Reason: To ensure the approved building height is complied with.)

7. CONSTRUCTION HOURS (GC)

No construction or any other work related activities shall be carried out on the site outside the hours of 7.00 am to 5.00 pm Mondays to Fridays and 8am to 1pm Saturdays.

No building activities are to be carried out at any time on a Sunday or public holiday.

Where the development involves the use of jackhammers/ rock breakers and the like or other heavy machinery, such equipment may only be used between the hours of 7.00 am - 5.00 pm Monday to Friday only.

(Reason: To maintain amenity to adjoining land owners.)

8. CONSTRUCTION WITHIN BOUNDARIES (GC)

The development including but not limited to footings, walls, roof barges and guttering must be constructed wholly within the boundary of the premises. No portion of the proposed structure shall encroach onto the adjoining properties. Gates must be installed so they do not open onto any footpath or adjoining land.

(Reason: Approved works are to be contained wholly within the subject site.)

9. DEMOLITION – GENERALLY (GC)

Alteration and demolition of the existing building is limited to that documented on the approved plans (by way of notation). No approval is given or implied for removal and/or rebuilding of any portion of the existing building which is not shown to be altered or

demolished.

(Reason: To ensure compliance with the approved development.)

10. **DEMOLITION - SITE SAFETY FENCING (GC)**

Site fencing is to be erected to a minimum height of 1.8m complying with WorkCover Guidelines, to exclude public access to the site, prior to any demolition works occurring and maintained for the duration of the demolition works.

If applicable, a separate Hoarding Application for the erection of an A class (fence type) or B class (overhead type) hoarding along the street frontage(s) complying with WorkCover requirements must be obtained including:

payment to Council of a footpath occupancy fee based on the area of footpath to be occupied and Council's Schedule of Fees and Charges before the commencement of work; and

provision of a Public Risk Insurance Policy with a minimum cover of \$10 million in relation to the occupation of and works within Council's road reserve, for the full duration of the proposed works, must be obtained with a copy provided to Council.

(Reasons: Statutory requirement and health and safety.)

11. **LANDSCAPING - CANOPY TREES IN FRONT SETBACK (GC)**

New development shall provide at least two (2) canopy trees within the front setback adjacent the front boundary. New canopy trees shall be at least three (3) metres high at the time of planting and capable of reaching a mature height of 10m.

Species shall be selected from Council's Recommended Tree List (Available from Council's website or from the Customer Service Centre). Compliance with this condition is to be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: To ensure the landscape character of the locality is maintained.)

12. **LANDSCAPING - IRRIGATION OF COMMON AND PRIVATE LANDSCAPE AREAS (GC)**

All common and private landscape areas including all planters are to have full coverage by a fully automatic irrigation system. The design, materials and installation are to be in accordance with Sydney Water Codes and satisfy all relevant Australian Standards. Details demonstrating compliance shall be submitted to the Principal Certifying Authority, prior occupation of the premises.

(Reason: To ensure appropriate landscape maintenance.)

13. **LANDSCAPING - TREES PERMITTED TO BE REMOVED (GC)**

The following listed trees are permitted to be removed to accommodate the proposed development:

Tree	Height/ Spread (m)	Location
2)Lagerstroemia indica	5 x 3	Front setback, subject property
4)Nerium oleander	2.5 x 2	Front setback, subject property

5)Plumeria rubra var Acutifolia	3 x 3	Front setback, subject property
6)Liquidambar styraciflua	9 x 6	Front setback, subject property
7)Ligustrum lucidum	8 x 5	Rear yard, subject property
8) Morus nigra	5 x 5	Rear yard, subject property

All trees permitted to be removed by this consent shall be replaced by species selected from Council's Recommended Tree List.

Replacement trees shall be a minimum 50 litre container size. Trees are to conform to the NATSPEC guide and Guide for assessing the quality of and purchasing of landscape trees by Ross Clarke, 2003. Trees are to be true to type, healthy and vigorous at time of delivery and planting, shall be pest and disease free, free from injury and wounds and self-supporting; and shall be maintained until maturity.

All trees are to be staked and tied with a minimum of three (3) hardwood stakes. Ties are to be hessian and fixed firmly to the stakes, one tie at half the height of the main stem, others as necessary to stabilise the plant.

Root deflection barriers having a minimum depth of 600mm are to be installed adjacent to all footpaths and driveways.

Soil conditioner/fertilizer/moisture retention additive/s are to be applied in accordance with manufacturer's recommendations, and mixed into the backfilling soil after planting tree/s.

A minimum 75mm depth of organic mulch shall be placed within an area 0.5m from the base of the tree.

Details demonstrating compliance shall be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: To ensure appropriate planting back onto the site.)

14. LANDSCAPING - TREE PRESERVATION (GC)

The trees listed below shall be retained at all times:

<u>Tree</u>	<u>Height/ Spread (m)</u>	<u>Location</u>	<u>Protection Zone (m)</u>	<u>Structural Root Zone (m)</u>
1)Lophostemon confertus	9 x 5	Road reserve	5.75	2.47
3) Lophostemon confertus	9 x 5	Road reserve	6.0	2.55
9)Callistomon viminalis	5 x 4	Adjoining, West	2.5	1.65
10) Chamaecyparis obtusa 'Gracilis'	7 x 4	Adjoining, South	3.35	2.0
11) Chamaecyparis obtusa 'Gracilis'	7 x 4	Adjoining, South	3.35	2.0

and protected by the establishment of a **protection zone** (in accordance with Australian Standard AS4970-*Protection of trees on development sites*) before any site works begin (including any demolition/excavation). The protection zone shall be maintained for the duration of works and implemented as follows:

- (a) A minimum 1.8m high barrier (Chain wire mesh panels, plywood or wooden paling fence panels: refer to *AS4687-Temporary fencing and hoardings* for fencing requirements) shall be erected around the perimeter of the stated Protection Zone as measured from the base of the tree (or where practical). Shade cloth or similar should be attached to reduce the transport of dust, other particulate matter and liquids into the protected area. Fence posts and supports should have a diameter greater than 20mm and be located clear of roots. The barrier shall be constructed so as to prevent pedestrian and vehicular entry into the protection zone. The barrier shall not project beyond the kerb onto the roadway or any adjacent footpath.
- (b) Signs identifying the Protection Zone should be installed on the fencing and be visible from within the development site. Lettering should comply with *AS4970-2009: Protection of Trees on Development Sites*.
- (c) No concrete slurry or wash, building materials, builders' rubble, excavation soil or similar shall be placed or stored within the tree protection zone.
- (d) The whole of the tree protection zone shall be mulched to a minimum depth of 75mm.
- (e) The tree protection zone shall be regularly watered.
- (f) Any major structural roots which are encountered shall be pruned by a qualified Arborist.
- (g) **No excavation or construction shall be carried out** within the stated *Structural Root Zone* distances from the base of the trunk surface.
- (h) Only permeable surfaces (e.g. decomposed granite, gravel, turfpave, permeable paving systems or soft landscaping) are permitted within the canopy spread of the trees to be protected.

(Reason: To ensure the protection of trees to be retained on the site.)

15. **MATERIALS – CONSISTENT WITH SUBMITTED SCHEDULE (GC)**

All external materials, finishes and colours are to be consistent with the schedule submitted and approved by Council with the development application.

(Reason: To ensure compliance with this consent.)

16. **PRINCIPAL CERTIFYING AUTHORITY (PCA) IDENTIFICATION SIGN (GC)**

Prior to commencement of any work, signage must be erected in a prominent position on the work site identifying:

- i) the Principal Certifying Authority (PCA) by showing the name, address and telephone number of the PCA;
- ii) the Principal Contractor by showing the Principal Contractor's name, address and telephone number (outside of work hours) for that person; and
- iii) the sign must state that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the work is being carried out, but must be removed when the work has been completed.

This clause does not apply to building work, subdivision work or demolition work that is carried out inside an existing building that does not affect the external walls of the building.

(Reason: Statutory requirement.)

17. PRIVACY - SCREEN PLANTING TO SIDE AND REAR BOUNDARIES (GC)

Evergreen shrubs with a minimum 5 litre container size achieving a minimum mature height of 3m shall be planted along the side and rear boundaries to provide suitable privacy screening. Screen planting shall be maintained at all times. Details of the selected plants shall be submitted to and approved by the Principal Certifying Authority. Compliance with this condition shall be certified by the Principal Certifying Authority, prior to occupation of the premises.

(Reason: To maintain privacy amenity to neighbouring residences.)

18. SITE MANAGEMENT (DURING DEMOLITION AND CONSTRUCTION WORKS)

All of the following are to be satisfied/complied with during demolition, construction and any other site works:

- i) All demolition is to be carried out in accordance with Australian Standard AS 2601-2001.
- ii) Demolition must be carried out by a registered demolition contractor.
- iii) A single entrance is permitted to service the site for demolition and construction. The footway and nature strip at the service entrance must be planked out.
- iv) No blasting is to be carried out at any time during construction of the building.
- v) Care must be taken during demolition/ excavation/ building/ construction to prevent any damage to adjoining buildings.
- vi) Adjoining owner property rights and the need for owner's permission must be observed at all times, including the entering onto land for the purpose of undertaking works.
- vii) Any demolition and excess construction materials are to be recycled wherever practicable.
- viii) The disposal of construction and demolition waste must be in accordance with the requirements of the Protection of the Environment Operations Act 1997.
- ix) All waste on the site is to be stored, handled and disposed of in such a manner as to not create air pollution (including odour), offensive noise or pollution of land and/or water as defined by the Protection of the Environment Operations Act 1997. All excavated material should be removed from the site in an approved manner and be disposed of lawfully to a tip or other authorised disposal area.
- x) All waste must be contained entirely within the site.
- xi) Section 143 of the Protection of the Environment Operations Act 1997 requires waste to be transported to a place which can lawfully accept it. All non-recyclable demolition materials are to be disposed of at an approved waste disposal depot in accordance with legislation.
- xii) All materials on site or being delivered to the site are to generally be contained within the site. The requirements of the Protection of the Environment Operations Act 1997 must be complied with when placing/stockpiling loose material, disposing of concrete waste, or other activities likely to pollute drains or water courses.
- xiii) Details as to the method and location of disposal of demolition materials (weight dockets, receipts, etc.) should be kept on site as evidence of approved methods of disposal or recycling.
- xiv) Any materials stored on site must be stored out of view or in such a manner so as not to cause unsightliness when viewed from nearby lands or roadways.
- xv) Public footways and roadways adjacent to the site must be maintained and cleared of obstructions during construction. No building materials, waste containers or skips may be stored on the road reserve or footpath without prior separate approval from Council, including payment of relevant fees.
- xvi) Building operations such as brick-cutting, washing tools or paint brushes, and mixing mortar not be performed on the roadway or public footway or any other locations

- which could lead to the discharge of materials into the stormwater drainage system.
- xvii) All site waters during excavation and construction must be contained on site in an approved manner to avoid pollutants entering into waterways or Council's stormwater drainage system.
 - xviii) Any work must not prohibit or divert any natural overland flow of water.
 - xix) Toilet facilities for employees must be provided in accordance with WorkCover NSW.
 - xx) Protection pads are to be installed to the kerb and gutter where trucks and vehicles enter the site.

(Reason: To ensure that demolition, building and any other site works are undertaken in accordance with relevant legislation and policy and in a manner which will be non-disruptive to the local area.)

19. STORMWATER MANAGEMENT PLAN - CERTIFICATION REQUIREMENT (GC)

A detailed Stormwater Management Plan (SWMP) in line with Council's Stormwater Management Code is to be prepared and certified by a practicing Chartered Professional Engineer on the National Professional Engineer's Register (NPER) at Engineers Australia and submitted to the Principal Certifying Authority and Council, prior to the issue of a Construction Certificate. The SWMP is to be based on the approved development as modified by any conditions of consent.

(Reason: To ensure appropriate provision is made for the disposal and management of stormwater generated by the development, and to ensure public infrastructure in Council's care and control is not overloaded.)

20. SYDNEY WATER - STAMPED PLANS PRIOR TO COMMENCEMENT (GC)

The approved plans must be submitted to a Sydney Water Quick Check agent or Customer Centre to determine whether the development will affect Sydney Water's sewer and water mains, stormwater drains and/or easements, and if further requirements need to be met. Plans will be appropriately stamped.

For Quick Check agent details please refer to the web site www.sydneywater.com.au (see Building Developing and Plumbing then Quick Check) or telephone 13 20 92. The consent authority or a Certifying Authority must ensure that a Quick Check agent/Sydney Water has stamped the plans before the commencement of work.

(Reason: Compliance with Sydney Water requirements.)

21. UTILITIES AND SERVICES - PROTECTION OF (GC)

Any footings or excavation to be located or undertaken adjacent to Council's stormwater must be designed to address the following requirements:

- i) all footings and excavation must be located wholly within the site and clear of any easement boundaries;
- ii) all footings and excavation must be located a minimum of 1000mm from the centreline of the pipeline or 500mm from the outside of the pipeline, whichever is the greater distance from the centreline; and
- iii) footings must extend to at least the depth of the invert of the pipeline unless the footings are to be placed on competent bedrock.

If permanent excavation is proposed beneath the obvert of the pipeline, suitable means to protect the excavation and proposed retaining structures from seepage or other water flow

from the pipeline and surrounding subsoil, must be provided. The design must be prepared by a qualified practicing Structural/Civil Engineer.

Construction plans must be approved by the appropriate utility's office (e.g. council, Sydney Water Corporation) to demonstrate that the development complies with the utility's requirements.

The applicant must provide written evidence (e.g. compliance certificate, formal advice) of compliance with the requirements of all relevant utility providers (e.g. Water, Energy, Telecommunications, Gas).

(Reason: To ensure protection of Council assets.)

22. **WASTE – TRACKABLE (GC)**

Removal of trackable waste (as defined by the NSW Environment Protection Authority) from the site must comply with the Protection of the Environment Operations (Waste) Regulation 2005 for the transportation, treatment and disposal of waste materials. Waste materials must not be disposed on land without permission of the land owner and must with the provisions of the Protection of the Environment and Operations Act 1997.

(Reason: To ensure compliance with legislation.)

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF A CONSTRUCTION CERTIFICATE (CC)

23. **ACCESS - ACCESS FOR PEOPLE WITH DISABILITIES (CC)**

Access for people with disabilities must be provided in accordance with the requirements of the Building Code of Australia, relevant Australian Standards and with regard to the Disability Discrimination Act 1992. Plans shall be notated demonstrating compliance and approved by the Principal Certifying Authority, prior to the issue of a Construction Certificate.

Note: Disability (Access to Premises - Buildings) Standards 2010 - As of 1 May 2011, if access is provided to the extent covered by this Standard, then such access cannot be viewed as unlawful under the Disability Discrimination Act 1992.

(Reason: To provide equitable access for people(s) with disabilities in accordance with the relevant legislation and Australian Standards.)

24. **BASIX COMMITMENTS (CC)**

The approved BASIX Certificate shall be submitted to the Principal Certifying Authority with the application for a Construction Certificate.

Where a change or changes are proposed in the BASIX commitments, the applicant must submit a new BASIX Certificate to the Principal Certifying Authority and Council. If any proposed change in the BASIX commitments is inconsistent with the development consent the applicant will be required to submit a modification to the development consent to Council under Section 96 of the Environmental Planning and Assessment Act 1979.

All commitments in the BASIX Certificate must be shown on the plans accompanying the Construction Certificate.

(Reason: Statutory compliance.)

25. BUILDING CODE OF AUSTRALIA - COMPLIANCE WITH (CC)

All architectural drawings, specifications and related documentation shall comply with the Building Code of Australia (BCA). All work must be carried out in accordance with the requirements of the Building Code of Australia (BCA).

In the case of residential building work for which the Home Building Act 1989 requires there to be a contract of insurance in force in accordance with Part 6 of that Act, such a contract of insurance is to be in force before any building work authorised to be carried out by the consent commences.

Details demonstrating compliance with this condition are to be submitted to the Principle Certifying Authority, prior to issue of the Construction Certificate.

(Reason: This is a 'prescribed' condition under clause 98(1) of the Environmental Planning and Assessment Regulation 2000.)

26. CAR PARKING - REQUIREMENTS FOR MULTIPLE USE BUILDINGS (CC)

The following car parking and service vehicle requirements apply:-

- i) (15) car spaces shall be provided on the development site. This shall consist of:
 - (9) resident spaces;
 - (3) visitor spaces; and
 - (3) car parking spaces for people with mobility impairment, in accordance with AS 2890.1.
- ii) All car spaces shall be allocated and marked according to this requirement.
- iii) If the development is to be strata subdivided, the car park layout must reflect the above allocation and thereafter be regarded as part of the entitlement of that strata lot.
- iv) Under no circumstances shall parking spaces be sold, let or otherwise disposed of for use other than in accordance with this condition.
- v) Each car parking space shall have minimum dimensions in accordance with the relevant Australian Standard and be provided on-site in accordance with the approved plans.
- vi) The parking bays shall be delineated by line marking.
- vii) Visitor spaces shall be clearly line marked and/or signposted and shall only be used by persons visiting residents of the property or commercial/business/retail premises located within the development. Visitor spaces shall not be allocated as permanent residential parking spaces. Access to visitor parking spaces shall not be restricted without development approval and a sign shall be erected at the vehicular entrance indicating the availability of visitor parking.

Details demonstrating compliance with this condition shall be submitted to and approved by the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: To ensure car parking provision in accordance with this consent.)

27. CAR PARKING - COMPLIANCE WITH AS/NZS 2890.1:2004 (CC)

Car parking dimensions must comply with the Australian/New Zealand Standard AS/NZS 2890.1:2004 - Parking facilities - Off-street car parking. Details demonstrating compliance are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction

Certificate.

(Reason: To ensure compliance with Australian Standards relating to parking of vehicles.)

28. COMMENCEMENT OF WORKS (NO WORKS UNTIL A CC IS OBTAINED)

Building work, demolition or excavation must not be carried out until a Construction Certificate has been issued by either Strathfield Council or a Principal Certifying Authority.

Demolition of any part of a building triggers 'commencement of erection of building' pursuant of section 81A(2) of the EP&A Act 1979. Accordingly, demolition works must not commence until a Construction Certificate has been issued, a Principal Certifying Authority has been appointed and a Notice of Commencement has been issued.

(Reason: To ensure compliance with statutory provisions.)

29. CONSTRUCTION AND ENVIRONMENTAL MANAGEMENT PLAN (CC)

The applicant must prepare and submit a Construction and Environmental Management Plan (CEMP) to the Principal Certifying Authority, including:

- i) Detailed information on any approvals required from other authorities prior to or during construction.
- ii) Traffic management, including details of:
 - ingress and egress of vehicles to the site;
 - management of loading and unloading of materials;
 - the location of heavy vehicle parking off-site; and
 - designated routes for vehicles to the site.
- iii) The proposed areas within the site to be used for a builder's site office and amenities, the storage of excavated material, construction materials and waste containers during the construction period.
- iv) Erosion and sediment control, detailing measures and procedures consistent with the requirements of Council's guidelines for managing stormwater, including:
 - the collection and treatment of stormwater and wastewater generated on site prior to discharge; and
 - procedures to prevent run-off of solid material and waste from the site.
- v) Waste management, including:
 - details of the types and estimated volumes of waste materials that will be generated;
 - procedures for maximising reuse and recycling of construction materials; and
 - details of the off-site disposal or recycling facilities for construction waste.
- vi) Dust control, outlining measures to minimise the generation and off-site transmission of dust and fine particles, such as watering or damp cloth fences.
- vii) A soil and water management plan, which includes:
 - measures to minimise the area of soils exposed at any one time and conserve top soil;
 - identification and protection of proposed stockpile locations;
 - preservation of existing vegetation and revegetation;
 - measures to prevent soil, sand, sediments leaving the site in an uncontrolled manner;
 - measures to control surface water flows through the site in a manner that diverts clean run-off around disturbed areas, minimises slope gradient and flow distance within disturbed areas, ensures surface run-off occurs at non-erodible velocities, and ensures disturbed areas are promptly rehabilitated;
 - details of sediment and erosion control measures in place before work

- commences;
- measures to ensure materials are not tracked onto the road by vehicles entering or leaving the site; and
 - details of drainage to protect and drain the site during works.
- viii) Asbestos management procedures:
- Anyone who removes, repairs or disturbs bonded or a friable asbestos material must hold a current removal licence from Workcover NSW holding either a Friable (Class A) or a Non- Friable (Class B) Asbestos Removal License which ever applies and a current WorkCover Demolition License where works involve demolition. To find a licensed asbestos removalist please see www.workcover.nsw.gov.au
 - Removal of asbestos by a person who does not hold a Class A or Class B asbestos removal license is permitted if the asbestos being removed is 10m² or less of non-friable asbestos (approximately the size of a small bathroom). Friable asbestos materials must only be removed by a person who holds a current Class A asbestos license.
 - Before starting work, a work site-specific permit approving each asbestos project must be obtained from Workcover NSW. A permit will not be granted without a current Workcover licence. All removal, repair or disturbance of or to asbestos material must comply with the following:
 - The Work Health and Safety Act 2011;
 - The Work Health and Safety Regulation 2011;
 - How to Safety Remove Asbestos Code of Practice – WorkCover 2011; and
 - Safe Work Australia Code of Practice for the Management and Control of Asbestos in the Workplace.
 - Following completion of asbestos removal works undertaken by a licensed asbestos removalist re-occupation of a workplace must not occur until an independent and suitably licensed asbestos removalist undertakes a clearance inspection and issues a clearance certificate.
 - The developer or demolition contractor must notify adjoining residents at least two (2) working days (i.e. Monday to Friday exclusive of public holidays) prior to the commencement of asbestos removal works. Notification is to include, at a minimum:
 - the date and time when asbestos removal works will commence;
 - the name, address and business hours contact telephone number of the demolisher, contractor and/or developer;
 - the full name and license number of the asbestos removalist/s; and
 - the telephone number of WorkCover's Hotline 13 10 50
 - warning signs informing all people nearby that asbestos removal work is taking place in the area. Signs should be placed at all of the main entry points to the asbestos removal work area where asbestos is present. These signs should be weatherproof, constructed of light-weight material and adequately secured so they remain in prominent locations. The signs should be in accordance with AS 1319-1994 Safety signs for the occupational environment for size, illumination, location and maintenance; and
 - appropriate barricades installed as appropriate to prevent public access and prevent the escape of asbestos fibres. Barricades must be installed prior to the commencement of asbestos removal works and remain in place until works are completed.

(Reason: Safety, amenity and protection of public infrastructure and the environment.)

30. COUNCIL PERMITS – FOR ALL ACTIVITIES ON COUNCIL LAND (CC)Works Permit

(as per Section 68 of the Local Government Act 1993 and Section 138 and 139 of the Roads Act 1993)

A Works Permit is required for construction of a vehicular crossing (driveway), new stormwater down pipe connection to kerb and gutter, new footpath and/or stormwater connection. A Works Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Standing Plant Permit

This permit must be applied for where it is intended to park a concrete pump, crane or other plant on the roadway or footpath. A Standing Plant Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Skip Bin Permit

This permit must be applied for if you intend to place a skip bin on the roadway or footpath. A Skip Bin Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Temporary Full or Part Road Closure Permit

This permit must be applied for if you require a full or a part road closure to take place to assist in your construction works. Please use the Works Permit Application Form, which is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Hoarding Permit

This permit must be applied for if you intend to erect a Class A (fence type) or Class B (overhead type) hoarding along the street frontage(s). A Hoarding Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Work Zone Permit

This permit must be applied for if you require permanent parking along the kerbside at the front of the site during construction works. A Work Zone Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Ground Anchoring Permit

This permit must be applied for, for the installation of ground anchors under Council's footway/road reserve. It does not cover ground anchors under private properties. A separate approval is required to be obtained from Roads and Maritime Services (RMS) if it is proposed to install ground anchors under a State or Classified Regional Road (please refer to the end of this application form for more information).

(Reason: Council requirement)

31. DILAPIDATION REPORT - PRE-COMMENCEMENT (CC)

Subject to access being granted, a pre-commencement Dilapidation Report is to be undertaken on all adjoining properties, which in the opinion of a suitably qualified engineer,

could be potentially affected by the construction of the project. The Dilapidation Report shall be prepared and a copy submitted to Principal Certifying Authority prior to the commencement of demolition and/or works.

The Dilapidation Report is to be prepared by a suitably Qualified Engineer with current Corporate Membership with the Institution of Engineers, Australia or Geotechnical Practitioner. The report shall include a photographic survey of adjoining properties detailing the physical condition of those properties, both internally and externally, including walls, ceilings, roof, structural members and other such items.

If access for undertaking the dilapidation survey is denied by an adjoining owner, the applicant must demonstrate, in writing, to Council's satisfaction attempts have been made to obtain access and/or advise the affected property owner of the reason for the survey and these attempts have been unsuccessful. Written concurrence must be obtained from Council in such circumstances.

The Report shall cover structural and geotechnical factors likely to arise from the development. A copy of this Report shall be submitted to Council as a record. The person having the benefit of the development consent must, at their own cost, rectify any damage caused to other properties during the construction of the project.

(Reason: To ensure no damage to adjoining properties occurs.)

32. **EROSION AND SEDIMENTATION CONTROL PLAN (CC)**

An Erosion and Sediment Control Plan is to be prepared where construction or excavation activity requires the disturbance of the soil surface and existing vegetation. Details including drawings and specifications must provide adequate measures for erosion and sediment control to ensure:

- i) Compliance with the approved Soil and Water Management Plan.
- ii) Removal or disturbance of vegetation and top soil is confined to within 3m of the approved building area (no trees to be removed without approval).
- iii) All uncontaminated run-off is diverted around cleared or disturbed areas.
- iv) Silt fences or other devices are installed to prevent sediment and other debris escaping from the cleared or disturbed areas into drainage systems or waterways.
- v) All erosion and sediment controls are fully maintained for the duration of demolition/development works.
- vi) Controls are put into place to prevent tracking of sediment by vehicles onto adjoining roadways.
- vii) All disturbed areas are rendered erosion-resistant by turfing, mulching, paving or similar.
- viii) All water pumped or otherwise removed from excavations or basement areas is filtered to achieve suspended solids/non filterable residue levels complying with the Australian Water Quality guidelines for Fresh and Marine Waters.
- ix) Pumped or overland flows of water are discharged so as not to cause, permit or allow erosion before the commencement of work (and until issue of the occupation certificate).

Details of the proposed soil erosion and sedimentation controls are to be submitted to the Principal Certifying Authority with the Construction Certificate Application. Under no circumstances are any works to commence, prior to these details being approved by the Principal Certifying Authority and the controls being in place on the site.

(Reason: Environmental protection.)

33. EXCAVATION - AFFECTING ADJOINING LAND (CC)

If an excavation associated with the approved development extends below the level of the base of the footings of a building on an adjoining allotment of land, the person having the benefit of the development consent must, at the person's own expense, comply with the requirements of clause 98E of the Environmental Planning and Assessment Regulation 2000, including:

- i) protect and support the adjoining premises from possible damage from the excavation, and
- ii) where necessary, underpin the adjoining premises to prevent any such damage.

The condition referred to in subclause (i) does not apply if the person having the benefit of the development consent owns the adjoining land or the owner of the adjoining land has given consent in writing to that condition not applying. Details shall be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Structural safety.)

34. EXCAVATION – DEWATERING (CC)

Any de-watering from the excavation or construction site must comply with the Protection of the Environment Operations Act 1997 and the following:

- i) Ground water or other water to be pumped from the site into Council's stormwater system must be sampled and analysed by a NATA accredited laboratory or Council for compliance with ANZECC Water Quality Guidelines.
- ii) If tested by NATA accredited laboratory, the certificate of analysis issued by the laboratory must be forwarded to Council as the appropriate regulatory authority under the Protection of the Environment Operations Act 1997, prior to the commencement of de-watering activities.
- iii) Council will grant approval to commence site de-watering to the stormwater based on the water quality results received.
- iv) It is the responsibility of the applicant to ensure during de-watering activities, the capacity of the stormwater system is not exceeded, there are no issues associated with erosion or scouring due to the volume of water pumped; and turbidity readings must not at any time exceed the ANZECC recommended 50ppm (parts per million) for receiving waters.

(Reason: To ensure compliance with legislation and to protect the surrounding natural environment.)

35. EXCAVATION – SHORING (CC)

Where any shoring for excavation is to be located on or is supporting Council's property, or any adjoining private property, engineering drawings and specifications certifying the shoring will be adequate for their intended purpose and must be submitted to the Council/Principal Certifying Authority for approval with the Construction Certificate. The documentation prepared and certified by an appropriately qualified and practicing structural engineer is to show all details, including the extent of encroachment and the method of removal and de-stressing of shoring elements. A copy of this documentation must be provided to the Council for record purposes at the time of Construction Certificate application.

(Reason: To ensure the protection of existing public infrastructure and adjoining properties.)

36. LANDSCAPING - MAINTENANCE STRATEGY (CC)

To ensure the survival of landscaping following works, a landscape maintenance strategy for the owner/occupier to administer over a 12 month establishment period following the issue of the Occupation Certificate shall be prepared and provided to the satisfaction of the Principal Certifying Authority with the Construction Certificate application. The strategy is to address maintenance issues such as, but not limited to plant survival, irrigation, soil testing, weeding, staking, fertilizing, remedial pruning and plant replacement.

(Reason: Ensure landscape survival.)

37. LANDSCAPING ON SLAB (CC)

To ensure the site landscaping thrives, the on slab landscaping shown on the approved landscaping plan is to be designed to include a minimum soil depth of 650mm for shrubs and trees; and 300mm for grass and ground covers. Adequate drainage provision and a permanent, automatic irrigation system conforming to Sydney Water requirements shall be included. Details demonstrating compliance shall be submitted to the Principal Certifying Authority with the Construction Certificate application.

(Reason: Ensure landscape survival.)

38. NOISE AND VIBRATION MANAGEMENT PLAN (CC)

Prior to the issue of a Construction Certificate, a Noise and Vibration Management Plan is to be prepared by a suitably qualified person addressing the likely noise and vibration from demolition, excavation and construction of the proposed development and provided to Council or the Principal Certifying Authority.

The Plan is to identify amelioration measures to ensure the noise and vibration levels will be compliance with:

- a. Construction noise management levels established using the *Interim Construction Noise Guideline (DECC, 2009)*;
- b. Vibration criteria established using the assessing vibration: *Technical guideline (DEC, 2006)* (for human exposure); and
- c. The vibration limits set out in the German Standard DIN 4150-3: *Structural Vibration-effects of vibration on structures* (for structural damage)

The report that itemises equipment to be used for excavation works. The Plan shall address, but shall not be limited to, the following matters:

- i) identification of activities carried out and associated noise sources;
- ii) identification of potentially affected sensitive receivers, including residences, churches, commercial premises, schools and properties containing noise sensitive equipment;
- iii) determination of appropriate noise and vibration objectives for each identified sensitive receiver;
- iv) noise and vibration monitoring, reporting and response procedures;
- v) assessment of potential noise and vibration from the proposed demolition, excavation and construction activities, including noise from construction vehicles;
- vi) description of specific mitigation treatments, management methods and procedures to be implemented to control noise and vibration during construction;
- vii) construction timetabling to minimise noise impacts including time and duration restrictions, respite periods and frequency;
- viii) procedures for notifying residents of construction activities likely to affect their

- ix) amenity through noise and vibration; and contingency plans to be implemented in the event of non-compliances and/or noise complaints. A register should be kept of complaints received, and the action taken to remediate the issue.

(Reason: To protect acoustic amenity of surrounding properties and the public.)

39. PRIVACY - OBSCURE GLAZING IN WET AREAS (CC)

All bathroom, ensuite and toilet windows shall be installed with obscure glazing. Plans shall be notated accordingly and details demonstrating compliance submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Privacy amenity.)

40. SECTION 94 CONTRIBUTION PAYMENT - DIRECT CONTRIBUTIONS PLAN (CC)

In accordance with the provisions of Section 94(1)(b) of the Environmental Planning and Assessment Act 1979 and the Strathfield Direct Development Contributions Plan 2010-2030, a contribution in the form of cash, cheque or credit card (financial transaction fee applies) shall be paid to Council for the following purposes:

Provision of Community Facilities	\$23,637.76
Provision of Major Open Space	\$117,203.08
Provision of Local Open Space	\$36,857.92
Provision Roads and traffic Management	\$6,321.60
Administration	\$2,038.23
TOTAL	\$186,058.59

The total amount of the contribution is valid as at the date of determination and is subject to quarterly indexation. Contributions shall be indexed at the time of payment in accordance with clause 2.14 of the Strathfield Direct Development Contributions Plan 2010-2030.

Contributions must be receipted by Council and submitted to the Accredited Certifier, prior to the issue of any Construction Certificate.

Please present a copy of this condition when paying the contribution at the Customer Service Centre so that it can be recalculated.

Note: A copy of Strathfield Council’s Section 94 Direct Development Contributions Plan may be downloaded from Council’s website.

(Reason: To enable the provision of public amenities and services required/anticipated as a consequence of increased demand resulting from the development.)

41. SECURITY PAYMENT - DAMAGE DEPOSIT FOR COUNCIL INFRASTRUCTURE (CC)

A security (damage deposit) of **\$21,000.00** (calculated in accordance with Council’s adopted Fees and Charges) shall be paid to Council, prior to the issue of a Construction Certificate.

The deposit is required as security against any damage to Council property during works on the site. The applicant must bear the cost of all restoration works to Council’s property damaged during the course of this development. All building work must be carried out in accordance with the Building Code of Australia.

Payment may be accepted in the form of cash, bank guarantee, cheque or credit card (financial transactions fees apply). Note: Additional fees apply for the lodgement of a bank guarantee in lieu of cash bond applies in accordance with Council's adopted Fees and Charges.

Any costs associated with works necessary to be carried out to rectify any damages caused by the development, shall be deducted from the Damage Deposit.

Note: Should Council property adjoining the site be defective e.g. cracked footpath, broken kerb etc., this should be reported in writing, or by photographic record, submitted to Council at least seven (7) days prior to the commencement of any work on site. This documentation will be used to resolve any dispute over damage to infrastructure. It is in the applicant's interest for it to be as full and detailed as possible.

The damage deposit shall be refunded upon completion of all works upon receipt of a Final Occupation Certificate stage and inspection by Council.

(Reason: Protection of Council infrastructure.)

42. STORMWATER DRAINAGE (CC)

The following stormwater precautions are required to be provided on the site:

- i) Grated drains shall be provided along the basement entry at the vehicular crossing(s) and are to connect to the internal drainage system.
- ii) Overflow paths shall be provided to allow for flows in excess of the capacity of the pipe/drainage system draining the site.
- iii) Allowance shall be made for surface runoff from adjacent properties, and to retain existing surface flow path systems through the site. Any redirection or treatment of these flows shall not adversely affect any other properties
- iv) Boundary fencing shall be erected in such a manner as not to interfere with the natural flow of ground and surface water to the detriment of any other party.

(Reason: To ensure the site is drained appropriately and does not interfere with the natural flow of flood waters.)

43. STORMWATER - SILT ARRESTORS AND GROSS POLLUTANT TRAPS (CC)

Silt and gross pollutant traps shall be fitted in all new stormwater pits and designed in accordance with Council's specification for the management of stormwater. Details demonstrating compliance are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Environmental protection.)

44. TRAFFIC - CONSTRUCTION TRAFFIC MANAGEMENT PLAN (CC)

A Construction Traffic Management Plan (CTMP) is to be prepared by an appropriately qualified Traffic Management Consultant and submitted to and approved by Council's Engineering Section, prior to the commencement of any works including demolition.

The following matters should be addressed in the CTMP (where applicable):

- i) description of the demolition, excavation and construction works;
- ii) site plan/s showing the site, roads, footpaths, site access points and vehicular

- movements;
- iii) size, type and estimated number of vehicular movements (including removal of excavated materials, delivery of materials and concrete to the site);
- iv) proposed route(s) from the arterial (state) road network to the site and the proposed route from the site back to the arterial road network;
- v) impacts of the work and vehicular movements on the road network, traffic and pedestrians and proposed methods to safely manage pedestrians and construction related vehicles in the frontage roadways;
- vi) any Traffic Control Plans (TCP's) proposed to regulate traffic and pedestrian movements for construction activities (such as concrete pours, crane installation/removal etc.);
- vii) proposed hours of construction related activities and vehicular movements to and from the site;
- viii) current/proposed approvals from other Agencies and Authorities (including Roads and Maritime Services, Police and State Transit Authority);
- ix) any activities proposed to be located or impact upon Council's road, footways or any public place;
- x) measures to maintain public safety and convenience;
- xi) any proposed road and/or footpath closures;
- xii) turning areas within the site for construction and spoil removal vehicles, allowing a forward egress for all construction vehicles on the site;
- xiii) locations of work zones (where it is not possible for loading/unloading to occur on the site) in the frontage roadways accompanied by supporting documentation that such work zones have been approved by the Local Traffic Committee and Council;
- xiv) location of any proposed crane and concrete pump and truck standing areas on and off the site (and relevant approvals from Council for plant on road);
- xv) a dedicated unloading and loading point within the site for all construction vehicles, plant and deliveries;
- xvi) material, plant and spoil bin storage areas within the site, where all materials are to be dropped off and collected;
- xvii) on-site parking area for employees, tradespersons and construction vehicles as far as possible;
- xviii) proposed areas within the site to be used for the storage of excavated material, construction materials and waste and recycling containers during the construction period; and
- xix) how it is proposed to ensure that soil/excavated material is not transported onto surrounding footpaths and roadways.

(Reason: To mitigate traffic impacts on the surrounding area during the construction period.)

45. **TREE BONDS (CC)**

A tree bond of **\$13,200.00** (calculated in accordance with Council's adopted Fees and Charges) shall be paid to Council, prior to the issue of a Construction Certificate.

The deposit is required as security against any damage to existing trees to be retained on Council's road reserve, during works on the site. The applicant must bear the cost of all restoration works to Council's property damaged during the course of this development.

Payment may be accepted in the form of cash, bank guarantee, cheque or credit card (financial transactions fees apply). Note: Additional fees apply for the lodgement of a bank guarantee in lieu of cash bond applies in accordance with Council's adopted Fees and Charges.

(Reason: To ensure the protection of trees to be retained on Council's Road Reserve.)

46. VEHICULAR CROSSINGS - WORKS PERMIT FOR CONSTRUCTION OF (CC)

Full-width, heavy-duty concrete vehicular crossing(s) shall be provided across the footpath at the entrance(s) and/or exit(s) to the site and designed in accordance with Council's guidelines and specifications. In this regard, a Works Permit is to be obtained (available from Council's Customer Services Centre or downloaded from Council's website), and the appropriate fees and charges paid, prior to the lodgement of a Construction Certificate.

(Reason: To ensure appropriate access to the site can be achieved.)

47. WASTE MANAGEMENT PLAN (CC)

A Waste Management Plan (WMP) is to be provided in accordance with Part H of Strathfield Consolidated Development Control Plan 2005. All requirements of the approved Waste Management Plan must be implemented during demolition, construction and on-going use of the premises.

The WMP must identify the types of waste that will be generated and all proposals to re-use, recycle or dispose of the waste. The WMP is to be submitted to the Principal Certifying Authority, prior to issue of the Construction Certificate.

(Reason: To ensure appropriate management of waste.)

48. WATER SUSTAINABILITY – GENERALLY (CC)

Water collected in the rainwater tank must comprise roof water only and not surface water. Water from the rainwater tank must only be used for following purposes and not for human consumption:

- i) toilet flushing;
- ii) clothes washing;
- iii) garden irrigation;
- iv) car washing and similar outdoor uses;
- v) filling swimming pools, spa pools and ornamental ponds; and
- vi) fire fighting.

(Reason: To promote sustainable water management practice.)

49. WORKS WITHIN THE ROAD RESERVE (CC)

Detailed drawings including long and short sections and specifications of all works within existing roads (including but not limited to structures, road works, driveway crossings, footpaths and stormwater drainage) shall be submitted to and approved by Council under Section 138 of the Roads Act 1993 and all fees and charges paid, prior to the issue of a Construction Certificate.

Detailed drawings and specifications are to be prepared and certified by an appropriately qualified Civil Engineer.

Upon completion of the works, the Applicant is to provide to Council with electronic copies of 'Work as Executed Plans'. The plans are to show relevant dimensions and finished levels and are to be certified by a surveyor.

The Applicant is to provide to Council, in an approved format, details of all public infrastructure created as part of the works.

All civil engineering works adjacent/near/outside 15 Homebush Road are to be fully supervised by Council. A maintenance period of six (6) months shall apply to the work, after it has been completed and approved. In that period the Applicant shall be liable for any part of the work which fails to perform in the manner outlined in Council's specifications, or as would reasonably be expected under the design conditions.

(Reason: To ensure compliance of engineering works/Council assets are constructed to acceptable standards for engineering works.)

CONDITIONS TO BE SATISFIED PRIOR TO THE COMMENCEMENT OF WORKS (CW)

50. APPOINTMENT OF A PRINCIPAL CERTIFYING AUTHORITY (PCA) (CW)

No work shall commence in connection with this Development Consent until:

- i) A construction certificate for the building work has been issued by the consent authority or a Principal Certifying Authority.
- ii) The person having the benefit of the development consent has appointed a principal certifying authority for the building work, and notified the principal certifying authority that the person will carry out the building work as an owner/builder, if that is the case.
- iii) The principal certifying authority has, no later than 2 days before the building work commences:
 - notified the Council of his or her appointment, and
 - notified the person having the benefit of the development consent of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- iv) The person having the benefit of the development consent, if not carrying out the work as an owner-builder, has:
 - appointed a principal contractor for the building work who must be the holder of a contractor licence if any residential building work is involved;
 - notified the principal certifying authority of such appointment; and
 - unless that person is the principal contractor, notified the principal contractor of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- v) The person having the benefit of the development consent has given at least 2 days notice to the Council of the person's intention to commence the erection of the building.

Note: If the principal certifying authority is the Council, the nomination will be subject to the payment of a fee for the service to cover the cost of undertaking all necessary inspections and the issue of the appropriate certificates.

Under the Environment Planning and Assessment (Quality of Construction) Act, 2003, a sign must be erected in a prominent position on the work site showing the name, address and telephone number of the principal certifying authority; the name of the principal contractor (if any) for the building work and a telephone number at which that person may be contacted outside working hours. That sign must also state that unauthorised entry is prohibited. The sign must not be removed until all work has been completed.

(Reason: Statutory requirement.)

51. NOTICE OF COMMENCEMENT (CW)

No work shall commence until the following details are submitted to Council:

- i) a Notice of Commencement (form will be attached with issue of a Construction Certificate or available from our website) within two (2) days of the date on which it is proposed to commence works associated with the Development Consent;
- ii) details of the appointment of a Principal Certifying Authority (either Council or another Principal Certifying Authority); and
- iii) details of the name, address and licence details of the Builder.

(Reason: Statutory requirement.)

CONDITIONS TO BE SATISFIED DURING DEMOLITION AND BUILDING WORKS (DW)

52. CONTAMINATED LAND UNEXPECTED FINDS (DW)

In the instance works cause the generation of odours or uncovering of unexpected contaminants works are to immediately cease, Council is to be notified and a suitably qualified environmental scientist appointed to further assess the site.

The contaminated land situation is to be evaluated by the supervising environmental consultant and an appropriate response determined in consultation with the applicant, which is agreed to by Strathfield Council's Environmental Services Manager.

Note: Council may also request that a NSW EPA accredited site auditor is involved to assist with the assessment of the contaminated land situation and review any new contamination information. The applicant must also adhere to any additional conditions which may be imposed by the accredited site auditor.

(Reason: To ensure compliance with statutory requirements.)

53. FILL MATERIAL (DW)

The only waste derived material which may be received at the development site is:

- i) Virgin excavated material (within the meaning of the Protection of the Environment Operations Act 1997), and
- ii) any other waste-derived material the subject of a resource recovery exemption under cl.51A of the Protection of the Environment Operations (Waste) Regulation 2005 that is permitted to be used as fill material.

Any (b)-type material received at the development site must be accompanied by documentation certifying by an appropriately qualified environmental consultant the materials compliance with the exemption conditions; and this documentation must be provided to the Principal Certifying Authority on request.

(Reason: To ensure imported fill is of an acceptable standard for environmental protection purposes.)

54. OBSTRUCTION OF PUBLIC WAY NOT PERMITTED DURING WORKS (DW)

The public way must not be obstructed by any materials, vehicles, refuse, skips or the like, under any circumstances, without the prior approval of Council.

(Reason: To maintain public access and safety.)

55. PUBLIC INFRASTRUCTURE AND SERVICES (DW)

The applicant must comply with the requirements (including financial costs) of any relevant utility provider (e.g. Energy Australia, Sydney Water, Telstra, RMS, Council etc.) in relation to any connections, works, repairs, relocation, replacements and/or adjustments to public infrastructure or services affected by the development.

(Reason: To maintain public infrastructure and/or services.)

56. **SITE REQUIREMENTS DURING DEMOLITION AND CONSTRUCTION**

All of the following are to be satisfied/complied with during demolition, construction and any other site works:

- i) All demolition is to be carried out in accordance with Australian Standards AS 2601-2001.
- ii) Demolition must be carried out by a registered demolition contractor.
- iii) A single entrance is permitted to service the site for demolition and construction. The footway and nature strip at the service entrance must be planked out with close boarded, hardwood timber footpath protection pads. The pad shall cover the entire width of the footpath opening for the full width of the fence.
- iv) No blasting is to be carried out at any time during construction of the building.
- v) Care must be taken during demolition/ excavation/ building/ construction to prevent any damage to adjoining buildings.
- vi) Adjoining owner property rights and the need for owner's permission must be observed at all times, including the entering onto land for the purpose of undertaking works.
- vii) Any demolition and excess construction materials are to be recycled wherever practicable.
- viii) The disposal of construction and demolition waste must be in accordance with the requirements of the Protection of the Environment Operations Act 1997.
- ix) All waste on the site is to be stored, handled and disposed of in such a manner as to not create air pollution (including odour), offensive noise or pollution of land and/or water as defined by the Protection of the Environment Operations Act 1997.
- x) All excavated material should be removed from the site in the approved manner and be disposed of lawfully to a tip or other authorised disposal area.
- xi) Section 143 of the Protection of the Environment Operations Act 1997 requires waste to be transported to a place which can lawfully accept it. All non-recyclable demolition materials are to be disposed of at an approved waste disposal depot in accordance with legislation.
- xii) All materials on site or being delivered to the site are to generally be contained within the site. The requirements of the Protection of the Environment Operations Act 1997 must be complied with when placing/stockpiling loose material, disposing of concrete waste, or other activities likely to pollute drains or water courses.
- xiii) Details as to the method and location of disposal of demolition materials (weight dockets, receipts etc.) should be kept on site as evidence of approved methods of disposal and recycling.
- xiv) Any materials stored on site must be stored out of view or in such a manner so as not to cause unsightliness when viewed from nearby lands or roadways.
- xv) Public footways and roadways adjacent to the site must be fully maintained and cleared of obstructions during construction unless prior separate approval from Council is obtained including payment of relevant fees.
- xvi) Building operations such as brick cutting, washing tools or paint brushes, and mixing mortar not be performed on the roadway or public footway or any other locations which could lead to the discharge of materials into the stormwater drainage system.
- xvii) All site waters during excavation and construction must be contained on site in an approved manner to avoid pollutants entering into waterways or Council's stormwater drainage system.

- xviii) Stamped plans, specifications, documentation and the consent shall be available on site at all times during construction.

(Reason: To ensure that demolition, building and any other site works are undertaken in accordance with relevant legislation and policy and in a manner which will be non-disruptive to the local area.)

57. SURVEY REPORT OF APPROVED LEVELS DURING AND POST CONSTRUCTION (DW)

A Survey Certificate to Australian Height Datum shall be prepared by a Registered Surveyor as follows:

- i) At the completion of the first structural floor level prior to the pouring of concrete indicating the level of that floor and the relationship of the building to the boundaries.
- ii) At the completed height of the building, prior to the placement of concrete inform work, or the laying of roofing materials.
- iii) At the completion of the development.

Progress certificates in response to points (1) through to (3) shall be provided to the Principal Certifying Authority at the time of carrying out relevant progress inspections. Under no circumstances is work allowed to proceed until such survey information is submitted to and approved by the Principal Certifying Authority.

(Reason: To ensure compliance with the approved plans.)

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF AN OCCUPATION CERTIFICATE (OC)

58. CAR PARKING - VISITOR CAR PARKING SIGNAGE (OC)

A sign shall be erected in a suitable location on the property near the driveway entrance indicating where visitor parking is available on the site. Signage shall also be erected above the visitor parking itself. Details demonstrating compliance shall be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: Adequate access and egress.)

59. ENGINEERING WORKS (CERTIFICATION OF)

Prior to occupation of the premises, a Work As Executed (WAE) Plan of all engineering and/or drainage works is to be submitted to the Principal Certifying Authority. The WAE Plan is to be certified by a suitably Qualified Engineer, with Corporate Membership standing in the Institution of Engineers Australia and registered on the National Professional Engineers Register (NPER) under the appropriate professional category, demonstrating that:

- i) the stormwater drainage system; and/or
- ii) the car parking arrangement and area; and/or
- iii) any related footpath crossing works; and/or
- iv) the proposed basement pump and well system; and/or
- v) the proposed driveway and layback; and/or
- vi) any other civil works

have been constructed in accordance with the approved plans and any relevant Standards and Council policies/specifications.

For major works, such as subdivisions, works within the road reserve (requiring separate S138 approval) and as where specified by Council, a Part 4A Certificate will be required. It is strongly recommended that an Engineer supervise all engineering related works.

Where Council is not the Principal Certifying Authority, an electronic copy of the above documents is to be provided to Council, prior to the issue of any Occupation Certificate.

(Reason: Asset management.)

60. FIRE SAFETY CERTIFICATION (OC)

A fire safety certificate shall be obtained in accordance with Part 9, Division 4 of the Environmental Planning and Assessment Regulation 2000, prior to the issue of any Occupation Certificate.

An fire safety certificate is a certificate issued by the owner of a building to the effect that each essential fire safety measure specified in the current fire safety schedule for the part of the building to which the certificate relates:

- i) has been assessed by a properly qualified person; and
- ii) was found, when it was assessed, to be capable of performing to at least the standard required by the current fire safety schedule for the building for which the certificate is issued.

An interim fire safety certificate must be provided before an interim occupation certificate can be used for a building under Clause 153(2) of the Environmental Planning & Assessment Regulation 2000.

A final fire safety certificate must be provided before an interim occupation certificate can be used for a building under Clause 153(1) of the Environmental Planning & Assessment Regulation 2000.

A copy of the fire safety certificate and fire safety schedule shall be:

- i) submitted to Strathfield Council;
- ii) submitted to the Commissioner of the New South Wales Fire Brigade; and
- iii) prominently displayed in the building.

(Reason: Fire safety and statutory requirement.)

61. LANDSCAPING - ARBORIST'S FOLLOW UP REPORT OF TREE/S TO BE RETAINED (OC)

As part of the on-going assessment of the tree/s to be retained, the consulting arborist engaged by the applicant is to assess their health and any impacts suffered by them as a result of the proposed approved development, prior to the issue of an Occupation Certificate. Findings are to be compiled in a detailed report and submitted to the Principle Certifying Authority, which documents the following:

- i) methods of excavation or construction used to carry out the works;
- ii) any damage sustained by the tree/s as a result of the works;
- iii) any subsequent remedial works required to be carried out by the consulting arborist as a result of the damage; and
- iv) any future or on-going remedial work required to be carried out to ensure the long term retention of the tree/s.

(Reason: To ensure the survival of trees to be retained.)

62. OCCUPATION OF BUILDING (OC)

A person must not commence occupation or use (or change of use where an existing building) of the whole or any part of a new building (within the meaning of section 109H (4) of the Act) unless an Interim Occupation Certificate or Final Occupation Certificate has been issued in relation to the building or part.

The Principal Certifying Authority is required to be satisfied, amongst other things, that:

- i) all required inspections (including each applicable mandatory critical stage inspection) have been carried out; and
- ii) any preconditions to the issue of the certificate required by a development consent have been met.

Note: New building includes an altered portion of, or an extension to, an existing building.

(Reason: Statutory requirement.)

63. STORMWATER - CERTIFICATION OF THE CONSTRUCTED DRAINAGE SYSTEM (OC)

The constructed stormwater system shall be certified by a suitably qualified person, in accordance with Council's Stormwater Management Code, prior to the issue of any Occupation Certificate.

(Reason: Adequate stormwater management.)

64. STORMWATER - COVENANT AND RESTRICTION AS TO USER FOR STORMWATER CONTROLLED SYSTEMS (OC)

Prior to the issue of any Occupation Certificate, the applicant shall register a Positive Covenant and a Restriction as to User under section 88E and or section 88B of the Conveyancing Act as appropriate in favour of Council, ensuring the ongoing retention, maintenance and operation of the stormwater facility (on-site detention, pump-out, charged lines, etc.).

Where any drainage line or service conduit is to traverse any property other than that which it serves, an appropriate easement will be required. In this case, the applicant shall register an easement no less than 1200mm wide over the proposed drainage line or service concurrently with any subdivision registration.

The wording on the 88B Instrument is to make reference to the Council file where the Construction plans and the Work As Executed (as built), plans are held. Typical wording can be obtained from Council's Specification for the Management of Stormwater document.

(Reason: To ensure the on-site detention and/or pump system is maintained to an appropriate operational standard.)

65. VENTILATION SYSTEMS – NATURAL (OC)

The natural ventilation system shall be designed, constructed and installed in accordance with the provisions of:

- i) The Building Code of Australia; and
- ii) Protection of the Environment Operations Act 1997.

Details demonstrating compliance with this condition shall be submitted to the Principal Certifying Authority, prior to issue of the Occupation Certificate.

(Reason: To ensure any natural ventilation systems comply with the relevant regulations/standards.)

CONDITIONS TO BE SATISFIED DURING ONGOING USE OF THE PREMISES (OU)

66. FIRE SAFETY ANNUAL STATEMENT (OU)

Pursuant to Part 9, Division 5 of the Environmental Planning and Assessment Regulation (as amended) the owner of the building shall provide to Council an Annual Fire Safety Statement from an appropriately qualified person certifying the essential fire safety measures in the building. The Annual Fire Safety Statement shall be submitted within 12 months of the issue of the fire safety certificate, and then on an annual basis.

A copy of the Fire Safety Statement obtained and Fire Safety Schedule shall also be:

- i) Forwarded to the Commissioner of the New South Wales Fire Brigade; and
- ii) Prominently displayed in the building.

(Reason: Fire safety)

RESOLUTION

That we find the clause 4.6 variation to be well founded and **approve** the application subject to the conditions of the consent as amended by the panel.

For the Decision: Stein, Atkins, Evernden, Smith

Against the Decision: Nil

**** End Minutes - Report No. 2****

TO: Strathfield Independent Hearing and Assessment Panel Meeting - 3 August 2017

REPORT: SIHAP – Report No. 3

SUBJECT: 88-92A PARRAMATTA ROAD, HOMEBUSH
LOT A DP 419617, LOT 1,2 AND 3 OF DP 201120

DA NO. DA2017/066

RECOMMENDATION

That Development Application No. DA2017/066 for the demolition of existing structures at 88 – 92A Parramatta Road, Homebush be **APPROVED**, subject to the following conditions:

GENERAL CONDITIONS (GC)

1. APPROVED PLANS AND REFERENCE DOCUMENTATION (GC)

The development, except where modified by a condition(s) of consent, is to be carried out in accordance with the following plans and reference documentation:

Plans affixed with Council's 'Development Consent' stamp relating to Development Consent No. DA2017/066:

Drawing No.	Title/Description	Prepared by	Issue / Revision & Date	Date received by Council
01/01	Demolition Plan	Linx Construction Pty Ltd	May 2017	16 May 2017

Reference Documentation affixed with Council's 'Development Consent' stamp relating to Development Consent No. DA2017/066:

Title / Description	Prepared by	Issue/Revision & Date	Date received by Council
Traffic Management	Linx Construction Pty Ltd	12/05/2017	16 May 2017
Demolition and Construction Management Plan	Linx Construction Pty Ltd	12/05/2017	16 May 2017
Waste Management Plan	Linx Construction Pty Ltd	12/05/2017	16 May 2017
Soil and Water Management	Linx Construction Pty Ltd	12/05/2017	16 May 2017

In the event of any inconsistency between the approved plans and supplementary documentation, the plans will prevail. However, the conditions of this consent shall prevail to the extent of any inconsistency.

(Reason: To ensure that the form of the development undertaken is in accordance with the determination of Council.)

2. CONSTRUCTION HOURS (GC)

No construction, demolition or any other work related activities shall be carried out on the site outside the hours of 7.00 am to 5.00 pm Mondays to Fridays and 8am to 1pm Saturdays.

No construction, demolition or any other work related activities are to be carried out at any time on a Sunday or public holiday.

Where the development involves the use of jackhammers/ rock breakers and the like or other heavy machinery, such equipment may only be used between the hours of 7.00 am - 5.00 pm Monday to Friday only.

(Reason: To maintain amenity to adjoining land owners.)

3. DEMOLITION – GENERALLY (GC)

Alteration and demolition of the existing building is limited to that documented on the approved plans (by way of notation). No approval is given or implied for removal and/or rebuilding of any portion of the existing building which is not shown to be altered or demolished.

(Reason: To ensure compliance with the approved development.)

4. DEMOLITION (GC)

Alterations to, and demolition of, the existing building shall be limited to that documented on the approved plans (by way of notation) or conditioned in this consent. No approval is given or implied for removal and/or rebuilding of any portion of the existing building which is shown to be retained.

Should any portion of the existing building which is indicated on the approved plans to be retained, be damaged for whatever reason, all the works in the area of this damaged portion are to cease and written notification given to Council. No work is to resume until the written approval of Council is obtained.

(Reason: Heritage conservation.)

5. DEMOLITION - SITE SAFETY FENCING (GC)

Site fencing is to be erected to a minimum height of 1.8m complying with WorkCover Guidelines, to exclude public access to the site, prior to any demolition works occurring and maintained for the duration of the demolition works.

If applicable, a separate Hoarding Application for the erection of an A class (fence type) or B class (overhead type) hoarding along the street frontage(s) complying with WorkCover requirements must be obtained including:

payment to Council of a footpath occupancy fee based on the area of footpath to be occupied and Council's Schedule of Fees and Charges before the commencement of work; and

provision of a Public Risk Insurance Policy with a minimum cover of \$10 million in relation to the occupation of and works within Council's road reserve, for the full duration of the proposed works, must be obtained with a copy provided to Council.

(Reasons: Statutory requirement and health and safety.)

5a. SITE SAFETY FENCING ALONG PARRAMATTA ROAD

Following the demolition of numbers 88-92A Parramatta Road fencing to a height of 2m as measured from the existing Parramatta road footpath level shall be constructed and maintained across the entire width of the properties. Fencing shall be constructed of structural plywood, painted non reflective black in colour, and treated with anti-graffiti finish. Any unauthorized affixed posters and/or graffiti shall be removed immediately.

(Reason: Site safety and improved pedestrian amenity)

6. LIGHTING (GC)

Any lighting of the premises shall be installed and maintained in accordance with Australian Standard AS 4282-1997: Control of the Obtrusive Effects of Outdoor Lighting so as to avoid annoyance to the occupants of adjoining premises or glare to motorists on nearby roads.

No flashing, moving or intermittent lighting, visible from any public place may be installed on the premises or external signage associated with the development, without the prior approval of Council.

(Reason: To protect the amenity of surrounding development and protect public safety.)

7. SITE MANAGEMENT (DURING DEMOLITION AND CONSTRUCTION WORKS)

All of the following are to be satisfied/complied with during demolition, construction and any other site works:

- i) All demolition is to be carried out in accordance with Australian Standard AS 2601-2001.
- ii) Demolition must be carried out by a registered demolition contractor.
- iii) A single entrance is permitted to service the site for demolition and construction. The footway and nature strip at the service entrance must be planked out.
- iv) No blasting is to be carried out at any time during construction of the building.
- v) Care must be taken during demolition/ excavation/ building/ construction to prevent any damage to adjoining buildings.
- vi) Adjoining owner property rights and the need for owner's permission must be observed at all times, including the entering onto land for the purpose of undertaking works.
- vii) Any demolition and excess construction materials are to be recycled wherever practicable.
- viii) The disposal of construction and demolition waste must be in accordance with the requirements of the Protection of the Environment Operations Act 1997.
- ix) All waste on the site is to be stored, handled and disposed of in such a manner as to not create air pollution (including odour), offensive noise or pollution of land and/or water as defined by the Protection of the Environment Operations Act 1997. All excavated material should be removed from the site in an approved manner and be disposed of lawfully to a tip or other authorised disposal area.
- x) All waste must be contained entirely within the site.
- xi) Section 143 of the Protection of the Environment Operations Act 1997 requires waste to be transported to a place which can lawfully accept it. All non-recyclable demolition materials are to be disposed of at an approved waste disposal depot in accordance with legislation.
- xii) All materials on site or being delivered to the site are to generally be contained within the site. The requirements of the Protection of the Environment Operations Act 1997 must be complied with when placing/stockpiling loose material, disposing of concrete waste, or other activities likely to pollute drains or water courses.
- xiii) Details as to the method and location of disposal of demolition materials (weight dockets, receipts, etc.) should be kept on site as evidence of approved methods of disposal or recycling.
- xiv) Any materials stored on site must be stored out of view or in such a manner so as not to cause unsightliness when viewed from nearby lands or roadways.
- xv) Public footways and roadways adjacent to the site must be maintained and cleared of obstructions during construction. No building materials, waste containers or skips may be stored on the road reserve or footpath without prior separate approval from

- Council, including payment of relevant fees.
- xvi) Building operations such as brick-cutting, washing tools or paint brushes, and mixing mortar not be performed on the roadway or public footway or any other locations which could lead to the discharge of materials into the stormwater drainage system.
 - xvii) All site waters during excavation and construction must be contained on site in an approved manner to avoid pollutants entering into waterways or Council's stormwater drainage system.
 - xviii) Any work must not prohibit or divert any natural overland flow of water.
 - xix) Toilet facilities for employees must be provided in accordance with WorkCover NSW.
 - xx) Protection pads are to be installed to the kerb and gutter where trucks and vehicles enter the site.

(Reason: To ensure that demolition, building and any other site works are undertaken in accordance with relevant legislation and policy and in a manner which will be non-disruptive to the local area.)

8. **STORMWATER MANAGEMENT PLAN - CERTIFICATION REQUIREMENT (GC)**

A detailed Stormwater Management Plan (SWMP) in line with Council's Stormwater Management Code is to be prepared and certified by a practicing Chartered Professional Engineer on the National Professional Engineer's Register (NPER) at Engineers Australia and submitted to the Principal Certifying Authority and Council, prior to the issue of a Construction Certificate. The SWMP is to be based on the approved development as modified by any conditions of consent.

(Reason: To ensure appropriate provision is made for the disposal and management of stormwater generated by the development, and to ensure public infrastructure in Council's care and control is not overloaded.)

9. **SYDNEY WATER - STAMPED PLANS PRIOR TO COMMENCEMENT (GC)**

The approved plans must be submitted to a Sydney Water Quick Check agent or Customer Centre to determine whether the development will affect Sydney Water's sewer and water mains, stormwater drains and/or easements, and if further requirements need to be met. Plans will be appropriately stamped.

For Quick Check agent details please refer to the web site www.sydneywater.com.au (see Building Developing and Plumbing then Quick Check) or telephone 13 20 92. The consent authority or a Certifying Authority must ensure that a Quick Check agent/Sydney Water has stamped the plans before the commencement of work.

(Reason: Compliance with Sydney Water requirements.)

10. **UTILITIES AND SERVICES - PROTECTION OF (GC)**

Any footings or excavation to be located or undertaken adjacent to Council's stormwater must be designed to address the following requirements:

- i) all footings and excavation must be located wholly within the site and clear of any easement boundaries;
- ii) all footings and excavation must be located a minimum of 1000mm from the centreline of the pipeline or 500mm from the outside of the pipeline, whichever is the greater distance from the centreline; and
- iii) footings must extend to at least the depth of the invert of the pipeline unless the footings are to be placed on competent bedrock.

If permanent excavation is proposed beneath the obvert of the pipeline, suitable means to protect the excavation and proposed retaining structures from seepage or other water flow from the pipeline and surrounding subsoil, must be provided. The design must be prepared by a qualified practicing Structural/Civil Engineer.

Construction plans must be approved by the appropriate utility's office (e.g. council, Sydney Water Corporation) to demonstrate that the development complies with the utility's requirements.

The applicant must provide written evidence (e.g. compliance certificate, formal advice) of compliance with the requirements of all relevant utility providers (e.g. Water, Energy, Telecommunications, Gas).

(Reason: To ensure protection of Council assets.)

11. WASTE – TRACKABLE (GC)

Removal of trackable waste (as defined by the NSW Environment Protection Authority) from the site must comply with the Protection of the Environment Operations (Waste) Regulation 2005 for the transportation, treatment and disposal of waste materials. Waste materials must not be disposed on land without permission of the land owner and must with the provisions of the Protection of the Environment and Operations Act 1997.

(Reason: To ensure compliance with legislation.)

CONDITIONS TO BE SATISFIED PRIOR TO COMMENCEMENT OF WORKS

12. CONSTRUCTION AND ENVIRONMENTAL MANAGEMENT PLAN (CW)

The applicant must prepare and submit a Construction and Environmental Management Plan (CEMP) to Council, including:

- i) Detailed information on any approvals required from other authorities prior to or during construction.
- ii) Traffic management, including details of:
 - ingress and egress of vehicles to the site;
 - management of loading and unloading of materials;
 - the location of heavy vehicle parking off-site; and
 - designated routes for vehicles to the site.
- iii) The proposed areas within the site to be used for a builder's site office and amenities, the storage of excavated material, construction materials and waste containers during the construction period.
- iv) Erosion and sediment control, detailing measures and procedures consistent with the requirements of Council's guidelines for managing stormwater, including:
 - the collection and treatment of stormwater and wastewater generated on site prior to discharge; and
 - procedures to prevent run-off of solid material and waste from the site.
- v) Waste management, including:
 - details of the types and estimated volumes of waste materials that will be generated;
 - procedures for maximising reuse and recycling of construction materials; and
 - details of the off-site disposal or recycling facilities for construction waste.
- vi) Dust control, outlining measures to minimise the generation and off-site transmission of dust and fine particles, such as watering or damp cloth fences.

- vii) A soil and water management plan, which includes:
- measures to minimise the area of soils exposed at any one time and conserve top soil;
 - identification and protection of proposed stockpile locations;
 - preservation of existing vegetation and revegetation;
 - measures to prevent soil, sand, sediments leaving the site in an uncontrolled manner;
 - measures to control surface water flows through the site in a manner that diverts clean run-off around disturbed areas, minimises slope gradient and flow distance within disturbed areas, ensures surface run-off occurs at non-erodible velocities, and ensures disturbed areas are promptly rehabilitated;
 - details of sediment and erosion control measures in place before work commences;
 - measures to ensure materials are not tracked onto the road by vehicles entering or leaving the site; and
 - details of drainage to protect and drain the site during works.
- viii) Asbestos management procedures:
- Anyone who removes, repairs or disturbs bonded or a friable asbestos material must hold a current removal licence from Workcover NSW holding either a Friable (Class A) or a Non- Friable (Class B) Asbestos Removal License which ever applies and a current WorkCover Demolition License where works involve demolition. To find a licensed asbestos removalist please see www.workcover.nsw.gov.au
 - Removal of asbestos by a person who does not hold a Class A or Class B asbestos removal license is permitted if the asbestos being removed is 10m² or less of non-friable asbestos (approximately the size of a small bathroom). Friable asbestos materials must only be removed by a person who holds a current Class A asbestos license.
 - Before starting work, a work site-specific permit approving each asbestos project must be obtained from Workcover NSW. A permit will not be granted without a current Workcover licence. All removal, repair or disturbance of or to asbestos material must comply with the following:
 - The Work Health and Safety Act 2011;
 - The Work Health and Safety Regulation 2011;
 - How to Safety Remove Asbestos Code of Practice – WorkCover 2011; and
 - Safe Work Australia Code of Practice for the Management and Control of Asbestos in the Workplace.
 - Following completion of asbestos removal works undertaken by a licensed asbestos removalist re-occupation of a workplace must not occur until an independent and suitably licensed asbestos removalist undertakes a clearance inspection and issues a clearance certificate.
 - The developer or demolition contractor must notify adjoining residents at least two (2) working days (i.e. Monday to Friday exclusive of public holidays) prior to the commencement of asbestos removal works. Notification is to include, at a minimum:
 - the date and time when asbestos removal works will commence;
 - the name, address and business hours contact telephone number of the demolisher, contractor and/or developer;
 - the full name and license number of the asbestos removalist/s; and
 - the telephone number of WorkCover's Hotline 13 10 50
 - warning signs informing all people nearby that asbestos removal work is taking place in the area. Signs should be placed at all of the main entry points to the asbestos removal work area where asbestos is present. These signs should be weatherproof, constructed of light-weight material and adequately secured so they remain in prominent locations. The signs

- should be in accordance with AS 1319-1994 Safety signs for the occupational environment for size, illumination, location and maintenance; and
- appropriate barricades installed as appropriate to prevent public access and prevent the escape of asbestos fibres. Barricades must be installed prior to the commencement of asbestos removal works and remain in place until works are completed.

(Reason: Safety, amenity and protection of public infrastructure and the environment.)

13. **COUNCIL PERMITS – FOR ALL ACTIVITIES ON COUNCIL LAND (CW)**

Works Permit

(as per Section 68 of the Local Government Act 1993 and Section 138 and 139 of the Roads Act 1993)

A Works Permit is required for construction of a vehicular crossing (driveway), new stormwater down pipe connection to kerb and gutter, new footpath and/or stormwater connection. A Works Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Standing Plant Permit

This permit must be applied for where it is intended to park a concrete pump, crane or other plant on the roadway or footpath. A Standing Plant Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Skip Bin Permit

This permit must be applied for if you intend to place a skip bin on the roadway or footpath. A Skip Bin Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Temporary Full or Part Road Closure Permit

This permit must be applied for if you require a full or a part road closure to take place to assist in your construction works. Please use the Works Permit Application Form, which is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Hoarding Permit

This permit must be applied for if you intend to erect a Class A (fence type) or Class B (overhead type) hoarding along the street frontage(s). A Hoarding Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Work Zone Permit

This permit must be applied for if you require permanent parking along the kerbside at the front of the site during construction works. A Work Zone Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Ground Anchoring Permit

This permit must be applied for, for the installation of ground anchors under Council's footway/road reserve. It does not cover ground anchors under private properties. A separate approval is required to be obtained from Roads and Maritime Services (RMS) if it is proposed to install ground anchors under a State or Classified Regional Road (please refer to the end of this application form for more information).

(Reason: Council requirement)

14. NOISE AND VIBRATION MANAGEMENT PLAN (CW)

Prior to commencement of works, a Noise and Vibration Management Plan is to be prepared by a suitably qualified person addressing the likely noise and vibration from demolition, excavation and construction of the proposed development and provided to Council.

The Plan is to identify amelioration measures to ensure the noise and vibration levels will be compliance with:

- a. Construction noise management levels established using the *Interim Construction Noise Guideline (DECC, 2009)*;
- b. Vibration criteria established using the assessing vibration: *Technical guideline (DEC, 2006)* (for human exposure); and
- c. The vibration limits set out in the German Standard DIN 4150-3: *Structural Vibration-effects of vibration on structures* (for structural damage)

The report that itemises equipment to be used for excavation works. The Plan shall address, but shall not be limited to, the following matters:

- i) identification of activities carried out and associated noise sources;
- ii) identification of potentially affected sensitive receivers, including residences, churches, commercial premises, schools and properties containing noise sensitive equipment;
- iii) determination of appropriate noise and vibration objectives for each identified sensitive receiver;
- iv) noise and vibration monitoring, reporting and response procedures;
- v) assessment of potential noise and vibration from the proposed demolition, excavation and construction activities, including noise from construction vehicles;
- vi) description of specific mitigation treatments, management methods and procedures to be implemented to control noise and vibration during construction;
- vii) construction timetabling to minimise noise impacts including time and duration restrictions, respite periods and frequency;
- viii) procedures for notifying residents of construction activities likely to affect their amenity through noise and vibration; and
- ix) contingency plans to be implemented in the event of non-compliances and/or noise complaints. A register should be kept of complaints received, and the action taken to remediate the issue.

(Reason: To protect acoustic amenity of surrounding properties and the public.)

15. REMEDIAL WORKS - PRE-COMMENCEMENT ENVIRONMENTAL MANAGEMENT PLAN (CW)

An Environmental Management Plan (EMP) shall be prepared for the proposed remedial works in accordance with the requirements of the approved Remedial Action Plan.

The EMP must be prepared by an appropriately qualified and experienced environmental consultant.

The EMP for Remediation must include, but is not be limited to, the following:

- i) asbestos management plan;
- ii) project contact information;
- iii) site security details;
- iv) timing and sequencing information;
- v) site soil and water management plan;
- vi) noise and vibration control plan;
- vii) dust control plan;
- viii) air monitoring;
- ix) odour control plan;
- x) health and safety plan;
- xi) waste management plan;
- xii) incident management contingency; and
- xiii) unexpected finds protocol.

The EMP must be prepared and implemented to the satisfaction of the supervising environmental consultant. The environmental site management measures must remain in place and be maintained throughout the period of the remediation works, until completion of site remediation and the site has been validated.

Note: An appropriately qualified and experienced environmental consultant certified under the Certified Environmental Practitioner" (CEnvP) Scheme or equivalent.

(Reason: To ensure compliance with statutory requirements.)

16. REMEDIAL WORKS - POST WORKS ENVIRONMENTAL MANAGEMENT PLAN (CW)

On completion of demolition and/or remedial works, an Environmental Management Plan (EMP) shall be prepared by an appropriately qualified and experienced environmental consultant. The EMP must be prepared in accordance with relevant NSW EPA Guidelines.

This Long-term EMP shall describe the nature and location of the contamination and prescribe how the contaminants will be managed and the responsible parties for this management in the long-term.

The Long-term EMP shall be submitted for review by a NSW EPA accredited site auditor prior to the commencement of construction and the issue of a construction certificate.

Any future intrusive ground works carried out that have the potential to conflict with any residual contamination remaining onsite must only be carried out in accordance with the Environmental Management Plan as referenced by the Site Auditor on the final Site Audit Statement and approved by the Council.

Note: A Long-term Environmental Management Plan (EMP) is also known as a Long-term Site Management Plan (SMP).

(Reason: Environmental protection and safety.)

17. TRAFFIC - CONSTRUCTION TRAFFIC MANAGEMENT PLAN (CW)

A Construction Traffic Management Plan (CTMP) is to be prepared by an appropriately qualified Traffic Management Consultant and submitted to and approved by Council's

Engineering Section, prior to the commencement of any works including demolition.

The following matters should be addressed in the CTMP (where applicable):

- i) description of the demolition, excavation and construction works;
- ii) site plan/s showing the site, roads, footpaths, site access points and vehicular movements;
- iii) size, type and estimated number of vehicular movements (including removal of excavated materials, delivery of materials and concrete to the site);
- iv) proposed route(s) from the arterial (state) road network to the site and the proposed route from the site back to the arterial road network;
- v) impacts of the work and vehicular movements on the road network, traffic and pedestrians and proposed methods to safely manage pedestrians and construction related vehicles in the frontage roadways;
- vi) any Traffic Control Plans (TCP's) proposed to regulate traffic and pedestrian movements for construction activities (such as concrete pours, crane installation/removal etc.);
- vii) proposed hours of construction related activities and vehicular movements to and from the site;
- viii) current/proposed approvals from other Agencies and Authorities (including Roads and Maritime Services, Police and State Transit Authority);
- ix) any activities proposed to be located or impact upon Council's road, footways or any public place;
- x) measures to maintain public safety and convenience;
- xi) any proposed road and/or footpath closures;
- xii) turning areas within the site for construction and spoil removal vehicles, allowing a forward egress for all construction vehicles on the site;
- xiii) locations of work zones (where it is not possible for loading/unloading to occur on the site) in the frontage roadways accompanied by supporting documentation that such work zones have been approved by the Local Traffic Committee and Council;
- xiv) location of any proposed crane and concrete pump and truck standing areas on and off the site (and relevant approvals from Council for plant on road);
- xv) a dedicated unloading and loading point within the site for all construction vehicles, plant and deliveries;
- xvi) material, plant and spoil bin storage areas within the site, where all materials are to be dropped off and collected;
- xvii) on-site parking area for employees, tradespersons and construction vehicles as far as possible;
- xviii) proposed areas within the site to be used for the storage of excavated material, construction materials and waste and recycling containers during the construction period; and
- xix) how it is proposed to ensure that soil/excavated material is not transported onto surrounding footpaths and roadways.

(Reason: To mitigate traffic impacts on the surrounding area during the construction period.)

18. **WASTE MANAGEMENT PLAN (CW)**

A Waste Management Plan (WMP) is to be provided in accordance with Part H of Strathfield Consolidated Development Control Plan 2005. All requirements of the approved Waste Management Plan must be implemented during demolition, construction and on-going use of the premises.

The WMP must identify the types of waste that will be generated and all proposals to re-use, recycle or dispose of the waste. The WMP is to be submitted to the Principal Certifying

Authority, prior to commencement of works.

(Reason: To ensure appropriate management of waste.)

19. WORKS ZONE - APPROVAL BY COUNCIL'S TRAFFIC COMMITTEE (CW)

An application for a 'Works Zone' must be submitted to and approved by the Strathfield Council Traffic Committee prior to the commencement of any site work (including demolition).

The suitability of the proposed length and duration of the Works Zone is to be demonstrated in the application for the Works Zone. The application for the Works Zone must be submitted to Council at least six (6) weeks prior to the commencement of work on the site to allow for assessment and tabling of agenda for the Strathfield Council Traffic Committee.

The requirement for a Works Zone may be varied or waived only if it can be demonstrated in the Construction Traffic Management Plan (to the satisfaction of Council) that all construction related activities (including all loading and unloading operations) can and will be undertaken wholly within the site. The written approval of Council must be obtained to provide a Works Zone or to waive the requirement to provide a Works Zone prior to the commencement of any site work.

(Reason: Council requirement.)

CONDITIONS TO BE SATISFIED DURING DEMOLITION AND BUILDING WORKS (DW)

20. CONTAMINATED LAND UNEXPECTED FINDS (DW)

In the instance works cause the generation of odours or uncovering of unexpected contaminants works are to immediately cease, Council is to be notified and a suitably qualified environmental scientist appointed to further assess the site.

The contaminated land situation is to be evaluated by the supervising environmental consultant and an appropriate response determined in consultation with the applicant, which is agreed to by Strathfield Council's Environmental Services Manager.

Note: Council may also request that a NSW EPA accredited site auditor is involved to assist with the assessment of the contaminated land situation and review any new contamination information. The applicant must also adhere to any additional conditions which may be imposed by the accredited site auditor.

(Reason: To ensure compliance with statutory requirements.)

21. FILL MATERIAL (DW)

The only waste derived material which may be received at the development site is:

- i) Virgin excavated material (within the meaning of the Protection of the Environment Operations Act 1997), and
- ii) any other waste-derived material the subject of a resource recovery exemption under cl.51A of the Protection of the Environment Operations (Waste) Regulation 2005 that is permitted to be used as fill material.

Any (b)-type material received at the development site must be accompanied by documentation certifying by an appropriately qualified environmental consultant the materials compliance with the exemption conditions; and this documentation must be

provided to the Principal Certifying Authority on request.

(Reason: To ensure imported fill is of an acceptable standard for environmental protection purposes.)

22. HERITAGE - HISTORIC RELICS FOUND DURING WORKS (DW)

Should any potentially historic relics be discovered on the site during excavation, all excavation or disturbance to the area is to stop immediately and the Heritage Division of the NSW Department of Environment and Heritage should be informed in accordance with Section 146 of the Heritage Act 1977. 'Relics' are any deposit, artefact, object or material evidence that relates to the settlement of the area that comprises New South Wales, not being Aboriginal settlement, and are of State or local heritage significance.

Should any potentially significant Aboriginal material be discovered on the site, all excavation or disturbance of the area is to stop immediately and the Heritage Division of the NSW Department of Environment and Heritage is to be informed in accordance with Section 91 of the National Parks and Wildlife Act 1974.

(Reason: To ensure the proper management and preservation of potentially significant archaeological material.)

23. OBSTRUCTION OF PUBLIC WAY NOT PERMITTED DURING WORKS (DW)

The public way must not be obstructed by any materials, vehicles, refuse, skips or the like, under any circumstances, without the prior approval of Council.

(Reason: To maintain public access and safety.)

24. PUBLIC INFRASTRUCTURE AND SERVICES (DW)

The applicant must comply with the requirements (including financial costs) of any relevant utility provider (e.g. Energy Australia, Sydney Water, Telstra, RMS, Council etc.) in relation to any connections, works, repairs, relocation, replacements and/or adjustments to public infrastructure or services affected by the development.

(Reason: To maintain public infrastructure and/or services.)

25. SITE REQUIREMENTS DURING DEMOLITION AND CONSTRUCTION

All of the following are to be satisfied/complied with during demolition, construction and any other site works:

- i) All demolition is to be carried out in accordance with Australian Standards AS 2601-2001.
- ii) Demolition must be carried out by a registered demolition contractor.
- iii) A single entrance is permitted to service the site for demolition and construction. The footway and nature strip at the service entrance must be planked out with close boarded, hardwood timber footpath protection pads. The pad shall cover the entire width of the footpath opening for the full width of the fence.
- iv) No blasting is to be carried out at any time during construction of the building.
- v) Care must be taken during demolition/ excavation/ building/ construction to prevent any damage to adjoining buildings.
- vi) Adjoining owner property rights and the need for owner's permission must be observed at all times, including the entering onto land for the purpose of undertaking works.

- vii) Any demolition and excess construction materials are to be recycled wherever practicable.
- viii) The disposal of construction and demolition waste must be in accordance with the requirements of the Protection of the Environment Operations Act 1997.
- ix) All waste on the site is to be stored, handled and disposed of in such a manner as to not create air pollution (including odour), offensive noise or pollution of land and/or water as defined by the Protection of the Environment Operations Act 1997.
- x) All excavated material should be removed from the site in the approved manner and be disposed of lawfully to a tip or other authorised disposal area.
- xi) Section 143 of the Protection of the Environment Operations Act 1997 requires waste to be transported to a place which can lawfully accept it. All non-recyclable demolition materials are to be disposed of at an approved waste disposal depot in accordance with legislation.
- xii) All materials on site or being delivered to the site are to generally be contained within the site. The requirements of the Protection of the Environment Operations Act 1997 must be complied with when placing/stockpiling loose material, disposing of concrete waste, or other activities likely to pollute drains or water courses.
- xiii) Details as to the method and location of disposal of demolition materials (weight dockets, receipts etc.) should be kept on site as evidence of approved methods of disposal and recycling.
- xiv) Any materials stored on site must be stored out of view or in such a manner so as not to cause unsightliness when viewed from nearby lands or roadways.
- xv) Public footways and roadways adjacent to the site must be fully maintained and cleared of obstructions during construction unless prior separate approval from Council is obtained including payment of relevant fees.
- xvi) Building operations such as brick cutting, washing tools or paint brushes, and mixing mortar not be performed on the roadway or public footway or any other locations which could lead to the discharge of materials into the stormwater drainage system.
- xvii) All site waters during excavation and construction must be contained on site in an approved manner to avoid pollutants entering into waterways or Council's stormwater drainage system.
- xviii) Stamped plans, specifications, documentation and the consent shall be available on site at all times during construction.

(Reason: To ensure that demolition, building and any other site works are undertaken in accordance with relevant legislation and policy and in a manner which will be non-disruptive to the local area.)

RESOLUTION

The application be **approved** subject to the recommended conditions in the report as amended by the panel.

For the Decision: Stein, Atkins, Evernden, Smith

Against the Decision: Nil

**** End Minutes - Report No. 3****

TO: Strathfield Independent Hearing and Assessment Panel Meeting - 3 August 2017

REPORT: SIHAP – Report No. 4

SUBJECT: 2 SUBWAY LANE, HOMEBUSH
LOT 7 DP 18702 AND LOT B DP403083

DA NO. DA2017/067

RECOMMENDATION

That Development Application No. DA2017/067 for the demolition of existing structures at 2 Subway Lane, Homebush be **APPROVED**, subject to the following conditions:

GENERAL CONDITIONS (GC)

1. APPROVED PLANS AND REFERENCE DOCUMENTATION (GC)

The development, except where modified by a condition(s) of consent, is to be carried out in accordance with the following plans and reference documentation:

Plans affixed with Council's 'Development Consent' stamp relating to Development Consent No. DA2017/067:

Drawing No.	Title/Description	Prepared by	Issue / Revision & Date	Date received by Council
01/01	Demolition Plan	Linx Construction Pty Ltd	May 2017	16 May 2017

Reference Documentation affixed with Council's 'Development Consent' stamp relating to Development Consent No. DA2017/067:

Title / Description	Prepared by	Issue/Revision & Date	Date received by Council
Traffic Management	Linx Construction Pty Ltd	12/05/2017	16 May 2017
Demolition and Construction Management Plan	Linx Construction Pty Ltd	12/05/2017	16 May 2017
Waste Management Plan	Linx Construction Pty Ltd	12/05/2017	16 May 2017
Soil and Water Management	Linx Construction Pty Ltd	12/05/2017	16 May 2017

In the event of any inconsistency between the approved plans and supplementary documentation, the plans will prevail. However, the conditions of this consent shall prevail to the extent of any inconsistency.

(Reason: To ensure that the form of the development undertaken is in accordance with the determination of Council.)

2. CONSTRUCTION HOURS (GC)

No construction, demolition or any other work related activities shall be carried out on the site outside the hours of 7.00 am to 5.00 pm Mondays to Fridays and 8am to 1pm Saturdays.

No construction, demolition or any other work related activities are to be carried out at any time on a Sunday or public holiday.

Where the development involves the use of jackhammers/ rock breakers and the like or other heavy machinery, such equipment may only be used between the hours of 7.00 am - 5.00 pm Monday to Friday only.

(Reason: To maintain amenity to adjoining land owners.)

3. DEMOLITION – GENERALLY (GC)

Alteration and demolition of the existing building is limited to that documented on the approved plans (by way of notation). No approval is given or implied for removal and/or rebuilding of any portion of the existing building which is not shown to be altered or demolished.

(Reason: To ensure compliance with the approved development.)

4. DEMOLITION (GC)

Alterations to, and demolition of, the existing building shall be limited to that documented on the approved plans (by way of notation) or conditioned in this consent. No approval is given or implied for removal and/or rebuilding of any portion of the existing building which is shown to be retained.

Should any portion of the existing building which is indicated on the approved plans to be retained, be damaged for whatever reason, all the works in the area of this damaged portion are to cease and written notification given to Council. No work is to resume until the written approval of Council is obtained.

(Reason: Heritage conservation.)

5. DEMOLITION - SITE SAFETY FENCING (GC)

Site fencing is to be erected to a minimum height of 1.8m complying with WorkCover Guidelines, to exclude public access to the site, prior to any demolition works occurring and maintained for the duration of the demolition works.

If applicable, a separate Hoarding Application for the erection of an A class (fence type) or B class (overhead type) hoarding along the street frontage(s) complying with WorkCover requirements must be obtained including:

payment to Council of a footpath occupancy fee based on the area of footpath to be occupied and Council's Schedule of Fees and Charges before the commencement of work; and

provision of a Public Risk Insurance Policy with a minimum cover of \$10 million in relation to the occupation of and works within Council's road reserve, for the full duration of the proposed works, must be obtained with a copy provided to Council.

(Reasons: Statutory requirement and health and safety.)

6. LIGHTING (GC)

Any lighting of the premises shall be installed and maintained in accordance with Australian Standard AS 4282-1997: Control of the Obtrusive Effects of Outdoor Lighting so as to avoid annoyance to the occupants of adjoining premises or glare to motorists on nearby roads.

No flashing, moving or intermittent lighting, visible from any public place may be installed on

the premises or external signage associated with the development, without the prior approval of Council.

(Reason: To protect the amenity of surrounding development and protect public safety.)

7. **SITE MANAGEMENT (DURING DEMOLITION AND CONSTRUCTION WORKS)**

All of the following are to be satisfied/complied with during demolition, construction and any other site works:

- i) All demolition is to be carried out in accordance with Australian Standard AS 2601-2001.
- ii) Demolition must be carried out by a registered demolition contractor.
- iii) A single entrance is permitted to service the site for demolition and construction. The footway and nature strip at the service entrance must be planked out.
- iv) No blasting is to be carried out at any time during construction of the building.
- v) Care must be taken during demolition/ excavation/ building/ construction to prevent any damage to adjoining buildings.
- vi) Adjoining owner property rights and the need for owner's permission must be observed at all times, including the entering onto land for the purpose of undertaking works.
- vii) Any demolition and excess construction materials are to be recycled wherever practicable.
- viii) The disposal of construction and demolition waste must be in accordance with the requirements of the Protection of the Environment Operations Act 1997.
- ix) All waste on the site is to be stored, handled and disposed of in such a manner as to not create air pollution (including odour), offensive noise or pollution of land and/or water as defined by the Protection of the Environment Operations Act 1997. All excavated material should be removed from the site in an approved manner and be disposed of lawfully to a tip or other authorised disposal area.
- x) All waste must be contained entirely within the site.
- xi) Section 143 of the Protection of the Environment Operations Act 1997 requires waste to be transported to a place which can lawfully accept it. All non-recyclable demolition materials are to be disposed of at an approved waste disposal depot in accordance with legislation.
- xii) All materials on site or being delivered to the site are to generally be contained within the site. The requirements of the Protection of the Environment Operations Act 1997 must be complied with when placing/stockpiling loose material, disposing of concrete waste, or other activities likely to pollute drains or water courses.
- xiii) Details as to the method and location of disposal of demolition materials (weight dockets, receipts, etc.) should be kept on site as evidence of approved methods of disposal or recycling.
- xiv) Any materials stored on site must be stored out of view or in such a manner so as not to cause unsightliness when viewed from nearby lands or roadways.
- xv) Public footways and roadways adjacent to the site must be maintained and cleared of obstructions during construction. No building materials, waste containers or skips may be stored on the road reserve or footpath without prior separate approval from Council, including payment of relevant fees.
- xvi) Building operations such as brick-cutting, washing tools or paint brushes, and mixing mortar not be performed on the roadway or public footway or any other locations which could lead to the discharge of materials into the stormwater drainage system.
- xvii) All site waters during excavation and construction must be contained on site in an approved manner to avoid pollutants entering into waterways or Council's stormwater drainage system.
- xviii) Any work must not prohibit or divert any natural overland flow of water.
- xix) Toilet facilities for employees must be provided in accordance with WorkCover

NSW.

- xx) Protection pads are to be installed to the kerb and gutter where trucks and vehicles enter the site.

(Reason: To ensure that demolition, building and any other site works are undertaken in accordance with relevant legislation and policy and in a manner which will be non-disruptive to the local area.)

8. STORMWATER MANAGEMENT PLAN - CERTIFICATION REQUIREMENT (GC)

A detailed Stormwater Management Plan (SWMP) in line with Council's Stormwater Management Code is to be prepared and certified by a practicing Chartered Professional Engineer on the National Professional Engineer's Register (NPER) at Engineers Australia and submitted to the Principal Certifying Authority and Council, prior to the issue of a Construction Certificate. The SWMP is to be based on the approved development as modified by any conditions of consent.

(Reason: To ensure appropriate provision is made for the disposal and management of stormwater generated by the development, and to ensure public infrastructure in Council's care and control is not overloaded.)

9. SYDNEY WATER - STAMPED PLANS PRIOR TO COMMENCEMENT (GC)

The approved plans must be submitted to a Sydney Water Quick Check agent or Customer Centre to determine whether the development will affect Sydney Water's sewer and water mains, stormwater drains and/or easements, and if further requirements need to be met. Plans will be appropriately stamped.

For Quick Check agent details please refer to the web site www.sydneywater.com.au (see Building Developing and Plumbing then Quick Check) or telephone 13 20 92. The consent authority or a Certifying Authority must ensure that a Quick Check agent/Sydney Water has stamped the plans before the commencement of work.

(Reason: Compliance with Sydney Water requirements.)

10. UTILITIES AND SERVICES - PROTECTION OF (GC)

Any footings or excavation to be located or undertaken adjacent to Council's stormwater must be designed to address the following requirements:

- i) all footings and excavation must be located wholly within the site and clear of any easement boundaries;
- ii) all footings and excavation must be located a minimum of 1000mm from the centreline of the pipeline or 500mm from the outside of the pipeline, whichever is the greater distance from the centreline; and
- iii) footings must extend to at least the depth of the invert of the pipeline unless the footings are to be placed on competent bedrock.

If permanent excavation is proposed beneath the obvert of the pipeline, suitable means to protect the excavation and proposed retaining structures from seepage or other water flow from the pipeline and surrounding subsoil, must be provided. The design must be prepared by a qualified practicing Structural/Civil Engineer.

Construction plans must be approved by the appropriate utility's office (e.g. council, Sydney Water Corporation) to demonstrate that the development complies with the utility's requirements.

The applicant must provide written evidence (e.g. compliance certificate, formal advice) of compliance with the requirements of all relevant utility providers (e.g. Water, Energy, Telecommunications, Gas).

(Reason: To ensure protection of Council assets.)

11. WASTE – TRACKABLE (GC)

Removal of trackable waste (as defined by the NSW Environment Protection Authority) from the site must comply with the Protection of the Environment Operations (Waste) Regulation 2005 for the transportation, treatment and disposal of waste materials. Waste materials must not be disposed on land without permission of the land owner and must with the provisions of the Protection of the Environment and Operations Act 1997.

(Reason: To ensure compliance with legislation.)

CONDITIONS TO BE SATISFIED PRIOR TO COMMENCEMENT OF WORK

12. CONSTRUCTION AND ENVIRONMENTAL MANAGEMENT PLAN (CW)

The applicant must prepare and submit a Construction and Environmental Management Plan (CEMP) to Council, including:

- i) Detailed information on any approvals required from other authorities prior to or during construction.
- ii) Traffic management, including details of:
 - ingress and egress of vehicles to the site;
 - management of loading and unloading of materials;
 - the location of heavy vehicle parking off-site; and
 - designated routes for vehicles to the site.
- iii) The proposed areas within the site to be used for a builder's site office and amenities, the storage of excavated material, construction materials and waste containers during the construction period.
- iv) Erosion and sediment control, detailing measures and procedures consistent with the requirements of Council's guidelines for managing stormwater, including:
 - the collection and treatment of stormwater and wastewater generated on site prior to discharge; and
 - procedures to prevent run-off of solid material and waste from the site.
- v) Waste management, including:
 - details of the types and estimated volumes of waste materials that will be generated;
 - procedures for maximising reuse and recycling of construction materials; and
 - details of the off-site disposal or recycling facilities for construction waste.
- vi) Dust control, outlining measures to minimise the generation and off-site transmission of dust and fine particles, such as watering or damp cloth fences.
- vii) A soil and water management plan, which includes:
 - measures to minimise the area of soils exposed at any one time and conserve top soil;
 - identification and protection of proposed stockpile locations;
 - preservation of existing vegetation and revegetation;
 - measures to prevent soil, sand, sediments leaving the site in an uncontrolled manner;
 - measures to control surface water flows through the site in a manner that diverts clean run-off around disturbed areas, minimises slope gradient and flow

- distance within disturbed areas, ensures surface run-off occurs at non-erodible velocities, and ensures disturbed areas are promptly rehabilitated;
- details of sediment and erosion control measures in place before work commences;
 - measures to ensure materials are not tracked onto the road by vehicles entering or leaving the site; and
 - details of drainage to protect and drain the site during works.
- viii) Asbestos management procedures:
- Anyone who removes, repairs or disturbs bonded or a friable asbestos material must hold a current removal licence from Workcover NSW holding either a Friable (Class A) or a Non- Friable (Class B) Asbestos Removal License which ever applies and a current WorkCover Demolition License where works involve demolition. To find a licensed asbestos removalist please see www.workcover.nsw.gov.au
 - Removal of asbestos by a person who does not hold a Class A or Class B asbestos removal license is permitted if the asbestos being removed is 10m² or less of non-friable asbestos (approximately the size of a small bathroom). Friable asbestos materials must only be removed by a person who holds a current Class A asbestos license.
 - Before starting work, a work site-specific permit approving each asbestos project must be obtained from Workcover NSW. A permit will not be granted without a current Workcover licence. All removal, repair or disturbance of or to asbestos material must comply with the following:
 - The Work Health and Safety Act 2011;
 - The Work Health and Safety Regulation 2011;
 - How to Safety Remove Asbestos Code of Practice – WorkCover 2011; and
 - Safe Work Australia Code of Practice for the Management and Control of Asbestos in the Workplace.
 - Following completion of asbestos removal works undertaken by a licensed asbestos removalist re-occupation of a workplace must not occur until an independent and suitably licensed asbestos removalist undertakes a clearance inspection and issues a clearance certificate.
 - The developer or demolition contractor must notify adjoining residents at least two (2) working days (i.e. Monday to Friday exclusive of public holidays) prior to the commencement of asbestos removal works. Notification is to include, at a minimum:
 - the date and time when asbestos removal works will commence;
 - the name, address and business hours contact telephone number of the demolisher, contractor and/or developer;
 - the full name and license number of the asbestos removalist/s; and
 - the telephone number of WorkCover's Hotline 13 10 50
 - warning signs informing all people nearby that asbestos removal work is taking place in the area. Signs should be placed at all of the main entry points to the asbestos removal work area where asbestos is present. These signs should be weatherproof, constructed of light-weight material and adequately secured so they remain in prominent locations. The signs should be in accordance with AS 1319-1994 Safety signs for the occupational environment for size, illumination, location and maintenance; and
 - appropriate barricades installed as appropriate to prevent public access and prevent the escape of asbestos fibres. Barricades must be installed prior to the commencement of asbestos removal works and remain in place until works are completed.

(Reason: Safety, amenity and protection of public infrastructure and the environment.)

13. COUNCIL PERMITS – FOR ALL ACTIVITIES ON COUNCIL LAND (CW)Works Permit

(as per Section 68 of the Local Government Act 1993 and Section 138 and 139 of the Roads Act 1993)

A Works Permit is required for construction of a vehicular crossing (driveway), new stormwater down pipe connection to kerb and gutter, new footpath and/or stormwater connection. A Works Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Standing Plant Permit

This permit must be applied for where it is intended to park a concrete pump, crane or other plant on the roadway or footpath. A Standing Plant Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Skip Bin Permit

This permit must be applied for if you intend to place a skip bin on the roadway or footpath. A Skip Bin Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Temporary Full or Part Road Closure Permit

This permit must be applied for if you require a full or a part road closure to take place to assist in your construction works. Please use the Works Permit Application Form, which is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Hoarding Permit

This permit must be applied for if you intend to erect a Class A (fence type) or Class B (overhead type) hoarding along the street frontage(s). A Hoarding Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Work Zone Permit

This permit must be applied for if you require permanent parking along the kerbside at the front of the site during construction works. A Work Zone Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Ground Anchoring Permit

This permit must be applied for, for the installation of ground anchors under Council's footway/road reserve. It does not cover ground anchors under private properties. A separate approval is required to be obtained from Roads and Maritime Services (RMS) if it is proposed to install ground anchors under a State or Classified Regional Road (please refer to the end of this application form for more information).

(Reason: Council requirement)

14. NOISE AND VIBRATION MANAGEMENT PLAN (CW)

Prior to commencement of work, a Noise and Vibration Management Plan is to be prepared by a suitably qualified person addressing the likely noise and vibration from demolition, excavation and construction of the proposed development and provided to Council.

The Plan is to identify amelioration measures to ensure the noise and vibration levels will be compliance with:

- a. Construction noise management levels established using the *Interim Construction Noise Guideline (DECC, 2009)*;
- b. Vibration criteria established using the assessing vibration: *Technical guideline (DEC, 2006)* (for human exposure); and
- c. The vibration limits set out in the German Standard DIN 4150-3: *Structural Vibration-effects of vibration on structures* (for structural damage)

The report that itemises equipment to be used for excavation works. The Plan shall address, but shall not be limited to, the following matters:

- i) identification of activities carried out and associated noise sources;
- ii) identification of potentially affected sensitive receivers, including residences, churches, commercial premises, schools and properties containing noise sensitive equipment;
- iii) determination of appropriate noise and vibration objectives for each identified sensitive receiver;
- iv) noise and vibration monitoring, reporting and response procedures;
- v) assessment of potential noise and vibration from the proposed demolition, excavation and construction activities, including noise from construction vehicles;
- vi) description of specific mitigation treatments, management methods and procedures to be implemented to control noise and vibration during construction;
- vii) construction timetabling to minimise noise impacts including time and duration restrictions, respite periods and frequency;
- viii) procedures for notifying residents of construction activities likely to affect their amenity through noise and vibration; and
- ix) contingency plans to be implemented in the event of non-compliances and/or noise complaints. A register should be kept of complaints received, and the action taken to remediate the issue.

(Reason: To protect acoustic amenity of surrounding properties and the public.)

15. REMEDIAL WORKS - PRE-COMMENCEMENT ENVIRONMENTAL MANAGEMENT PLAN (CW)

An Environmental Management Plan (EMP) shall be prepared for the proposed remedial works in accordance with the requirements of the approved Remedial Action Plan.

The EMP must be prepared by an appropriately qualified and experienced environmental consultant.

The EMP for Remediation must include, but is not be limited to, the following:

- i) asbestos management plan;
- ii) project contact information;
- iii) site security details;
- iv) timing and sequencing information;
- v) site soil and water management plan;

- vi) noise and vibration control plan;
- vii) dust control plan;
- viii) air monitoring;
- ix) odour control plan;
- x) health and safety plan;
- xi) waste management plan;
- xii) incident management contingency; and
- xiii) unexpected finds protocol.

The EMP must be prepared and implemented to the satisfaction of the supervising environmental consultant. The environmental site management measures must remain in place and be maintained throughout the period of the remediation works, until completion of site remediation and the site has been validated.

Note: An appropriately qualified and experienced environmental consultant certified under the Certified Environmental Practitioner" (CEnvP) Scheme or equivalent.

(Reason: To ensure compliance with statutory requirements.)

16. **REMEDIAL WORKS - POST WORKS ENVIRONMENTAL MANAGEMENT PLAN (CW)**

On completion of demolition and/or remedial works, an Environmental Management Plan (EMP) shall be prepared by an appropriately qualified and experienced environmental consultant. The EMP must be prepared in accordance with relevant NSW EPA Guidelines.

This Long-term EMP shall describe the nature and location of the contamination and prescribe how the contaminants will be managed and the responsible parties for this management in the long-term.

The Long-term EMP shall be submitted for review by a NSW EPA accredited site auditor prior to the commencement of construction and the issue of a construction certificate.

Any future intrusive ground works carried out that have the potential to conflict with any residual contamination remaining onsite must only be carried out in accordance with the Environmental Management Plan as referenced by the Site Auditor on the final Site Audit Statement and approved by the Council.

Note: A Long-term Environmental Management Plan (EMP) is also known as a Long-term Site Management Plan (SMP).

(Reason: Environmental protection and safety.)

17. **TRAFFIC - CONSTRUCTION TRAFFIC MANAGEMENT PLAN (CW)**

A Construction Traffic Management Plan (CTMP) is to be prepared by an appropriately qualified Traffic Management Consultant and submitted to and approved by Council's Engineering Section, prior to the commencement of any works including demolition.

The following matters should be addressed in the CTMP (where applicable):

- i) description of the demolition, excavation and construction works;
- ii) site plan/s showing the site, roads, footpaths, site access points and vehicular movements;
- iii) size, type and estimated number of vehicular movements (including removal of excavated materials, delivery of materials and concrete to the site);
- iv) proposed route(s) from the arterial (state) road network to the site and the proposed

- v) route from the site back to the arterial road network;
- v) impacts of the work and vehicular movements on the road network, traffic and pedestrians and proposed methods to safely manage pedestrians and construction related vehicles in the frontage roadways;
- vi) any Traffic Control Plans (TCP's) proposed to regulate traffic and pedestrian movements for construction activities (such as concrete pours, crane installation/removal etc.);
- vii) proposed hours of construction related activities and vehicular movements to and from the site;
- viii) current/proposed approvals from other Agencies and Authorities (including Roads and Maritime Services, Police and State Transit Authority);
- ix) any activities proposed to be located or impact upon Council's road, footways or any public place;
- x) measures to maintain public safety and convenience;
- xi) any proposed road and/or footpath closures;
- xii) turning areas within the site for construction and spoil removal vehicles, allowing a forward egress for all construction vehicles on the site;
- xiii) locations of work zones (where it is not possible for loading/unloading to occur on the site) in the frontage roadways accompanied by supporting documentation that such work zones have been approved by the Local Traffic Committee and Council;
- xiv) location of any proposed crane and concrete pump and truck standing areas on and off the site (and relevant approvals from Council for plant on road);
- xv) a dedicated unloading and loading point within the site for all construction vehicles, plant and deliveries;
- xvi) material, plant and spoil bin storage areas within the site, where all materials are to be dropped off and collected;
- xvii) on-site parking area for employees, tradespersons and construction vehicles as far as possible;
- xviii) proposed areas within the site to be used for the storage of excavated material, construction materials and waste and recycling containers during the construction period; and
- xix) how it is proposed to ensure that soil/excavated material is not transported onto surrounding footpaths and roadways.

(Reason: To mitigate traffic impacts on the surrounding area during the construction period.)

18. **WASTE MANAGEMENT PLAN (CW)**

A Waste Management Plan (WMP) is to be provided in accordance with Part H of Strathfield Consolidated Development Control Plan 2005. All requirements of the approved Waste Management Plan must be implemented during demolition, construction and on-going use of the premises.

The WMP must identify the types of waste that will be generated and all proposals to re-use, recycle or dispose of the waste. The WMP is to be submitted to the Principal Certifying Authority, prior to commencement of work.

(Reason: To ensure appropriate management of waste.)

19. **WORKS ZONE - APPROVAL BY COUNCIL'S TRAFFIC COMMITTEE (CW)**

An application for a 'Works Zone' must be submitted to and approved by the Strathfield Council Traffic Committee prior to the commencement of any site work (including demolition).

The suitability of the proposed length and duration of the Works Zone is to be demonstrated in the application for the Works Zone. The application for the Works Zone must be submitted to Council at least six (6) weeks prior to the commencement of work on the site to allow for assessment and tabling of agenda for the Strathfield Council Traffic Committee.

The requirement for a Works Zone may be varied or waived only if it can be demonstrated in the Construction Traffic Management Plan (to the satisfaction of Council) that all construction related activities (including all loading and unloading operations) can and will be undertaken wholly within the site. The written approval of Council must be obtained to provide a Works Zone or to waive the requirement to provide a Works Zone prior to the commencement of any site work.

(Reason: Council requirement.)

CONDITIONS TO BE SATISFIED DURING DEMOLITION AND BUILDING WORKS (DW)

20. CONTAMINATED LAND UNEXPECTED FINDS (DW)

In the instance works cause the generation of odours or uncovering of unexpected contaminants works are to immediately cease, Council is to be notified and a suitably qualified environmental scientist appointed to further assess the site.

The contaminated land situation is to be evaluated by the supervising environmental consultant and an appropriate response determined in consultation with the applicant, which is agreed to by Strathfield Council's Environmental Services Manager.

Note: Council may also request that a NSW EPA accredited site auditor is involved to assist with the assessment of the contaminated land situation and review any new contamination information. The applicant must also adhere to any additional conditions which may be imposed by the accredited site auditor.

(Reason: To ensure compliance with statutory requirements.)

21. FILL MATERIAL (DW)

The only waste derived material which may be received at the development site is:

- i) Virgin excavated material (within the meaning of the Protection of the Environment Operations Act 1997), and
- ii) any other waste-derived material the subject of a resource recovery exemption under cl.51A of the Protection of the Environment Operations (Waste) Regulation 2005 that is permitted to be used as fill material.

Any (b)-type material received at the development site must be accompanied by documentation certifying by an appropriately qualified environmental consultant the materials compliance with the exemption conditions; and this documentation must be provided to the Principal Certifying Authority on request.

(Reason: To ensure imported fill is of an acceptable standard for environmental protection purposes.)

22. HERITAGE - HISTORIC RELICS FOUND DURING WORKS (DW)

Should any potentially historic relics be discovered on the site during excavation, all excavation or disturbance to the area is to stop immediately and the Heritage Division of the

NSW Department of Environment and Heritage should be informed in accordance with Section 146 of the Heritage Act 1977. 'Relics' are any deposit, artefact, object or material evidence that relates to the settlement of the area that comprises New South Wales, not being Aboriginal settlement, and are of State or local heritage significance.

Should any potentially significant Aboriginal material be discovered on the site, all excavation or disturbance of the area is to stop immediately and the Heritage Division of the NSW Department of Environment and Heritage is to be informed in accordance with Section 91 of the National Parks and Wildlife Act 1974.

(Reason: To ensure the proper management and preservation of potentially significant archaeological material.)

23. OBSTRUCTION OF PUBLIC WAY NOT PERMITTED DURING WORKS (DW)

The public way must not be obstructed by any materials, vehicles, refuse, skips or the like, under any circumstances, without the prior approval of Council.

(Reason: To maintain public access and safety.)

24. PUBLIC INFRASTRUCTURE AND SERVICES (DW)

The applicant must comply with the requirements (including financial costs) of any relevant utility provider (e.g. Energy Australia, Sydney Water, Telstra, RMS, Council etc.) in relation to any connections, works, repairs, relocation, replacements and/or adjustments to public infrastructure or services affected by the development.

(Reason: To maintain public infrastructure and/or services.)

25. SITE REQUIREMENTS DURING DEMOLITION AND CONSTRUCTION

All of the following are to be satisfied/complied with during demolition, construction and any other site works:

- i) All demolition is to be carried out in accordance with Australian Standards AS 2601-2001.
- ii) Demolition must be carried out by a registered demolition contractor.
- iii) A single entrance is permitted to service the site for demolition and construction. The footway and nature strip at the service entrance must be planked out with close boarded, hardwood timber footpath protection pads. The pad shall cover the entire width of the footpath opening for the full width of the fence.
- iv) No blasting is to be carried out at any time during construction of the building.
- v) Care must be taken during demolition/ excavation/ building/ construction to prevent any damage to adjoining buildings.
- vi) Adjoining owner property rights and the need for owner's permission must be observed at all times, including the entering onto land for the purpose of undertaking works.
- vii) Any demolition and excess construction materials are to be recycled wherever practicable.
- viii) The disposal of construction and demolition waste must be in accordance with the requirements of the Protection of the Environment Operations Act 1997.
- ix) All waste on the site is to be stored, handled and disposed of in such a manner as to not create air pollution (including odour), offensive noise or pollution of land and/or water as defined by the Protection of the Environment Operations Act 1997.
- x) All excavated material should be removed from the site in the approved manner and be disposed of lawfully to a tip or other authorised disposal area.
- xi) Section 143 of the Protection of the Environment Operations Act 1997 requires

- waste to be transported to a place which can lawfully accept it. All non-recyclable demolition materials are to be disposed of at an approved waste disposal depot in accordance with legislation.
- xii) All materials on site or being delivered to the site are to generally be contained within the site. The requirements of the Protection of the Environment Operations Act 1997 must be complied with when placing/stockpiling loose material, disposing of concrete waste, or other activities likely to pollute drains or water courses.
 - xiii) Details as to the method and location of disposal of demolition materials (weight dockets, receipts etc.) should be kept on site as evidence of approved methods of disposal and recycling.
 - xiv) Any materials stored on site must be stored out of view or in such a manner so as not to cause unsightliness when viewed from nearby lands or roadways.
 - xv) Public footways and roadways adjacent to the site must be fully maintained and cleared of obstructions during construction unless prior separate approval from Council is obtained including payment of relevant fees.
 - xvi) Building operations such as brick cutting, washing tools or paint brushes, and mixing mortar not be performed on the roadway or public footway or any other locations which could lead to the discharge of materials into the stormwater drainage system.
 - xvii) All site waters during excavation and construction must be contained on site in an approved manner to avoid pollutants entering into waterways or Council's stormwater drainage system.
 - xviii) Stamped plans, specifications, documentation and the consent shall be available on site at all times during construction.

(Reason: To ensure that demolition, building and any other site works are undertaken in accordance with relevant legislation and policy and in a manner which will be non-disruptive to the local area.)

RESOLUTION

The application be **approved** subject to the recommended conditions in the report as amended by the panel.

For the Decision: Stein, Atkins, Evernden, Smith

Against the Decision: Nil

**** End Minutes - Report No. 4****