

Minutes

Of the meeting of the:

Strathfield Local Planning Panel Meeting

Held on:

Thursday, 1 November 2018

Commencing at 10:00am at Council Town Hall (Supper Room), 65 Homebush Road, Strathfield

TABLE OF CONTENTS

Item Page No.

SLPP AGENDA ITEMS

SLPP - Report No. 1
 DA2018/111 - 23 Redmyre Road, Strathfield
 Lot 1 DP 724485 & Lot 1 DP 9337554

(Number of Speakers: 0)

SLPP - Report No. 2
 DA2018/032-195 Parramatta Road, Homebust West
 Lot 1 DP 34615.....30

(Number of Speakers: 0)

SLPP - Report No. 3
 DA2018/080 - 14 Francis Street, Strathfield
 LOT 15 SECTION 1 DP 1246764

(Number of Speakers: 1)

SLPP - Report No. 4
 DA2017/051/01 - 14-18 Pilcher Street, Strathfield South
 Lot 17-19 in DP 1143285

(Number of Speakers: 0)

The Chair tabled the pecuniary Interest disclosures of Panel Members.

The meeting of the Strathfield Local Planning Panel Meeting was held in the Council Town Hall (Supper Room), 65 Homebush Road, Strathfield on Thursday 1 November 2018. The meeting commenced at 10:00am and closed at 2:40pm.

The Public Meeting commenced at 10:13am and closed at 11:50am.

The Panel Members conducted site inspections for the purpose of considering items included on the Agenda-

Site inspection time commenced: 8:16am

Site inspection time concluded: 10:05am

PRESENT

Jan Murrell – Chair

Eric Armstrong, Expert

Ian Stapleton, Expert

Robert Jolliffe, Community

ALSO PRESENT

Stephen Clements, Director Infrastructure, Development and Environment

Kandace Lindeberg, Principal Development Planner

Gregory Hansell, Senior Planner

Lily Parker, Administration Assistant

DECLARATIONS OF PECUNIARY INTEREST / CONFLICT OF INTEREST

Ian Stapleton declared a potential conflict of interest due to having to work with the applicant on other projects in relation to DA2018/111, 23 Redmyre Road, Strathfield. The chair determined that this could be perceived as a conflict of interest and he did not participate in the site inspection, public meeting or determination.

TO: Strathfield Local Planning Panel Meeting - 1 November 2018
REPORT: SLPP – Report No. 1
SUBJECT: DA2018/111 - 23 REDMYRE ROAD, STRATHFIELD
LOT 1 DP 724485 & LOT 1 DP 933755
DA NO. DA2018/111

RECOMMENDATION

That Development Application No. 2018/111 for alterations and additions to the existing single storey dwelling including a basement level, in-ground swimming pool, front fence and associated landscaping at 23 Redmyre Road, Strathfield be **APPROVED**, subject to the following conditions:

SPECIAL CONDITIONS (SC)

1. STRUCTURAL ENGINEERING DESIGN, CERTIFICATION & WORK METHODS STATEMENT (SC)

A Structural Engineering design and Work Methods Statement must be produced for the excavation works associated with the driveway and basement and submitted to Council and the Principal Certifying Authority prior to the issue of a Construction Certificate or the commencement of works, whichever occurs first (including site preparation works). The design detail and work methods statement must demonstrate how the portions of the original dwelling house on the site identified to remain as part of the approved works are to be protected during the excavation works and must be accompanied by certification by an appropriately qualified and accredited structural engineer with experience in heritage buildings.

(Reason: to protect the existing dwelling house on the site and to achieve a good heritage outcome.)

2. DEMOLITION - HERITAGE ITEMS (SC)

Alterations to, and demolition of, the existing building shall be limited to that documented on the approved plans (by way of notation) or conditioned in this consent. No approval is given or implied for removal and/or rebuilding of any portion of the existing building which is shown to be retained.

Should any portion of the existing building which is indicated on the approved plans to be retained, be damaged for whatever reason, all the works in the area of this damaged portion are to cease and written notification given to Council. No work is to resume until the written approval of Council is obtained.

(Reason: Heritage conservation.)

3. HERITAGE - REUSE OF SIGNIFICANT BUILDING ELEMENTS (SC)

The reuse and recycling of significant elements such as bricks, stained glass windows, sandstone blocks, verandah thresholds, wall vents, ceiling roses and timber joinery etc. is required. The recycling is to occur, preferably on site and/or to suitable professional recycling yards specialising in the recycling of historic building materials. Removal and storage of these materials is to be carefully carried out by the workers and a specific stockpile area is to be designated and protected. A detailed plan for execution of the above requirements is to be submitted to and approved by Council's Heritage Advisor, prior to issue of a Construction Certificate.

(Reason: To allow for preservation of cultural resources within the Strathfield Council area.)

4. HERITAGE - SUBMISSION OF PHOTOGRAPHIC SURVEY (CC)

A photographic survey is to be made of all structures prior to the commencement of any works on the site, including site preparation works. A copy of this survey is to be submitted to Council **prior to the issue of the Construction Certificate.** Written confirmation that Council reserved the right to use the photographs for its own purposes and genuine research purposes is to be included.

(Reason: To provide a historic record of heritage significant works on the site for archival purposes.)

GENERAL CONDITIONS (GC)

5. APPROVED PLANS AND REFERENCE DOCUMENTATION (GC)

The development, except where modified by a condition(s) of consent, is to be carried out in accordance with the following plans and reference documentation:

Plans affixed with Council's 'Development Consent' stamp relating to Development Consent No.2018/111:

Drawing No.	Title/Description	Prepared by	Issue / Revision & Date	Date received by Council
A1.02	Site Plan	The Site Foreman	Rev C dated 24 September 2018	10 October 2018
A1.03	Demolition Plan	The Site Foreman	-	24 October 2018
A1.04	Basement Floor Plan	The Site Foreman	Rev C dated 24 September 2018	10 October 2018
A1.05	Ground Floor Plan	The Site Foreman	Rev C dated 24 September 2018	10 October 2018
A1.06	Level 1 Floor Plan	The Site Foreman	Rev C dated 24 September 2018	10 October 2018
A1.07	Roof Plan	The Site Foreman	Rev C dated 24 September 2018	10 October 2018
A2.01	South Elevation, North Elevation	The Site Foreman	Rev C dated 24 September 2018	10 October 2018
A2.02	West Elevation	The Site Foreman	Rev C dated 24 September 2018	10 October 2018
A2.03	East Elevation	The Site Foreman	Rev C dated 24 September 2018	10 October 2018
A3.01	Section AA	The Site Foreman	Rev C dated 24 September 2018	10 October 2018

A3.02	Section BB	The Site Foreman	Rev C dated 24 September 2018	10 October 2018
A3.03	Ramp Section	The Site Foreman	Rev C dated 24 September 2018	10 October 2018
A3.04	Section CC	The Site Foreman	Rev A dated 24 September 2018	10 October 2018
A4.01	Schedule of External Finishes	The Site Foreman	Rev C dated 24 September 2018	10 October 2018
A5.04	Sediment & Erosion Control Plan	The Site Foreman	Rev B dated 3 August 2018	6 August 2018
L01/1	Landscape Planting Plan	Michael Siu Landscape Architects	Rev D dated 27 June 2018	6 August 2018
SW01	Roof Plan	HYTEN Engineering	Rev D dated 3 July 2018	6 August 2018
SW02	Ground Floor Plan	HYTEN Engineering	Rev D dated 3 July 2018	6 August 2018
SW03	First Floor Plan	HYTEN Engineering	Rev D dated 3 July 2018	6 August 2018
SW04	Basement Plan	HYTEN Engineering	Rev D dated 3 July 2018	6 August 2018
SW05	Pit & Connection Details	HYTEN Engineering	Rev D dated 3 July 2018	6 August 2018

Reference Documentation affixed with Council's 'Development Consent' stamp relating to Development Consent No.2018/111:

Title / Description	Prepared by	Issue/Revision & Date	Date received by Council
Structural Report	HYTEN Engineering	Dated 4 April 2017	10 October 2018
Heritage Impact Statement	Diana's Planning and Heritage	Dated July 2018	6 August 2018
Heritage Impact Statement: Addendum Statement	The Site Foreman	Rev A dated 28 September 2018	10 October 2018
BASIX Certificate	No. A284830_02	Issued 4 August 2018	6 August 2018
Waste Management Plan	The Site Foreman	Dated 17 July 2018	6 August 2018

In the event of any inconsistency, the conditions of this consent shall prevail.

(Reason: To ensure that the form of the development undertaken is in accordance with the determination of Council.)

6. **BUILDING HEIGHT - MAXIMUM RL TO BE COMPLIED WITH (GC)**

The height of the two (2) storey addition measured from Australian Height Datum (AHD) must not exceed Relative Level (RL) 19.55AHD to the ridge top.

(Reason: To ensure the approved building height is complied with.)

7. CONSTRUCTION HOURS (GC)

No construction or any other work related activities shall be carried out on the site outside the hours of 7.00 am to 5.00 pm Mondays to Fridays and 8am to 1pm Saturdays.

No building activities are to be carried out at any time on a Sunday or public holiday.

Where the development involves the use of jackhammers/rock breakers and the like or other heavy machinery, such equipment may only be used between the hours of 7.00 am - 5.00 pm Monday to Friday only.

(Reason: To maintain amenity to adjoining land owners.)

8. CONSTRUCTION WITHIN BOUNDARIES (GC)

The development including but not limited to footings, walls, roof barges and guttering must be constructed wholly within the boundary of the premises. No portion of the proposed structure shall encroach onto the adjoining properties. Gates must be installed so they do not open onto any footpath or adjoining land.

(Reason: Approved works are to be contained wholly within the subject site.)

9. DEMOLITION – GENERALLY (GC)

Alteration and demolition of the existing building is limited to that documented on the approved plans (by way of notation). No approval is given or implied for removal and/or rebuilding of any portion of the existing building which is not shown to be altered or demolished.

(Reason: To ensure compliance with the approved development.)

10. DEMOLITION - SITE SAFETY FENCING (GC)

Site fencing is to be erected to a minimum height of 1.8m complying with WorkCover Guidelines, to exclude public access to the site, prior to any demolition works occurring and maintained for the duration of the demolition works.

If applicable, a separate Hoarding Application for the erection of an A class (fence type) or B class (overhead type) hoarding/fencing along the street frontage(s) complying with WorkCover requirements must be obtained including:

- payment to Council of a footpath occupancy fee based on the area of footpath to be occupied and Council's Schedule of Fees and Charges before the commencement of work; and
- provision of a Public Risk Insurance Policy with a minimum cover of \$10 million in relation to the occupation of and works within Council's road reserve, for the full duration of the proposed works, must be obtained with a copy provided to Council.

(Reasons: Statutory requirement and health and safety.)

11. LANDSCAPING ADJACENT SWIMMING POOLS/SPAS (GC)

A minimum one (1) metre wide landscape strip is to be provided between the swimming

pool and adjacent common boundaries. The landscape strip is to be planted with a continuous row of evergreen shrubs of a minimum five (5) litre container size and capable of achieving a minimum mature height of three (3) metres. Details of the selected plants shall be submitted to and approved by the Principal Certifying Authority. Compliance with this condition shall be certified by the Principal Certifying Authority, prior to occupation of the premises.

(Reason: Privacy amenity of adjoining properties.)

12. LANDSCAPING - CANOPY TREES IN FRONT SETBACK (GC)

New development shall provide at least two (2) canopy trees within the front setback adjacent the front boundary (existing trees may be included). New canopy trees shall be at least three (3) metres high at the time of planting and capable of reaching a mature height of 10m.

Species shall be selected from Council’s Recommended Tree List (Available from Council’s website or from the Customer Service Centre). Compliance with this condition is to be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: To ensure the landscape character of the locality is maintained.)

13. LANDSCAPING – TREES TO BE RETAINED (GC)

The trees listed below shall be retained at all times:

<u>Tree</u>	<u>Height/ Spread (m)</u>	<u>Location</u>	<u>Protection Zone (m)</u>	<u>Structural Root Zone (m)</u>
1)Lophostemon confertus	10 x 8	Road Reserve	4.8	2.47
2)Livistona australis	15 x 12	Road Reserve	3.6	2.25
3)Lophostemon confertus	15 x 12	Road Reserve	9.0	3.09
4) Murraya paniculata x 3	3 x 7	Front Yard	6.0 x 3.0	6.0 x 2.0
5) Plumeria rubra	2 x 2	Front Yard	2.0	2.0
6) Macadamia integrifolia	6 x 4	Front Yard	2.4	2.0

and protected by the establishment of a protection zone (in accordance with Australian Standard AS4970 Protection of trees on development sites) before any site works begin (including any demolition/excavation).

Manual excavation is required within the canopy spread of the trees to be retained.

(Reason: To ensure the protection of trees to be retained on the site.)

14. ENVIRONMENTAL PROTECTION – TREE (GC)

All street trees and trees on private property that are protected under Council’s controls and as listed above, shall be retained except where Council’s prior written consent has been obtained. The felling, lopping, topping, ringbarking, wilful destruction or removal of any tree/s unless in conformity with this approval or subsequent approval is prohibited.

All healthy trees and shrubs identified for retention on the approved drawings are to be suitably protected in accordance with Section 4, Tree protection measures, and Appendix C Tree Protection Zone Sign, of Australian Standard AS4970 - 2009, Protection of Trees on Development Sites, prior to the commencement of any works (including any demolition and

excavation) and maintained for the duration of the works.

In this regard the street tree and all protected trees on or adjacent to the site will be protected as described below;

- i. A Tree Protection (Management) Plan prepared by a AQF Level 5 Arborist is to be available on site at all times prior to the issue of the Constriction Certificate, for all demolition and site works. This Tree Protection (Management) Plan must be shown on the demand of Authorised Council staff.
- ii. Protective perimeter fencing must be consistent with AS 4687, using metal fence posts greater than 20mm diameter and solid or chain wire mesh 2 metres in height supported on concrete pads/feet at 2-2.5 metre spacing. Fencing placement should not be closer than 2.5 metres from the trunk of each protected tree, or at a distance as specified by the approved Tree Protection (Management) Plan and approved by Council's Tree Management Officer. Shade cloth is to be used to prevent entry of dust and contaminated liquids into the root protection area.
- iii. Signs must be placed on the Fencing. These signs must comply with AS1319. The signs must state the purpose of the fencing and the name and contact details of the builder and the appointed AQF Level 5 consultant arborist.
- iv. Root protection is to be provided in the form of mulching to a depth of 50-100mm, inside of the fenced tree protection zone.
- v. Ground (Root) Trunk and Branch Protection must comply with the diagram of Figure 4 of AS4970 – 2009. Ground protection within the tree protection zone and drip line should be in the form of heavy steel plates or timber rumble boards over mulch or aggregate. Trunk and branch protection should be to a minimum height of 2 metres and must include measures to protect the tree/s against damage from the movement of trucks, plant equipment and materials at greater heights above ground level.
- vi. Temporary signs, cables, wires must not be attached to, or suspended, on any street tree or protected tree.
- vii. Above ground utilities must not be placed within the canopy of an existing protected tree, or create the future need for clearance pruning.
- viii. Below ground utilities/services must not be located inside the fenced tree protection zone.
- ix. Scaffolding must not be located in the fenced tree protection zone unless authorised by the approved Tree Protection (Management) Plan and Council's Tree Management Officer
- x. Council must be notified in writing within 24 hours, for all temporary removal of the tree protection fencing ground (root) trunk and branch protection within the root protection area.
- xi. Pruning of a street tree is prohibited without the written consent of Council.

(Reason: To ensure the protection of trees to be retained on the site.)

15. **LANDSCAPING - CANOPY TREES IN REAR SETBACK (GC)**

New development shall provide at least one (1) canopy trees within the rear yard New canopy trees shall be planted from 200 litre containers at the time of planting and capable of reaching a potential mature height of 10 m.

The new trees must not be planted closer than 1.5 metres from a structure or property boundary.

Species shall be selected from Council’s Recommended Tree List (Available from Council’s website or from the Customer Service Centre). Compliance with this condition is to be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

Trees are to conform to the NATSPEC guide and Guide for assessing the quality of and purchasing of landscape trees by Ross Clarke, 2003. Trees are to be true to type, healthy and vigorous at time of delivery and planting, shall be pest and disease free, free from injury and wounds and self-supporting; and shall be maintained until maturity.

All trees are to be staked and tied with a minimum of three (3) hardwood stakes. Ties are to be hessian and fixed firmly to the stakes, one tie at half the height of the main stem, others as necessary to stabilise the plant.

Root deflection barriers having a minimum depth of 600mm are to be installed adjacent to all footpaths and driveways.

Soil conditioner/fertilizer/moisture retention additive/s are to be applied in accordance with manufacturer’s recommendations, and mixed into the backfilling soil after planting tree/s.

A minimum 75mm depth of organic mulch shall be placed within an area 0.5m from the base of the tree.

Details demonstrating compliance shall be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: To ensure the landscape character of the locality is maintained.)

16. LANDSCAPING – TREES PERMITTED TO BE REMOVED (GC)

The following listed trees are permitted to be removed to accommodate the proposed development.

<u>Tree</u>	<u>Height/ Spread (m)</u>	<u>Location</u>
7)Frangipanni	2 x 2	Western Yard
8)Row of insignificant trees	3 x 10	Eastern yard

All trees permitted to be removed by this consent shall be replaced by species selected from Council’s recommended planting list. Replacements shall be a minimum 50 litre container size and shall be maintained until maturity.

(Reason: To ensure the landscape character of the locality is maintained.)

17. MATERIALS – CONSISTENT WITH SUBMITTED SCHEDULE (GC)

All external materials, finishes and colours are to be consistent with the schedule submitted and approved by Council with the development application.

(Reason: To ensure compliance with this consent.)

18. PRINCIPAL CERTIFYING AUTHORITY (PCA) IDENTIFICATION SIGN (GC)

Prior to commencement of any work, signage must be erected in a prominent position on the work site identifying:

- i) the Principal Certifying Authority (PCA) by showing the name, address and telephone number of the PCA;
- ii) the Principal Contractor by showing the Principal Contractor's name, address and telephone number (outside of work hours) for that person; and
- iii) the sign must state that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the work is being carried out, but must be removed when the work has been completed.

This clause does not apply to building work, subdivision work or demolition work that is carried out inside an existing building that does not affect the external walls of the building.

(Reason: Statutory requirement.)

19. PRIVACY - SCREEN PLANTING TO SIDE AND REAR BOUNDARIES (GC)

Evergreen shrubs with a minimum 5 litre container size achieving a minimum mature height of 3m shall be planted along the side and rear boundaries to provide suitable privacy screening. Screen planting shall be maintained at all times. Details of the selected plants shall be submitted to and approved by the Principal Certifying Authority. Compliance with this condition shall be certified by the Principal Certifying Authority, prior to occupation of the premises.

(Reason: To maintain privacy amenity to neighbouring residences.)

20. SITE MANAGEMENT (DURING DEMOLITION AND CONSTRUCTION WORKS)

All of the following are to be satisfied/complied with during demolition, construction and any other site works:

- i) All demolition is to be carried out in accordance with Australian Standard AS 2601-2001.
- ii) Demolition must be carried out by a registered demolition contractor.
- iii) A single entrance is permitted to service the site for demolition and construction. Protection pads are to be installed to the kerb, gutter and nature strip where trucks and vehicles enter the site.
- iv) No blasting is to be carried out at any time during construction of the building.
- v) Care must be taken during demolition/ excavation/ building/ construction to prevent any damage to adjoining buildings.
- vi) Adjoining owner property rights and the need for owner's permission must be observed at all times, including the entering onto land for the purpose of undertaking works.
- vii) Any demolition and excess construction materials are to be recycled wherever practicable.
- viii) The disposal of construction and demolition waste must be in accordance with the requirements of the Protection of the Environment Operations Act 1997.
- ix) All waste on the site is to be stored, handled and disposed of in such a manner as to not create air pollution (including odour), offensive noise or pollution of land and/or water as defined by the Protection of the Environment Operations Act 1997. All excavated material should be removed from the site in an approved manner and be disposed of lawfully to a tip or other authorised disposal area.
- x) All waste must be contained entirely within the site.
- xi) A site plan including temporary waste storage locations, construction material storage areas and vehicular access to and from the site must be included with application.

- xii) Section 143 of the Protection of the Environment Operations Act 1997 requires waste to be transported to a place which can lawfully accept it. All non-recyclable demolition materials are to be disposed of at an approved waste disposal depot in accordance with legislation.
- xiii) Details as to the method and location of disposal of demolition materials (weight dockets, receipts, etc.) should be kept on site as evidence of approved methods of disposal or recycling and must be presented to Council and/or Principal Certifying Authority upon request.
- xiv) All materials on site or being delivered to the site are to generally be contained within the site. The requirements of the Protection of the Environment Operations Act 1997 must be complied with when placing/stockpiling loose material, disposing of concrete waste, or other activities likely to pollute drains or water courses.
- xv) Any materials stored on site must be stored out of view or in such a manner so as not to cause unsightliness when viewed from nearby lands or roadways.
- xvi) Public footways, include nature strips and roadways adjacent to the site must be maintained and cleared of obstructions during construction. No building materials, waste containers or skips may be stored on the road reserve or footpath without prior separate approval from Council, including payment of relevant fees.
- xvii) Building operations such as brick-cutting, washing tools or paint brushes, and mixing mortar not be performed on the roadway or public footway or any other locations which could lead to the discharge of materials into the stormwater drainage system.
- xviii) All site waters during excavation and construction must be contained on site in an approved manner to avoid pollutants entering into waterways or Council's stormwater drainage system.
- xix) Any work must not prohibit or divert any natural overland flow of water.
- xx) Toilet facilities for employees must be provided in accordance with WorkCover NSW.

(Reason: To ensure that demolition, building and any other site works are undertaken in accordance with relevant legislation and policy and in a manner which will be non-disruptive to the local area.)

21. **STORMWATER MANAGEMENT PLAN - CERTIFICATION REQUIREMENT (GC)**

A detailed Stormwater Management Plan (SWMP) in line with Council's Stormwater Management Code is to be prepared and certified by a practicing Chartered Professional Engineer on the National Professional Engineer's Register (NPER) at Engineers Australia and submitted to the Principal Certifying Authority and Council, prior to the issue of a Construction Certificate. The SWMP is to be based on the approved development as modified by any conditions of consent.

(Reason: To ensure appropriate provision is made for the disposal and management of stormwater generated by the development, and to ensure public infrastructure in Council's care and control is not overloaded.)

22. **SYDNEY WATER - STAMPED PLANS PRIOR TO COMMENCEMENT (GC)**

The approved plans must be submitted to a Sydney Water Quick Check agent or Customer Centre to determine whether the development will affect Sydney Water's sewer and water mains, stormwater drains and/or easements, and if further requirements need to be met. Plans will be appropriately stamped.

For Quick Check agent details please refer to the web site www.sydneywater.com.au (see Building Developing and Plumbing then Quick Check) or telephone 13 20 92. The consent authority or a Certifying Authority must ensure that a Quick Check agent/Sydney Water has stamped the plans before the commencement of work.

(Reason: Compliance with Sydney Water requirements.)

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF A CONSTRUCTION CERTIFICATE (CC)

23. BASIX COMMITMENTS (CC)

The approved BASIX Certificate shall be submitted to the Principal Certifying Authority with the application for a Construction Certificate.

Where a change or changes are proposed in the BASIX commitments, the applicant must submit a new BASIX Certificate to the Principal Certifying Authority and Council. If any proposed change in the BASIX commitments is inconsistent with the development consent the applicant will be required to submit a modification to the development consent to Council under Section 4.55 of the Environmental Planning and Assessment Act 1979.

All commitments in the BASIX Certificate must be shown on the plans accompanying the Construction Certificate.

(Reason: Statutory compliance.)

24. BUILDING CODE OF AUSTRALIA - COMPLIANCE WITH (CC)

All architectural drawings, specifications and related documentation shall comply with the Building Code of Australia (BCA). All work must be carried out in accordance with the requirements of the Building Code of Australia (BCA).

In the case of residential building work for which the Home Building Act 1989 requires there to be a contract of insurance in force in accordance with Part 6 of that Act, such a contract of insurance is to be in force before any building work authorised to be carried out by the consent commences.

Details demonstrating compliance with this condition are to be submitted to the Principle Certifying Authority, prior to issue of the Construction Certificate.

(Reason: This is a 'prescribed' condition under clause 98(1) of the Environmental Planning and Assessment Regulation 2000.)

25. CAR PARKING - BASEMENT CAR PARKING REQUIREMENTS (CC)

Details demonstrating compliance with the following is to be submitted to the Principal Certifying Authority, prior to issue of the Construction Certificate:

- i) Minimal internal clearance of the basement is 2.2m in accordance with BCA requirements.
- ii) Driveways shall comply with Australian/New Zealand Standard AS/NZS 2890.1:2004 - Parking facilities - Off-street car parking and achieve a maximum gradient of 1:4.
- iii) Basement entries and ramps/driveways within the property are to be no more than 3.5m wide.
- iv) Provision of pump-out systems and stormwater prevention shall be in accordance with Council's Stormwater Management Guide.

(Reason: To ensure suitable development.)

26. CAR PARKING - VEHICULAR ACCESS RAMPS (CC)

Vehicular access ramps shall comply with the provisions of AS/NZS 2890.1:2004. Plans to be submitted shall contain the following details:

- i) Longitudinal section along the extreme wheel paths of each driveway/access ramp at a scale of 1:25 demonstrating compliance with the scraping provisions of AS/NZS 2890.1:2004. It shall include all levels and grades, including those levels stipulated as boundary levels, both existing and proposed. It shall extend from the centre-line of the roadway through to the parking area.
- ii) Sections showing the clearance to the underside of any overhead structure (minimum headroom requirements 2200mm minimum for standard headroom clearance or 2400mm where disabled access provisions are to be provided) demonstrating compliance with the provisions of AS/NZS 2890.1:2004.
- iii) Longitudinal section along the gutter line showing how it is intended to transition the vehicular crossing into the existing kerb and gutter. Boundary levels shall generally run parallel with the kerb levels.
- iv) Location of verge trees, street furniture and service installations.
- v) Superimposition of vehicle turning circles for access into parking spaces.
- vi) Certification that the design complies with AS/NZS 2890.1:2004 by a Qualified Engineer.

The certification referred to in (vi) above shall be submitted to the Principal Certifying Authority prior to the issue of a Construction Certificate (for the design) and to the Principal Certifying Authority prior to the issue of any Occupation Certificate for the 'as-built works'.

(Reason: To ensure adequate vehicular access can be achieved.)

27. CAR PARKING - COMPLIANCE WITH AS/NZS 2890.1:2004 (CC)

Car parking dimensions must comply with the Australian/New Zealand Standard AS/NZS 2890.1:2004 - Parking facilities - Off-street car parking. Details demonstrating compliance are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: To ensure compliance with Australian Standards relating to parking of vehicles.)

28. CAR PARKING - VEHICULAR CIRCULATION, AISLE AND RAMP WIDTHS (CC)

The aisle widths, internal circulation, ramp widths and grades of the car park shall comply with the Roads and Traffic Authority Guidelines and AS/NZS 2890.1:2004 - Off-Street Car Parking Code.

Vehicular manoeuvring paths are to be prepared demonstrating that all vehicles can enter or depart the site in a forward direction without encroaching on required car parking spaces.

(Reason: To ensure compliance with Australian Standards relating to manoeuvring, access and parking of vehicles.)

29. COMMENCEMENT OF WORKS (NO WORKS UNTIL A CC IS OBTAINED)

Building work, demolition or excavation must not be carried out until a Construction Certificate has been issued by either Strathfield Council or a Principal Certifying Authority.

Demolition of any part of a building triggers 'commencement of erection of building' pursuant of section 4.19 of the EP&A Act 1979. Accordingly, demolition works must not commence until a Construction Certificate has been issued, a Principal Certifying Authority

has been appointed and a Notice of Commencement has been issued.

(Reason: To ensure compliance with statutory provisions.)

30. CONSTRUCTION AND ENVIRONMENTAL MANAGEMENT PLAN (CC)

The applicant must prepare and submit a Construction and Environmental Management Plan (CEMP) to the Principal Certifying Authority, including:

- i) Detailed information on any approvals required from other authorities prior to or during construction.
- ii) Traffic management, including details of:
 - ingress and egress of vehicles to the site;
 - management of loading and unloading of materials;
 - the location of heavy vehicle parking off-site; and
 - designated routes for vehicles to the site.
- iii) The proposed areas within the site to be used for a builder's site office and amenities, the storage of excavated material, construction materials and waste containers during the construction period.
- iv) Erosion and sediment control, detailing measures and procedures consistent with the requirements of Council's guidelines for managing stormwater, including:
 - the collection and treatment of stormwater and wastewater generated on site prior to discharge; and
 - procedures to prevent run-off of solid material and waste from the site.
- v) Waste management, including:
 - details of the types and estimated volumes of waste materials that will be generated;
 - procedures for maximising reuse and recycling of construction materials; and
 - details of the off-site disposal or recycling facilities for construction waste.
- vi) Dust control, outlining measures to minimise the generation and off-site transmission of dust and fine particles, such as watering or damp cloth fences.
- vii) A soil and water management plan, which includes:
 - measures to minimise the area of soils exposed at any one time and conserve top soil;
 - identification and protection of proposed stockpile locations;
 - preservation of existing vegetation and revegetation;
 - measures to prevent soil, sand, sediments leaving the site in an uncontrolled manner;
 - measures to control surface water flows through the site in a manner that diverts clean run-off around disturbed areas, minimises slope gradient and flow distance within disturbed areas, ensures surface run-off occurs at non-erodible velocities, and ensures disturbed areas are promptly rehabilitated;
 - details of sediment and erosion control measures in place before work commences;
 - measures to ensure materials are not tracked onto the road by vehicles entering or leaving the site; and
 - details of drainage to protect and drain the site during works.
- viii) Asbestos management procedures:
 - Anyone who removes, repairs or disturbs bonded or a friable asbestos material must hold a current removal licence from Workcover NSW holding either a Friable (Class A) or a Non- Friable (Class B) Asbestos Removal License which ever applies and a current WorkCover Demolition License where works involve demolition. To find a licensed asbestos removalist please see www.workcover.nsw.gov.au
 - Removal of asbestos by a person who does not hold a Class A or Class B

asbestos removal license is permitted if the asbestos being removed is 10m² or less of non-friable asbestos (approximately the size of a small bathroom). Friable asbestos materials must only be removed by a person who holds a current Class A asbestos license.

- Before starting work, a work site-specific permit approving each asbestos project must be obtained from WorkCover NSW. A permit will not be granted without a current WorkCover licence. All removal, repair or disturbance of or to asbestos material must comply with the following:
 - The Work Health and Safety Act 2011;
 - The Work Health and Safety Regulation 2011;
 - How to Safety Remove Asbestos Code of Practice – WorkCover 2011; and
 - Safe Work Australia Code of Practice for the Management and Control of Asbestos in the Workplace.
- Following completion of asbestos removal works undertaken by a licensed asbestos removalist re-occupation of a workplace must not occur until an independent and suitably licensed asbestos removalist undertakes a clearance inspection and issues a clearance certificate.
- The developer or demolition contractor must notify adjoining residents at least two (2) working days (i.e. Monday to Friday exclusive of public holidays) prior to the commencement of asbestos removal works. Notification is to include, at a minimum:
 - the date and time when asbestos removal works will commence;
 - the name, address and business hours contact telephone number of the demolisher, contractor and/or developer;
 - the full name and license number of the asbestos removalist/s; and
 - the telephone number of WorkCover's Hotline 13 10 50
 - warning signs informing all people nearby that asbestos removal work is taking place in the area. Signs should be placed at all of the main entry points to the asbestos removal work area where asbestos is present. These signs should be weatherproof, constructed of light-weight material and adequately secured so they remain in prominent locations. The signs should be in accordance with AS 1319-1994 Safety signs for the occupational environment for size, illumination, location and maintenance; and
 - appropriate barricades installed as appropriate to prevent public access and prevent the escape of asbestos fibres. Barricades must be installed prior to the commencement of asbestos removal works and remain in place until works are completed.

(Reason: Safety, amenity and protection of public infrastructure and the environment.)

31. **COUNCIL PERMITS – FOR ALL ACTIVITIES ON COUNCIL LAND (CC)**

Works Permit

(as per Section 68 of the Local Government Act 1993 and Section 138 and 139 of the Roads Act 1993)

A Works Permit is required for construction of a vehicular crossing (driveway), new stormwater down pipe connection to kerb and gutter, new footpath and/or stormwater connection. A Works Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Standing Plant Permit

This permit must be applied for where it is intended to park a concrete pump, crane or other plant on the roadway or footpath. A Standing Plant Permit Application Form is available

from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Skip Bin Permit

This permit must be applied for if you intend to place a skip bin on the roadway or footpath. A Skip Bin Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Temporary Full or Part Road Closure Permit

This permit must be applied for if you require a full or a part road closure to take place to assist in your construction works. Please use the Works Permit Application Form, which is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Hoarding/Fencing Permit

This permit must be applied for if you intend to erect a Class A (fence type) or Class B (overhead type) hoarding/fencing along the street frontage(s). A Hoarding Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Work Zone Permit

This permit must be applied for if you require permanent parking along the kerbside at the front of the site during construction works. A Work Zone Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Ground Anchoring Permit

This permit must be applied for, for the installation of ground anchors under Council's footway/road reserve. It does not cover ground anchors under private properties. A separate approval is required to be obtained from Roads and Maritime Services (RMS) if it is proposed to install ground anchors under a State or Classified Regional Road (please refer to the end of this application form for more information).

(Reason: Council requirement.)

32. DILAPIDATION REPORT - PRE-COMMENCEMENT (CC)

Subject to access being granted, a pre-commencement Dilapidation Report is to be undertaken on all adjoining properties, which in the opinion of a suitably qualified engineer, could be potentially affected by the construction of the project. The Dilapidation Report shall be carried out prior to the issue of a Construction Certificate.

The Dilapidation Report is to be prepared by a suitably Qualified Engineer with current Corporate Membership with the Institution of Engineers, Australia or Geotechnical Practitioner. The report shall include a photographic survey of adjoining properties detailing the physical condition of those properties, both internally and externally, including walls, ceilings, roof, structural members and other such items.

If access for undertaking the dilapidation survey is denied by an adjoining owner, the applicant must demonstrate, in writing, to Council's satisfaction attempts have been made to obtain access and/or advise the affected property owner of the reason for the survey and these attempts have been unsuccessful. Written concurrence must be obtained from

Council in such circumstances.

The Report shall cover structural and geotechnical factors likely to arise from the development. A copy of this Report shall be submitted to Council as a record. The person having the benefit of the development consent must, at their own cost, rectify any damage caused to other properties during the construction of the project.

(Reason: To ensure no damage to adjoining properties occurs.)

33. **EROSION AND SEDIMENTATION CONTROL PLAN (CC)**

An Erosion and Sediment Control Plan is to be prepared where construction or excavation activity requires the disturbance of the soil surface and existing vegetation. Details including drawings and specifications must provide adequate measures for erosion and sediment control to ensure:

- i) Compliance with the approved Soil and Water Management Plan.
- ii) Removal or disturbance of vegetation and top soil is confined to within 3m of the approved building area (no trees to be removed without approval).
- iii) All uncontaminated run-off is diverted around cleared or disturbed areas.
- iv) Silt fences or other devices are installed to prevent sediment and other debris escaping from the cleared or disturbed areas into drainage systems or waterways.
- v) All erosion and sediment controls are fully maintained for the duration of demolition/development works.
- vi) Controls are put into place to prevent tracking of sediment by vehicles onto adjoining roadways.
- vii) All disturbed areas are rendered erosion-resistant by turfing, mulching, paving or similar.
- viii) All water pumped or otherwise removed from excavations or basement areas is filtered to achieve suspended solids/non filterable residue levels complying with the Australian Water Quality guidelines for Fresh and Marine Waters.
- ix) Pumped or overland flows of water are discharged so as not to cause, permit or allow erosion before the commencement of work (and until issue of the occupation certificate).

Details of the proposed soil erosion and sedimentation controls are to be submitted to the Principal Certifying Authority with the Construction Certificate Application. Under no circumstances are any works to commence, prior to these details being approved by the Principal Certifying Authority and the controls being in place on the site.

(Reason: Environmental protection.)

34. **EXCAVATION - AFFECTING ADJOINING LAND (CC)**

If an excavation associated with the approved development extends below the level of the base of the footings of a building on an adjoining allotment of land, the person having the benefit of the development consent must, at the person's own expense, comply with the requirements of clause 98E of the Environmental Planning and Assessment Regulation 2000, including:

- i) protect and support the adjoining premises from possible damage from the excavation, and
- ii) where necessary, underpin the adjoining premises to prevent any such damage.

The condition referred to in subclause (i) does not apply if the person having the benefit of the development consent owns the adjoining land or the owner of the adjoining land has

given consent in writing to that condition not applying. Details shall be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Structural safety.)

35. LANDSCAPING - LANDSCAPE PLAN REQUIRED (CC)

A landscape plan prepared by a qualified landscape architect or landscape consultant to a scale of 1:100 or 1:200, conforming to all relevant conditions of consent is to be submitted to the satisfaction of the Principal Certifying Authority with the Construction Certificate application.

The plan must include the following information:

- i) details demonstrating compliance with SCDCP 2005 in relation to landscaping requirements;
- ii) location of all existing and proposed landscape features including materials to be used;
- iii) all trees to be retained, removed or transplanted;
- iv) existing and proposed finished ground levels;
- v) top and bottom wall levels for both existing and proposed retaining and free standing walls; and
- vi) a detailed plant schedule which includes proposed species listed by botanical (genus and species) and common names, quantities of each species, pot sizes and the estimated size at maturity. A minimum of 25% of species shall be locally sourced indigenous species. Species shall be predominantly selected from Council's Recommended Tree List.

Consideration within the design should be given to the scale of planting in proportion to the proposed development, consistency with the existing landscape character of the area, potential views, solar access and privacy for neighbouring development.

(Reason: Landscape quality.)

36. PRIVACY - OBSCURE GLAZING IN WET AREAS (CC)

All bathroom, ensuite and toilet windows shall be installed with obscure glazing. Plans shall be notated accordingly and details demonstrating compliance submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Privacy amenity.)

37. SECTION 7.11 CONTRIBUTION PAYMENT - INDIRECT CONTRIBUTIONS PLAN) (CC)

In accordance with the provisions of Section 7.11 of the Environmental Planning and Assessment Act 1979 and the Strathfield Indirect Development Contributions Plan 2010-2030, a contribution in the form of cash, cheque or credit card (financial transaction fee applies) shall be paid to Council for the following purposes:

Local Amenity Improvement Levy	\$10,594.84
--------------------------------	--------------------

The total amount of the contribution is valid as at the date of determination and is subject to quarterly indexation. The amount of the contribution under this condition shall be indexed in accordance with clause 4.12 of the Strathfield Indirect Development Contributions Plan 2010-2030.

Contributions must be received by Council and submitted to the Accredited Certifier, prior to the issue of any Construction Certificate.

A copy of this condition is to be presented to Council's Customer Service Centre when paying the contribution so that it can be recalculated.

Note: A copy of Strathfield Council's Section 7.11 Indirect Development Contributions Plan may be downloaded from Council's website.

(Reason: To enable the provision of public amenities and services required/anticipated as a consequence of increased demand resulting from the development.)

38. **SECURITY PAYMENT - DAMAGE DEPOSIT FOR COUNCIL INFRASTRUCTURE (CC)**

A security (damage deposit) of **\$15,000** (calculated in accordance with Council's adopted Fees and Charges) shall be paid to Council, prior to the issue of a Construction Certificate.

The deposit is required as security against any damage to Council property during works on the site. The applicant must bear the cost of all restoration works to Council's property damaged during the course of this development. All building work must be carried out in accordance with the Building Code of Australia.

Payment may be accepted in the form of cash, bank guarantee, cheque or credit card (financial transactions fees apply). Note: Additional fees apply for the lodgement of a bank guarantee in lieu of cash bond applies in accordance with Council's adopted Fees and Charges.

Any costs associated with works necessary to be carried out to rectify any damages caused by the development, shall be deducted from the Damage Deposit.

Note: Should Council property adjoining the site be defective e.g. cracked footpath, broken kerb etc., this should be reported in writing, or by photographic record, submitted to Council at least seven (7) days prior to the commencement of any work on site. This documentation will be used to resolve any dispute over damage to infrastructure. It is in the applicant's interest for it to be as full and detailed as possible.

The damage deposit shall be refunded upon completion of all works upon receipt of a Final Occupation Certificate stage and inspection by Council.

(Reason: Protection of Council infrastructure.)

39. **STORMWATER - RAINWATER RE-USE (CC)**

A rainwater re-use system shall be provided in accordance with either the BASIX minimum requirements, any relevant Council Rainwater Policy and/or specification of the management of stormwater, whichever is applicable. A detailed stormwater plan showing the proposed re-use system shall be submitted to and approved by the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Compliance and amenity.)

40. **STORMWATER DRAINAGE (CC)**

The following stormwater precautions are required to be provided on the site:

- i) Grated drains shall be provided along the driveway/basement entry at the vehicular

- crossing(s) and are to connect to the internal drainage system.
- ii) Overflow paths shall be provided to allow for flows in excess of the capacity of the pipe/drainage system draining the site.
 - iii) Allowance shall be made for surface runoff from adjacent properties, and to retain existing surface flow path systems through the site. Any redirection or treatment of these flows shall not adversely affect any other properties
 - iv) Boundary fencing shall be erected in such a manner as not to interfere with the natural flow of ground and surface water to the detriment of any other party.

(Reason: To ensure the site is drained appropriately and does not interfere with the natural flow of flood waters.)

41. SWIMMING POOLS / SPAS (CONSTRUCTION OF)

The approved swimming pool/spa must comply with all relevant legislation including:

- i) Swimming Pools Amendment Act 1992 (as amended);
- ii) Swimming Pools Regulations 2008; and
- iii) Australian Standard AS1926.1-2012 – Safety Barriers for Swimming Pools.

Details demonstrating compliance with this condition shall be demonstrated to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Safety and statutory compliance.)

42. SWIMMING POOLS / SPAS - MECHANICAL PLANT ENCLOSURE (CC)

Any mechanical plant associated with the swimming pool and spa shall be acoustically treated to comply with the Protection of the Environment Operations Act 1997. Details are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: To ensure the acoustic amenity of the neighbouring residents.)

43. TRAFFIC - CONSTRUCTION TRAFFIC MANAGEMENT PLAN (CC)

A Construction Traffic Management Plan (CTMP) is to be prepared by an appropriately qualified Traffic Management Consultant and submitted to and approved by Council's Engineering Section, prior to the commencement of any works including demolition.

The following matters should be addressed in the CTMP (where applicable):

- i) description of the demolition, excavation and construction works;
- ii) site plan/s showing the site, roads, footpaths, site access points and vehicular movements;
- iii) size, type and estimated number of vehicular movements (including removal of excavated materials, delivery of materials and concrete to the site);
- iv) proposed route(s) from the arterial (state) road network to the site and the proposed route from the site back to the arterial road network;
- v) impacts of the work and vehicular movements on the road network, traffic and pedestrians and proposed methods to safely manage pedestrians and construction related vehicles in the frontage roadways;
- vi) any Traffic Control Plans (TCP's) proposed to regulate traffic and pedestrian movements for construction activities (such as concrete pours, crane installation/removal etc.);
- vii) proposed hours of construction related activities and vehicular movements to and

- from the site;
- viii) current/proposed approvals from other Agencies and Authorities (including Roads and Maritime Services, Police and State Transit Authority);
 - ix) any activities proposed to be located or impact upon Council's road, footways or any public place;
 - x) measures to maintain public safety and convenience;
 - xi) any proposed road and/or footpath closures;
 - xii) turning areas within the site for construction and spoil removal vehicles, allowing a forward egress for all construction vehicles on the site;
 - xiii) locations of work zones (where it is not possible for loading/unloading to occur on the site) in the frontage roadways accompanied by supporting documentation that such work zones have been approved by the Local Traffic Committee and Council;
 - xiv) location of any proposed crane and concrete pump and truck standing areas on and off the site (and relevant approvals from Council for plant on road);
 - xv) a dedicated unloading and loading point within the site for all construction vehicles, plant and deliveries;
 - xvi) material, plant and spoil bin storage areas within the site, where all materials are to be dropped off and collected;
 - xvii) on-site parking area for employees, tradespersons and construction vehicles as far as possible;
 - xviii) proposed areas within the site to be used for the storage of excavated material, construction materials and waste and recycling containers during the construction period; and
 - xix) how it is proposed to ensure that soil/excavated material is not transported onto surrounding footpaths and roadways.

(Reason: To mitigate traffic impacts on the surrounding area during the construction period.)

44. **TREE BONDS (CC)**

A tree bond of **\$19,800** (calculated in accordance with Council's adopted Fees and Charges) shall be paid to Council, prior to the issue of a Construction Certificate.

The deposit is required as security against any damage to existing trees to be retained on Council's road reserve, during works on the site. The applicant must bear the cost of all restoration works to Council's property damaged during the course of this development.

Payment may be accepted in the form of cash, bank guarantee, cheque or credit card (financial transactions fees apply). Note: Additional fees apply for the lodgement of a bank guarantee in lieu of cash bond applies in accordance with Council's adopted Fees and Charges.

A refund of the Tree Bond must be made in writing.

Tree Bonds may be forfeited if a tree is dead, made dangerous or has been terminally damaged, or will be held until tree/s have fully recovered from the construction damage or were replacement/planted trees have become fully established and are over 6 metres in height.

(Reason: To ensure the protection of trees to be retained on Council's Road Reserve.)

45. **WATER SUSTAINABILITY – GENERALLY (CC)**

Water collected in the rainwater tank must comprise roof water only and not surface water. Water from the rainwater tank must only be used for following purposes and not for human

consumption:

- i) toilet flushing;
- ii) clothes washing;
- iii) garden irrigation;
- iv) car washing and similar outdoor uses;
- v) filling swimming pools, spa pools and ornamental ponds; and
- vi) fire fighting.

(Reason: To promote sustainable water management practice.)

46. **WATER HEATING SYSTEMS - LOCATION OF (CC)**

Water heating systems shall be located so as not to be visible from public places and the ground level of adjoining properties. Details (type and location) of the water heaters shall be submitted to and approved by the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: To maintain streetscape character.)

CONDITIONS TO BE SATISFIED PRIOR TO THE COMMENCEMENT OF WORKS (CW)

47. **APPOINTMENT OF A PRINCIPAL CERTIFYING AUTHORITY (PCA) (CW)**

No work shall commence in connection with this Development Consent until:

- i) A construction certificate for the building work has been issued by the consent authority or a Principal Certifying Authority.
- ii) The person having the benefit of the development consent has appointed a principal certifying authority for the building work, and notified the principal certifying authority that the person will carry out the building work as an owner/builder, if that is the case.
- iii) The principal certifying authority has, no later than 2 days before the building work commences:
 - notified the Council of his or her appointment, and
 - notified the person having the benefit of the development consent of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- iv) The person having the benefit of the development consent, if not carrying out the work as an owner-builder, has:
 - appointed a principal contractor for the building work who must be the holder of a contractor licence if any residential building work is involved;
 - notified the principal certifying authority of such appointment; and
 - unless that person is the principal contractor, notified the principal contractor of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- v) The person having the benefit of the development consent has given at least 2 days' notice to the Council of the person's intention to commence the erection of the building.

Note: If the principal certifying authority is the Council, the nomination will be subject to the payment of a fee for the service to cover the cost of undertaking all necessary inspections and the issue of the appropriate certificates.

Under the Environment Planning and Assessment (Quality of Construction) Act, 2003, a sign must be erected in a prominent position on the work site showing the name, address and

telephone number of the principal certifying authority; the name of the principal contractor (if any) for the building work and a telephone number at which that person may be contacted outside working hours. That sign must also state that unauthorised entry is prohibited. The sign must not be removed until all work has been completed.

(Reason: Statutory requirement.)

48. **HOME BUILDING COMPENSATION FUND (CW)**

No residential building work within the meaning of the Home Building Act 1989 may commence until:

- i) A contract of insurance in accordance with Part 6 of the Home Building Act 1989 is entered into and in force, where such a contract is required under that Act (this is a prescribed condition of consent pursuant to clause 981(b) Environmental Planning and Assessment Regulation 2000.
- ii) The PCA is satisfied that the principal contractor for the work is the holder of the appropriate licence and is covered by the appropriate insurance, in each case if required by the Home Building Act 1989 (unless the work is to be carried out by an owner-builder).
- iii) If the work is to be carried out by an owner builder, that the owner builder is the holder of any owner -builder permit required under the Home Building Act 1989.
- iv) Written notice of the following information has been provided to Council (this is a prescribed condition of consent pursuant to clause 98B of the Environmental Planning and Assessment Regulation 2000):
 - In the case of work for which a principal contractor is required to be appointed:
 - the name and licence number of the principal contractor; and
 - the name of the insurer by which the work is insured under Part 6 of the Home Building Act 1989.
 - In the case of work to be done by an owner-builder:
 - the name of the owner-builder; and
 - if the owner-builder is required to hold an owner-builder permit under the Home Building Act 1989, the number of the owner-builder permits.

Where Council is not the PCA, the PCA is responsible for notifying Council of the above matters.

Note: Where arrangements for doing residential building work change while the work is in progress so that the above information becomes out of date, the PCA (where not the Council) must provide Council with written notice of the updated information.

(Reason: Statutory requirement.)

49. **NOTICE OF COMMENCEMENT (CW)**

No work shall commence until the following details are submitted to Council:

- i) a Notice of Commencement (form will be attached with issue of a Construction Certificate or available from our website) within two (2) days of the date on which it is proposed to commence works associated with the Development Consent;
- ii) details of the appointment of a Principal Certifying Authority (either Council or another Principal Certifying Authority); and
- iii) details of the name, address and licence details of the Builder.

(Reason: Statutory requirement.)

CONDITIONS TO BE SATISFIED DURING DEMOLITION AND BUILDING WORKS (DW)**50. FILL MATERIAL (DW)**

The only waste derived material which may be received at the development site is:

- i) Virgin excavated material (within the meaning of the Protection of the Environment Operations Act 1997), and
- ii) any other waste-derived material the subject of a resource recovery exemption under cl.51A of the Protection of the Environment Operations (Waste) Regulation 2005 that is permitted to be used as fill material.

Any (b)-type material received at the development site must be accompanied by documentation certifying by an appropriately qualified environmental consultant the materials compliance with the exemption conditions; and this documentation must be provided to the Principal Certifying Authority on request.

(Reason: To ensure imported fill is of an acceptable standard for environmental protection purposes.)

51. HERITAGE - HISTORIC RELICS FOUND DURING WORKS (DW)

Should any potentially historic relics be discovered on the site during excavation, all excavation or disturbance to the area is to stop immediately and the Heritage Division of the NSW Department of Environment and Heritage should be informed in accordance with Section 146 of the Heritage Act 1977. 'Relics' are any deposit, artefact, object or material evidence that relates to the settlement of the area that comprises New South Wales, not being Aboriginal settlement, and are of State or local heritage significance.

Should any potentially significant Aboriginal material be discovered on the site, all excavation or disturbance of the area is to stop immediately and the Heritage Division of the NSW Department of Environment and Heritage is to be informed in accordance with Section 91 of the National Parks and Wildlife Act 1974.

(Reason: To ensure the proper management and preservation of potentially significant archaeological material.)

52. OBSTRUCTION OF PUBLIC WAY NOT PERMITTED DURING WORKS (DW)

The public way must not be obstructed by any materials, vehicles, refuse, skips or the like, under any circumstances, without the prior approval of Council.

(Reason: To maintain public access and safety.)

53. PUBLIC INFRASTRUCTURE AND SERVICES (DW)

The applicant must comply with the requirements (including financial costs) of any relevant utility provider (e.g. Energy Australia, Sydney Water, Telstra, RMS, Council etc.) in relation to any connections, works, repairs, relocation, replacements and/or adjustments to public infrastructure or services affected by the development.

(Reason: To maintain public infrastructure and/or services.)

54. SURVEY REPORT OF APPROVED LEVELS DURING AND POST CONSTRUCTION (DW)

A Survey Certificate to Australian Height Datum shall be prepared by a Registered

Surveyor as follows:

- i) At the completion of the first structural floor level prior to the pouring of concrete indicating the level of that floor and the relationship of the building to the boundaries.
- ii) At the completed height of the building, prior to the placement of concrete inform work, or the laying of roofing materials.
- iii) At the completion of the development.

Progress certificates in response to points (1) through to (3) shall be provided to the Principal Certifying Authority at the time of carrying out relevant progress inspections. Under no circumstances is work allowed to proceed until such survey information is submitted to and approved by the Principal Certifying Authority.

(Reason: To ensure compliance with the approved plans.)

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF AN OCCUPATION CERTIFICATE (OC)

55. DRAINAGE SYSTEM - MAINTENANCE OF EXISTING SYSTEM (OC)

Where elements of the existing drainage system are to be utilised, the existing drainage system shall be overhauled and maintained clear of silt and accumulated debris. Silt and the like shall be removed, not flushed from the system.

A certificate shall be provided by a suitably qualified person (a registered plumber or a person of equivalent or greater experience or qualification) to the satisfaction of the Principal Certifying Authority, prior to the issue of any Occupation Certificate to confirm that the system is in good working order and adequate to accept additional flows having regard to any relevant standards and/or Sydney Water requirements.

(Reason: Maintenance and environment.)

56. ENGINEERING WORKS (CERTIFICATION OF)

Prior to occupation of the premises, a Work As Executed (WAE) Plan of all engineering and/or drainage works is to be submitted to the Principal Certifying Authority. The WAE Plan is to be certified by a suitably Qualified Engineer, with Corporate Membership standing in the Institution of Engineers Australia and registered on the National Professional Engineers Register (NPER) under the appropriate professional category, demonstrating that:

- i) the stormwater drainage system; and/or
- ii) the car parking arrangement and area; and/or
- iii) any related footpath crossing works; and/or
- iv) the proposed basement pump and well system; and/or
- v) the proposed driveway and layback; and/or
- vi) any other civil works

have been constructed in accordance with the approved plans and any relevant Standards and Council policies/specifications.

For major works, such as subdivisions, works within the road reserve (requiring separate S138 approval) and as where specified by Council, a Part 4A Certificate will be required. It is strongly recommended that an Engineer supervise all engineering related works.

Where Council is not the Principal Certifying Authority, an electronic copy of the above

documents is to be provided to Council, prior to the issue of any Occupation Certificate.

(Reason: Asset management.)

57. FUEL HEATERS - DOMESTIC SOLID (OC)

Prior to the issue of any Occupation Certificate the Principal Certifying Authority must be satisfied through the issue of appropriate certification that system as installed complies with the standard specified in the Environment Protection Authority's Environmental Guidelines for Selecting, Installing and Operating Domestic Solid Fuel Heaters; AS/NZS 2918: 2001 Domestic solid fuel burning appliances-Installation and the Building Code of Australia. Details demonstrating compliance with the requirements of this condition is to be submitted to the satisfaction of the Principal Certifying Authority prior to the issue of any interim / final occupation certificate.

(Reason: To mitigate harmful environmental impacts and maintain public safety.)

58. LANDSCAPING - ARBORIST'S FOLLOW UP REPORT OF TREE/S TO BE RETAINED (OC)

As part of the on-going assessment of the tree/s to be retained, the consulting arborist engaged by the applicant is to assess their health and any impacts suffered by them as a result of the proposed approved development, prior to the issue of an Occupation Certificate. Findings are to be compiled in a detailed report and submitted to the Principle Certifying Authority, which documents the following:

- i) methods of excavation or construction used to carry out the works;
- ii) any damage sustained by the tree/s as a result of the works;
- iii) any subsequent remedial works required to be carried out by the consulting arborist as a result of the damage; and
- iv) any future or on-going remedial work required to be carried out to ensure the long term retention of the tree/s.

(Reason: To ensure the survival of trees to be retained.)

59. OCCUPATION OF BUILDING (OC)

A person must not commence occupation or use (or change of use where an existing building) of the whole or any part of a new building (within the meaning of section 109H (4) of the Act) unless an Interim Occupation Certificate or Final Occupation Certificate has been issued in relation to the building or part.

The Principal Certifying Authority is required to be satisfied, amongst other things, that:

- i) all required inspections (including each applicable mandatory critical stage inspection) have been carried out; and
- ii) any preconditions to the issue of the certificate required by a development consent have been met.

Note: New building includes an altered portion of, or an extension to, an existing building.

(Reason: Statutory requirement.)

60. RAINWATER TANKS (OC)

Rainwater tanks must be installed on residential properties by a suitably qualified and

licensed plumber and in accordance with the following:

- i) Australian/New Zealand Standard AS/NZS 3500:2003;
- ii) NSW Code of Practice Plumbing and Drainage, 2006 produced by Committee on Uniformity of Plumbing and Drainage Regulations in NSW (CUPDR); and
- iii) Council's rainwater tank policy.

Details demonstrating compliance with this condition are to be submitted to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: To protect public health and amenity.)

61. STORMWATER - CERTIFICATION OF THE CONSTRUCTED DRAINAGE SYSTEM (OC)

The constructed stormwater system shall be certified by a suitably qualified person, in accordance with Council's Stormwater Management Code, prior to the issue of any Occupation Certificate.

(Reason: Adequate stormwater management.)

62. STORMWATER - COVENANT AND RESTRICTION AS TO USER FOR STORMWATER CONTROLLED SYSTEMS (OC)

Prior to the issue of any Occupation Certificate, the applicant shall register a Positive Covenant and a Restriction as to User under section 88E and or section 88B of the Conveyancing Act as appropriate in favour of Council, ensuring the ongoing retention, maintenance and operation of the stormwater facility (on-site detention, pump-out, charged lines, etc).

Where any drainage line or service conduit is to traverse any property other than that which it serves, an appropriate easement will be required. In this case, the applicant shall register an easement no less than 1200mm wide over the proposed drainage line or service concurrently with any subdivision registration.

The wording on the 88E and/or the 88B Instrument is to make reference to the Council file where the Construction plans and the Work As Executed (as built), plans are held. Typical wording can be obtained from Council's Specification for the Management of Stormwater document.

(Reason: To ensure the on-site detention and/or pump system is maintained to an appropriate operational standard.)

63. SUBDIVISION - EVIDENCE OF CONSOLIDATION (OC)

The existing allotments shall be consolidated into a single lot. Evidence that the plan of consolidation has been registered as a deposited plan with the Land and Property Information Office must be submitted to Council, prior to the issue of any occupation certificate for the development.

(Reason: Proper management of land.)

64. SWIMMING POOLS / SPAS - REGISTRATION AND REQUIREMENTS (OC)

The approved swimming pool/spa must comply with all relevant legislation including:

- i) Swimming Pools Amendment Act 1992 (as amended);

- ii) Swimming Pools Regulations 2008; and
- iii) Australian Standard AS1926.1-2012 – Safety Barriers for Swimming Pools.

Swimming pool owners must register their swimming pool or spa on the NSW Swimming Pool Register. A copy of a valid certificate of compliance or relevant occupation certificate must be attached to new residential tenancy agreements to rent property with a swimming pool or spa pool. Note: This requirement does not apply to a lot in strata or community title schemes with more than two lots.

A copy of a valid certificate of compliance or relevant occupation certificate must be attached to new residential tenancy agreements to rent property with a swimming pool or spa pool. Note: This requirement does not apply to a lot in strata or community title schemes with more than two lots; or for any off the plan contacts.

Details demonstrating compliance with this condition shall be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: Safety and statutory compliance.)

RESOLUTION

The Panel endorses the Council Officer's planning report and recommendation and has determined that the application be **APPROVED** subject to the conditions as contained in the report.

Panel Reasons:

The Panel had the benefit of a site inspection and the Council Officer's report that includes heritage assessment and notes no submission were received in respect of the notification. The Panel notes Condition 11 requires amendments to the landscape plan to provide additional planting on the rear boundary and a canopy tree in the rear garden. These conditions are important because of the interface with the heritage conservation area fronting Churchill Avenue and need to provide filtering of the new two storey pavilion that contains a glazed gable on this elevation.

The Panel is satisfied the proposed development with the refurbishment of the original dwelling and the construction of a new two storey component at the rear will sit comfortably in the streetscape and is consistent with the objectives of the Heritage Conservation Area.

FOR: J.Murrell, E.Armstrong, R. Jolliffe

AGAINST: Nil

Ian Stapleton declared a potential conflict of interest due to having to work with the applicant on other projects in relation to DA2018/111, 23 Redmyre Road, Strathfield. The chair determined that this could be perceived as a conflict of interest and he did not participate in the site inspection, public meeting or determination.

**** End Minutes - Report No. 1****

TO: Strathfield Local Planning Panel Meeting - 1 November 2018
REPORT: SLPP – Report No. 2
SUBJECT: DA2018/032-195 PARRAMATTA ROAD, HOMEBUST WEST
LOT 1 DP 34615
DA NO. DA2018/032

RECOMMENDATION

In consideration of the written request made by the applicant pursuant to Clause 4.6 of the Strathfield Local Environmental Plan 2012, the consent authority is satisfied that compliance with the development standard contained in Clause 4.3 (Height of Buildings) and Clause 4.4 (Floor Space Ratio) of the SLEP 2012 is well founded and that there are sufficient environmental planning grounds to justify contravening the development standard.

That Development Application No. DA2018/032 for demolition of existing carpark and construction of a five (5) storey hotel comprising ground floor facilities and 152 hotel suites over two (2) levels of basement car parking, subdivision of existing lot into two (2) lots and the creation of a stratum subdivision to enable car parking access for the Wentworth Hotel at 195 Parramatta Road, Homebush West be **APPROVED**, subject to the following conditions:

SPECIAL CONDITIONS (SC)

1. ENVIRONMENTAL SITE ASSESSMENT (SC)

The recommendations of the Preliminary Stage 1 Environmental Site Assessment dated 13/12/2017 as prepared by Environmental Investigation Services are to be implemented.

(Reason: Statutory requirement and health and safety)

2. FLOODING – COMPLY WITH FLOOD IMPACT REPORT (SC)

As the site is commercial in nature, the applicant must be made aware of the flood risk and should make his/her own assessment as to the flood risk they are willing to take. A minimum Flood Planning Level of 1% AEP is required, however based on the risk extent applicant can decide the level to which the floor level is to be raised above the required minimum level. Applicant shall not be allowed to place floor level below the minimum 1% AEP. Flood Impact Assessment Report prepared by a suitably qualified professional hydraulics/civil engineer shall be submitted to the Principal Certifying Authority for approval and a copy for Council's record prior to issue of a Construction Certificate.

(Reason: To mitigate flood risk and associated damage)

3. FLOODING AND OVERLAND FLOW (SC)

Allowance shall be made for surface runoff from adjacent properties, and to retain existing surface flow path systems through the site. Any redirection or treatment of these flows shall not adversely affect any other properties.

(Reason: To mitigate flood risk and associated damage)

4. COUNCIL'S DRAINAGE INFRASTRUCTURE (SC)

Driveway crossings, including aprons and laybacks shall be located a minimum of 1m clear of any stormwater pits, lintels or poles and 2m clear of the trunk of any trees within the road

reserve. An amended stormwater drainage concept plan shall be submitted to this effect prior to issue of a Construction Certificate.

(Reason: Compliance with Council's requirements.)

GENERAL CONDITIONS (GC)

5. APPROVED PLANS AND REFERENCE DOCUMENTATION (GC)

The development is to be carried out in accordance with the following plans and reference documentation as amended by the Deferred Commencement conditions, except where modified by the conditions of this consent.

Plans affixed with Council's 'Development Consent' stamp relating to Development Consent No. DA2018/032:

Drawing No.	Title/Description	Prepared by	Issue/Revision & Date	Date received by Council
DA-011	Site Plan	Squillace	Issue C dated 10 August 2018	31 August 2018
DA-012	Demolition Plan	Squillace	Issue B dated 8 March 2018	15 March 2018
DA-098	Basement 2	Squillace	Issue C dated 10 August 2018	31 August 2018
DA-099	Basement 1	Squillace	Issue C dated 10 August 2018	31 August 2018
DA-100	Ground Floor	Squillace	Issue C dated 10 August 2018	31 August 2018
DA-101	Level 1	Squillace	Issue C dated 10 August 2018	31 August 2018
DA-102	Level 2 & 3	Squillace	Issue C dated 10 August 2018	31 August 2018
DA-104	Level 4	Squillace	Issue C dated 10 August 2018	31 August 2018
DA-105	Roof Plan	Squillace	Issue C dated 10 August 2018	31 August 2018
DA-200	Elevations	Squillace	Issue C dated 10 August 2018	31 August 2018
DA-300	Sections	Squillace	Issue C dated 10 August 2018	31 August 2018
DA-301	Streetscapes	Squillace	Issue C dated 10 August 2018	31 August 2018
C1.01	Cover Sheet, Notes and Legends	Acor Consultants	Issue B dated 15 December 2017	15 March 2018
C1.05	Details - Sheet 1	Acor Consultants	Issue B dated 15 December 2017	15 March 2018
C1.06	Details - Sheet 2	Acor Consultants	Issue B dated 15 December 2017	15 March 2018
C1.07	Details - Sheet 3	Acor Consultants	Issue B dated 15 December 2017	15 March 2018
C2.01	Stormwater	Acor	Issue B dated	15 March 2018

	Management Plan – Ground Level	Consultants	15 December 2017	
C2.02	Stormwater Management Plan – Level 1	Acor Consultants	Issue A dated 15 December 2017	15 March 2018
C3.01	Soil Erosion and Sediment Control Plan	Acor Consultants	Issue B dated 15 December 2017	15 March 2018
1 of 5	Plan of Subdivision of Lot 1 DP 34615	LTS Lockley	27 February 2018	15 March 2018
2 of 5	Plan of Subdivision of Lot 1 DP 34615	LTS Lockley	27 February 2018	15 March 2018
3 of 5	Plan of Subdivision of Lot 1 DP 34615	LTS Lockley	27 February 2018	15 March 2018
4 of 5	Plan of Subdivision of Lot 1 DP 34615	LTS Lockley	27 February 2018	15 March 2018
5 of 5	Plan of Subdivision of Lot 1 DP 34615	LTS Lockley	27 February 2018	15 March 2018

Reference Documentation affixed with Council's 'Development Consent' stamp relating to Development Consent No. DA2018/032:

Title/Description	Prepared by	Issue/Revision & Date	Date received by Council
Plan of Management	Mecone	Revision B dated 24 August 2018	31 August 2018
Geotechnical Investigation	JK Geotechnics	8 December 2017	15 March 2018
Construction Impact Assessment & Management Plan	Botanics Tree Wise People	November 2017	15 March 2018

In the event of any inconsistency, the conditions of this consent shall prevail.

(Reason: To ensure that the form of the development undertaken is in accordance with the determination of Council.)

6. **BUILDING HEIGHT - MAXIMUM RL TO BE COMPLIED WITH (GC)**

The height of the building measured from Australian Height Datum (AHD) must not exceed Reduced Level (RL) 27.70 AHD to the top of the lift overrun on the roof of the building.

(Reason: To ensure the approved building height is complied with.)

7. **CONSTRUCTION HOURS (GC)**

No construction or any other work related activities shall be carried out on the site outside the hours of 7.00 am to 5.00 pm Mondays to Fridays and 8am to 1pm Saturdays.

No building activities are to be carried out at any time on a Sunday or public holiday.

Where the development involves the use of jackhammers/rock breakers and the like or other heavy machinery, such equipment may only be used between the hours of 7.00 am - 5.00 pm Monday to Friday only.

(Reason: To maintain amenity to adjoining land owners.)

8. CONSTRUCTION WITHIN BOUNDARIES (GC)

The development including but not limited to footings, walls, roofing and guttering must be constructed wholly within the boundary of the premises. No portion of the proposed building shall encroach onto the adjoining properties. Gates must be installed so they do not open onto any footpath or adjoining land.

(Reason: Approved works are to be contained wholly within the subject site.)

9. DEMOLITION – GENERALLY (GC)

Alteration and demolition of the existing structures is limited to that documented on the approved plans (by way of notation). No approval is given or implied for removal and/or rebuilding of any portion of existing structures which are not shown to be altered or demolished.

(Reason: To ensure compliance with the approved development.)

10. DEMOLITION - SITE SAFETY FENCING (GC)

Site fencing is to be erected to a minimum height of 1.8m complying with WorkCover Guidelines, to exclude public access to the site, prior to any demolition works occurring and maintained for the duration of the demolition works.

If applicable, a separate Hoarding Application for the erection of an A class (fence type) or B class (overhead type) hoarding/fencing along the street frontage(s) complying with WorkCover requirements must be obtained including:

- payment to Council of a footpath occupancy fee based on the area of footpath to be occupied and Council's Schedule of Fees and Charges before the commencement of work; and
- provision of a Public Risk Insurance Policy with a minimum cover of \$10 million in relation to the occupation of and works within Council's road reserve, for the full duration of the proposed works, must be obtained with a copy provided to Council.

(Reasons: Statutory requirement and health and safety.)

11. TREE RETENTION & PROTECTION (GC)

The trees listed below shall be retained at all times.

Tree No. in Arborist Report	Height/Spread (m)	Location	Protection Zone (m)	Structural Root Zone (m)
1 - Agonis flexuosa	8x5	Road Reserve	8.6	3.0
2 - Cinnamomum camphora	16x18	Subject Site	10.8	3.0

3 - Cinnamomum camphora	18x18	Subject Site	11.4	3.0
4 – Melaleuca quinquenervia	9x4	Subject Site	3.6	3.0
5 – Melaleuca quinquenervia	11x5	Subject Site		
6 - Melaleuca quinquenervia	11x6	Subject Site		
7 - Melaleuca quinquenervia	9x5	Subject Site		
10 - Agonis flexuosa	9x6	Road Reserve	12.0	3.0
18-22 Casuarina glauca	10x4	Subject Site	3.6	3.0

These trees shall be protected by the establishment of a protection zone (in accordance with Australian Standard AS4970-Protection of trees on development sites) before any site works begin (including any demolition/excavation). The protection zone shall be maintained for the duration of works and implemented as follows:

- a) A minimum 1.8m high barrier (Chain wire mesh panels, plywood or wooden paling fence panels: refer to AS4687-Temporary fencing and hoardings for fencing requirements) shall be erected around the perimeter of the stated Protection Zone as measured from the base of the tree (or where practical). Shade cloth or similar should be attached to reduce the transport of dust, other particulate matter and liquids into the protected area. Fence posts and supports should have a diameter greater than 20mm and be located clear of roots. The barrier shall be constructed so as to prevent pedestrian and vehicular entry into the protection zone. The barrier shall not project beyond the kerb onto the roadway or any adjacent footpath.
- b) Signs identifying the Protection Zone should be installed on the fencing and be visible from within the development site. Lettering should comply with AS4970-2009: Protection of Trees on Development Sites.
- c) No concrete slurry or wash, building materials, builders' rubble, excavation soil or similar shall be placed or stored within the tree protection zone.
- d) The whole of the tree protection zone shall be mulched to a minimum depth of 75mm.
- e) The tree protection zone shall be regularly watered.
- f) Any major structural roots which are encountered shall be pruned by a qualified Arborist.
- g) No excavation or construction shall be carried out within the stated Structural Root Zone distances from the base of the trunk surface.
- h) Only permeable surfaces (e.g. decomposed granite, gravel, turfpave, permeable paving systems or soft landscaping) are permitted within the canopy spread of the trees to be protected.

(Reason: To ensure the protection of trees to be retained on the site.)

12. TREE REMOVAL (GC)

The following listed trees are permitted to be removed to accommodate the proposed development. However, any of the trees listed below that are located on adjoining properties must only be removed after consent from the tree's owner has been sought and obtained in writing.

Tree No. in Arborist Report	Height/Spread (m)	Location
8 – Lophostemon confertus	8x4	Subject Site
9 - Lophostemon confertus	9x4	Subject Site
11-17 Various	8x5	Subject Site

(Reason: To ensure a reasonable balance of tree retention/removal to allow development.)

13. TREE & LANDSCAPING REQUIREMENTS (GC)

- a) A minimum 600mm deep root deflection barrier shall be provided on both sides of the proposed driveway crossings and footpaths.
- b) All noxious weeds on the site shall be removed and destroyed as per their classification under the Noxious Weeds Act 1993.
- c) All trees permitted to be removed by this consent shall be replaced by species selected from Council's recommended planting list. Replacements shall be a minimum 50 litre container size and shall be maintained until maturity.
- d) General maintenance of Council's nature strip adjoining the development site, including regular lawn mowing, edging, irrigation of the lawn and street trees and restricting the storage of materials, rubbish and parking or driving of vehicles on the nature strip, must be carried out during the full period of all approved works (including any demolition and excavation).
- e) Manual excavation is required within the TPZ of the retained trees.
- f) The landscaped areas including all planters are to have full coverage by a fully automatic irrigation system. The design, materials and installation are to be in accordance with Sydney Water Codes and all relevant Australian Standards.
- g) All plants specified are to be native Australian plant species.

(Reason: To ensure the protection of trees and enhance landscaping.)

14. LIGHTING (GC)

Any lighting of the premises shall be installed and maintained in accordance with Australian Standard AS 4282-1997: Control of the Obtrusive Effects of Outdoor Lighting so as to avoid annoyance to the occupants of adjoining premises or glare to motorists on nearby roads.

No flashing, moving or intermittent lighting, visible from any public place may be installed on the premises or external signage associated with the development, without the prior approval of Council.

(Reason: To protect the amenity of surrounding development and protect public safety.)

15. MATERIALS – CONSISTENT WITH SUBMITTED SCHEDULE (GC)

All external materials, finishes and colours are to be consistent with the schedule submitted and approved by Council with the development application.

(Reason: To ensure compliance with this consent.)

16. PRINCIPAL CERTIFYING AUTHORITY (PCA) IDENTIFICATION SIGN (GC)

Prior to commencement of any work, signage must be erected in a prominent position on the work site identifying:

- i) the Principal Certifying Authority (PCA) by showing the name, address and telephone number of the PCA;
- ii) the Principal Contractor by showing the Principal Contractor's name, address and telephone number (outside of work hours) for that person; and
- iii) the sign must state that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the work is being carried out, but must be removed when the work has been completed.

This clause does not apply to building work, subdivision work or demolition work that is carried out inside an existing building that does not affect the external walls of the building.

(Reason: Statutory requirement.)

17. SITE MANAGEMENT (DURING DEMOLITION AND CONSTRUCTION WORKS)

All of the following are to be satisfied/complied with during demolition, construction and any other site works:

- i) All demolition is to be carried out in accordance with Australian Standard AS 2601-2001.
- ii) Demolition must be carried out by a registered demolition contractor.
- iii) A single entrance is permitted to service the site for demolition and construction. Protection pads are to be installed to the kerb, gutter and nature strip where trucks and vehicles enter the site.
- iv) No blasting is to be carried out at any time during construction of the building.
- v) Care must be taken during demolition/ excavation/ building/ construction to prevent any damage to adjoining buildings.
- vi) Adjoining owner property rights and the need for owner's permission must be observed at all times, including the entering onto land for the purpose of undertaking works.
- vii) Any demolition and excess construction materials are to be recycled wherever practicable.
- viii) The disposal of construction and demolition waste must be in accordance with the requirements of the Protection of the Environment Operations Act 1997.
- ix) All waste on the site is to be stored, handled and disposed of in such a manner as to not create air pollution (including odour), offensive noise or pollution of land and/or water as defined by the Protection of the Environment Operations Act 1997. All excavated material should be removed from the site in an approved manner and be disposed of lawfully to a tip or other authorised disposal area.
- x) All waste must be contained entirely within the site.
- xi) A site plan including temporary waste storage locations, construction material storage areas and vehicular access to and from the site must be included with application.
- xii) Section 143 of the Protection of the Environment Operations Act 1997 requires waste to be transported to a place which can lawfully accept it. All non-recyclable demolition materials are to be disposed of at an approved waste disposal depot in accordance with legislation.
- xiii) Details as to the method and location of disposal of demolition materials (weight dockets, receipts, etc.) should be kept on site as evidence of approved methods of

- disposal or recycling and must be presented to Council and/or Principal Certifying Authority upon request.
- xiv) All materials on site or being delivered to the site are to generally be contained within the site. The requirements of the Protection of the Environment Operations Act 1997 must be complied with when placing/stockpiling loose material, disposing of concrete waste, or other activities likely to pollute drains or water courses.
 - xv) Any materials stored on site must be stored out of view or in such a manner so as not to cause unsightliness when viewed from nearby lands or roadways.
 - xvi) Public footways, include nature strips and roadways adjacent to the site must be maintained and cleared of obstructions during construction. No building materials, waste containers or skips may be stored on the road reserve or footpath without prior separate approval from Council, including payment of relevant fees.
 - xvii) Building operations such as brick-cutting, washing tools or paint brushes, and mixing mortar not be performed on the roadway or public footway or any other locations which could lead to the discharge of materials into the stormwater drainage system.
 - xviii) All site waters during excavation and construction must be contained on site in an approved manner to avoid pollutants entering into waterways or Council's stormwater drainage system.
 - xix) Any work must not prohibit or divert any natural overland flow of water.
 - xx) Toilet facilities for employees must be provided in accordance with WorkCover NSW.

(Reason: To ensure that demolition, building and any other site works are undertaken in accordance with relevant legislation and policy and in a manner which will be non-disruptive to the local area.)

18. **WASTE – TRACKABLE (GC)**

Removal of trackable waste (as defined by the NSW Environment Protection Authority) from the site must comply with the Protection of the Environment Operations (Waste) Regulation 2005 for the transportation, treatment and disposal of waste materials. Waste materials must not be disposed on land without permission of the land owner and must with the provisions of the Protection of the Environment and Operations Act 1997.

(Reason: To ensure compliance with legislation.)

19. **CLASSIFICATION OF WASTE (GC)**

Prior to the exportation of waste (including fill or soil) from the site, the waste materials must be tested and classified in accordance with the provisions of the protection of the environment operations act 1997 and the NSW EPA waste classification guidelines, part 1: classification of waste (November 2014). Testing is required prior to off-site disposal. In accordance with DECC waste classification guidelines (2014) materials identified for off-site disposal must be removed by a suitably qualified contractor to an appropriately licensed waste facility.

Note: attention is drawn to part 4 of the NSW DECC waste classification guidelines (2014) which makes particular reference to the management and disposal of acid & potential acid sulfate soils. The classification of the material is essential to determine where the waste may be legally taken. The protection of the environment operations act 1997 provides for the commission of an offence for both the waste owner and the transporters if the waste is taken to a place that cannot lawfully be used as a waste facility for the particular class of waste. For the transport and disposal of industrial, hazardous or group a liquid waste advice should be sought from the EPA.

Evidence that the requirements specified above have been satisfied must be provided to

the Council and/or Principal Certifying Authority prior to the issue of an occupation certificate. Where an occupation certificate is not required this evidence must be provided to the satisfaction of Council.

(Reason: To ensure compliance with legislation.)

20. **STORMWATER MANAGEMENT PLAN - CERTIFICATION REQUIREMENT (GC)**

A detailed Stormwater Management Plan (SWMP) in line with Council's Stormwater Management Code is to be prepared and certified by a practicing Chartered Professional Engineer on the National Professional Engineer's Register (NPER) at Engineers Australia and submitted to the Principal Certifying Authority and Council, prior to the issue of a Construction Certificate. The SWMP is to be based on the approved development as modified by any conditions of consent.

(Reason: To ensure appropriate provision is made for the disposal and management of stormwater generated by the development, and to ensure public infrastructure in Council's care and control is not overloaded.)

21. **SYDNEY WATER - STAMPED PLANS PRIOR TO COMMENCEMENT (GC)**

The approved plans must be submitted to a Sydney Water Quick Check agent or Customer Centre to determine whether the development will affect Sydney Water's sewer and water mains, stormwater drains and/or easements, and if further requirements need to be met. Plans will be appropriately stamped.

For Quick Check agent details please refer to the web site www.sydneywater.com.au (see Building Developing and Plumbing then Quick Check) or telephone 13 20 92. The consent authority or a Certifying Authority must ensure that a Quick Check agent/Sydney Water has stamped the plans before the commencement of work.

(Reason: Compliance with Sydney Water requirements.)

22. **SIGNAGE (GC)**

No signage is approved as part of this development consent. A separate development application for any proposed signs which are externally fitted or applied must be submitted for the approval of Council, prior to the erection or display of any such signs. This does not apply to signs which are classified as being "Exempt Development".

(Reason: To protect the amenity of the streetscape.)

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF A CONSTRUCTION CERTIFICATE (CC)

23. **TRAFFIC & PARKING ASSESMENT**

An updated traffic and parking study that reflects the latest revised plans and operational aspects of the development and which demonstrates that the proposed off-street car parking provision is adequate based on the cumulative car parking demands of the existing hotel and new hotel building is to be submitted to council's satisfaction prior to issue of any Construction Certificate for the development.

24. **DELETED**

25. **DELETED**

26. DELETED**27. ACCESS - ACCESS FOR PEOPLE WITH DISABILITIES (CC)**

Access for people with disabilities must be provided in accordance with the requirements of the Building Code of Australia, relevant Australian Standards and with regard to the Disability Discrimination Act 1992. Plans shall be notated demonstrating compliance and approved by the Principal Certifying Authority, prior to the issue of a Construction Certificate.

Note: Disability (Access to Premises - Buildings) Standards 2010 - As of 1 May 2011, if access is provided to the extent covered by this Standard, then such access cannot be viewed as unlawful under the Disability Discrimination Act 1992.

(Reason: To provide equitable access for people(s) with disabilities in accordance with the relevant legislation and Australian Standards.)

28. ACCESS - DISABLED TOILETS (CC)

Plans and details of the disabled toilets complying with the relevant Australian Standards, the Building Code of Australia, and with regard to the Disability Discrimination Act 1992. Plans shall be notated demonstrating compliance and approved by the Principal Certifying Authority, prior to the issue of a Construction Certificate.

Note: Disability (Access to Premises - Buildings) Standards 2010 - As of 1 May 2011, if access is provided to the extent covered by this Standard, then such access cannot be viewed as unlawful under the Disability Discrimination Act 1992.

(Reason: To provide equitable access for people(s) with disabilities in accordance with the relevant legislation and Australian Standards.)

29. BUILDING CODE OF AUSTRALIA - COMPLIANCE WITH (CC)

All architectural drawings, specifications and related documentation shall comply with the Building Code of Australia (BCA). All work must be carried out in accordance with the requirements of the Building Code of Australia (BCA).

In the case of residential building work for which the Home Building Act 1989 requires there to be a contract of insurance in force in accordance with Part 6 of that Act, such a contract of insurance is to be in force before any building work authorised to be carried out by the consent commences.

Details demonstrating compliance with this condition are to be submitted to the Principle Certifying Authority, prior to issue of the Construction Certificate.

(Reason: This is a 'prescribed' condition under clause 98(1) of the Environmental Planning and Assessment Regulation 2000.)

30. CAR PARKING - BASEMENT CAR PARKING REQUIREMENTS (CC)

Details demonstrating compliance with the following is to be submitted to the Principal Certifying Authority, prior to issue of the Construction Certificate:

- i) Minimal internal clearance of the basement is 2.2m in accordance with BCA requirements.

- ii) Driveways shall comply with Australian/New Zealand Standard AS/NZS 2890.1:2004 - Parking facilities - Off-street car parking and achieve a maximum gradient of 1:4.
- iii) Basement entries and ramps/driveways within the property are to be no more than 3.5m wide.
- iv) Provision of pump-out systems and stormwater prevention shall be in accordance with Council's Stormwater Management Guide.

(Reason: To ensure suitable development.)

31. **DELETED**

32. **DELETED**

33. **CAR PARKING - VEHICULAR ACCESS RAMPS (CC)**

Vehicular access ramps shall comply with the provisions of AS/NZS 2890.1:2004. Plans to be submitted shall contain the following details:

- i) Longitudinal section along the extreme wheel paths of each driveway/access ramp at a scale of 1:25 demonstrating compliance with the scraping provisions of AS/NZS 2890.1:2004. It shall include all levels and grades, including those levels stipulated as boundary levels, both existing and proposed. It shall extend from the centre-line of the roadway through to the parking area.
- ii) Sections showing the clearance to the underside of any overhead structure (minimum headroom requirements 2200mm minimum for standard headroom clearance or 2400mm where disabled access provisions are to be provided) demonstrating compliance with the provisions of AS/NZS 2890.1:2004.
- iii) Longitudinal section along the gutter line showing how it is intended to transition the vehicular crossing into the existing kerb and gutter. Boundary levels shall generally run parallel with the kerb levels.
- iv) Location of verge trees, street furniture and service installations.
- v) Superimposition of vehicle turning circles for access into parking spaces.
- vi) Certification that the design complies with AS/NZS 2890.1:2004 by a Qualified Engineer.

The certification referred to in (vi) above shall be submitted to **and approved by Council** prior to the issue of a Construction Certificate (for the design) and to the Principal Certifying Authority prior to the issue of any Occupation Certificate for the 'as-built works'.

(Reason: To ensure adequate vehicular access can be achieved.)

34. **DELETED**

35. **DELETED**

36. **COMMENCEMENT OF WORKS (NO WORKS UNTIL A CC IS OBTAINED)**

Building work, demolition or excavation must not be carried out until a Construction Certificate has been issued by either Strathfield Council or a Principal Certifying Authority.

Demolition of any part of a building triggers 'commencement of erection of building' pursuant of section 4.19 of the EP&A Act 1979. Accordingly, demolition works must not commence until a Construction Certificate has been issued, a Principal Certifying Authority has been appointed and a Notice of Commencement has been issued.

(Reason: To ensure compliance with statutory provisions.)

37. CONSTRUCTION AND ENVIRONMENTAL MANAGEMENT PLAN (CC)

The applicant must prepare and submit a Construction and Environmental Management Plan (CEMP) to the Principal Certifying Authority, including:

- i) Detailed information on any approvals required from other authorities prior to or during construction.
- ii) Traffic management, including details of:
 - ingress and egress of vehicles to the site;
 - management of loading and unloading of materials;
 - the location of heavy vehicle parking off-site; and
 - designated routes for vehicles to the site.
- iii) The proposed areas within the site to be used for a builder's site office and amenities, the storage of excavated material, construction materials and waste containers during the construction period.
- iv) Erosion and sediment control, detailing measures and procedures consistent with the requirements of Council's guidelines for managing stormwater, including:
 - the collection and treatment of stormwater and wastewater generated on site prior to discharge; and
 - procedures to prevent run-off of solid material and waste from the site.
- v) Waste management, including:
 - details of the types and estimated volumes of waste materials that will be generated;
 - procedures for maximising reuse and recycling of construction materials; and
 - details of the off-site disposal or recycling facilities for construction waste.
- vi) Dust control, outlining measures to minimise the generation and off-site transmission of dust and fine particles, such as watering or damp cloth fences.
- vii) A soil and water management plan, which includes:
 - measures to minimise the area of soils exposed at any one time and conserve top soil;
 - identification and protection of proposed stockpile locations;
 - preservation of existing vegetation and revegetation;
 - measures to prevent soil, sand, sediments leaving the site in an uncontrolled manner;
 - measures to control surface water flows through the site in a manner that diverts clean run-off around disturbed areas, minimises slope gradient and flow distance within disturbed areas, ensures surface run-off occurs at non-erodible velocities, and ensures disturbed areas are promptly rehabilitated;
 - details of sediment and erosion control measures in place before work commences;
 - measures to ensure materials are not tracked onto the road by vehicles entering or leaving the site; and
 - details of drainage to protect and drain the site during works.
- viii) Asbestos management procedures:
 - Anyone who removes, repairs or disturbs bonded or a friable asbestos material must hold a current removal licence from Workcover NSW holding either a Friable (Class A) or a Non- Friable (Class B) Asbestos Removal License which ever applies and a current WorkCover Demolition License where works involve demolition. To find a licensed asbestos removalist please see www.workcover.nsw.gov.au
 - Removal of asbestos by a person who does not hold a Class A or Class B asbestos removal license is permitted if the asbestos being removed is 10m² or less of non-friable asbestos (approximately the size of a small bathroom). Friable asbestos materials must only be removed by a person who holds a

- current Class A asbestos license.
- Before starting work, a work site-specific permit approving each asbestos project must be obtained from WorkCover NSW. A permit will not be granted without a current WorkCover licence. All removal, repair or disturbance of or to asbestos material must comply with the following:
 - The Work Health and Safety Act 2011;
 - The Work Health and Safety Regulation 2011;
 - How to Safely Remove Asbestos Code of Practice – WorkCover 2011; and
 - Safe Work Australia Code of Practice for the Management and Control of Asbestos in the Workplace.
 - Following completion of asbestos removal works undertaken by a licensed asbestos removalist re-occupation of a workplace must not occur until an independent and suitably licensed asbestos removalist undertakes a clearance inspection and issues a clearance certificate.
 - The developer or demolition contractor must notify adjoining residents at least two (2) working days (i.e. Monday to Friday exclusive of public holidays) prior to the commencement of asbestos removal works. Notification is to include, at a minimum:
 - the date and time when asbestos removal works will commence;
 - the name, address and business hours contact telephone number of the demolisher, contractor and/or developer;
 - the full name and license number of the asbestos removalist/s; and
 - the telephone number of WorkCover's Hotline 13 10 50
 - warning signs informing all people nearby that asbestos removal work is taking place in the area. Signs should be placed at all of the main entry points to the asbestos removal work area where asbestos is present. These signs should be weatherproof, constructed of light-weight material and adequately secured so they remain in prominent locations. The signs should be in accordance with AS 1319-1994 Safety signs for the occupational environment for size, illumination, location and maintenance; and
 - appropriate barricades installed as appropriate to prevent public access and prevent the escape of asbestos fibres. Barricades must be installed prior to the commencement of asbestos removal works and remain in place until works are completed.

(Reason: Safety, amenity and protection of public infrastructure and the environment.)

38. **COUNCIL PERMITS – FOR ALL ACTIVITIES ON COUNCIL LAND (CC)**

Works Permit

(as per Section 68 of the Local Government Act 1993 and Section 138 and 139 of the Roads Act 1993)

A Works Permit is required for construction of a vehicular crossing (driveway), new stormwater down pipe connection to kerb and gutter, new footpath and/or stormwater connection. A Works Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Standing Plant Permit

This permit must be applied for where it is intended to park a concrete pump, crane or other plant on the roadway or footpath. A Standing Plant Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Skip Bin Permit

This permit must be applied for if you intend to place a skip bin on the roadway or footpath. A Skip Bin Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Temporary Full or Part Road Closure Permit

This permit must be applied for if you require a full or a part road closure to take place to assist in your construction works. Please use the Works Permit Application Form, which is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Hoarding/Fencing Permit

This permit must be applied for if you intend to erect a Class A (fence type) or Class B (overhead type) hoarding/fencing along the street frontage(s). A Hoarding Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Work Zone Permit

This permit must be applied for if you require permanent parking along the kerbside at the front of the site during construction works. A Work Zone Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Ground Anchoring Permit

This permit must be applied for, for the installation of ground anchors under Council's footway/road reserve. It does not cover ground anchors under private properties. A separate approval is required to be obtained from Roads and Maritime Services (RMS) if it is proposed to install ground anchors under a State or Classified Regional Road (please refer to the end of this application form for more information).

(Reason: Council requirement.)

39. DILAPIDATION REPORT - PRE-COMMENCEMENT (CC)

Subject to access being granted, a pre-commencement Dilapidation Report is to be undertaken on all adjoining properties, which in the opinion of a suitably qualified engineer, could be potentially affected by the construction of the project. The Dilapidation Report shall be carried out prior to the issue of a Construction Certificate.

The Dilapidation Report is to be prepared by a suitably Qualified Engineer with current Corporate Membership with the Institution of Engineers, Australia or Geotechnical Practitioner. The report shall include a photographic survey of adjoining properties detailing the physical condition of those properties, both internally and externally, including walls, ceilings, roof, structural members and other such items.

If access for undertaking the dilapidation survey is denied by an adjoining owner, the applicant must demonstrate, in writing, to Council's satisfaction attempts have been made to obtain access and/or advise the affected property owner of the reason for the survey and these attempts have been unsuccessful. Written concurrence must be obtained from Council in such circumstances.

The Report shall cover structural and geotechnical factors likely to arise from the

development. A copy of this Report shall be submitted to Council as a record. The person having the benefit of the development consent must, at their own cost, rectify any damage caused to other properties during the construction of the project.

(Reason: To ensure no damage to adjoining properties occurs.)

40. DRIVEWAY DESIGN - SPEED HUMP AND STOP SIGN ON EXIT (CC)

The applicant shall install a stop sign and a speed hump at the exit from the site. The stop sign must be accompanied by the associated line marking and the speed hump shall be set back by 1.5 metres from the boundary alignment. The devices shall be designed and constructed in accordance with the provision of all relevant Australian Standards. The building plans shall indicate compliance with this requirement, prior to the issue of a Construction Certificate.

(Reason: Traffic safety and management.)

41. EROSION AND SEDIMENTATION CONTROL PLAN (CC)

An Erosion and Sediment Control Plan is to be prepared where construction or excavation activity requires the disturbance of the soil surface and existing vegetation. Details including drawings and specifications must provide adequate measures for erosion and sediment control to ensure:

- i) Compliance with the approved Soil and Water Management Plan.
- ii) Removal or disturbance of vegetation and top soil is confined to within 3m of the approved building area (no trees to be removed without approval).
- iii) All uncontaminated run-off is diverted around cleared or disturbed areas.
- iv) Silt fences or other devices are installed to prevent sediment and other debris escaping from the cleared or disturbed areas into drainage systems or waterways.
- v) All erosion and sediment controls are fully maintained for the duration of demolition/development works.
- vi) Controls are put into place to prevent tracking of sediment by vehicles onto adjoining roadways.
- vii) All disturbed areas are rendered erosion-resistant by turfing, mulching, paving or similar.
- viii) All water pumped or otherwise removed from excavations or basement areas is filtered to achieve suspended solids/non filterable residue levels complying with the Australian Water Quality guidelines for Fresh and Marine Waters.
- ix) Pumped or overland flows of water are discharged so as not to cause, permit or allow erosion before the commencement of work (and until issue of the occupation certificate).

Details of the proposed soil erosion and sedimentation controls are to be submitted to the Principal Certifying Authority with the Construction Certificate Application. Under no circumstances are any works to commence, prior to these details being approved by the Principal Certifying Authority and the controls being in place on the site.

(Reason: Environmental protection.)

42. EXCAVATION - AFFECTING ADJOINING LAND (CC)

If an excavation associated with the approved development extends below the level of the base of the footings of a building on an adjoining allotment of land, the person having the benefit of the development consent must, at the person's own expense, comply with the

requirements of clause 98E of the Environmental Planning and Assessment Regulation 2000, including:

- i) protect and support the adjoining premises from possible damage from the excavation, and
- ii) where necessary, underpin the adjoining premises to prevent any such damage.

The condition referred to in subclause (i) does not apply if the person having the benefit of the development consent owns the adjoining land or the owner of the adjoining land has given consent in writing to that condition not applying. Details shall be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Structural safety.)

43. **EXCAVATION – DEWATERING (CC)**

Any de-watering from the excavation or construction site must comply with the Protection of the Environment Operations Act 1997 and the following:

- i) Ground water or other water to be pumped from the site into Council's stormwater system must be sampled and analysed by a NATA accredited laboratory or Council for compliance with ANZECC Water Quality Guidelines.
- ii) If tested by NATA accredited laboratory, the certificate of analysis issued by the laboratory must be forwarded to Council as the appropriate regulatory authority under the Protection of the Environment Operations Act 1997, prior to the commencement of de-watering activities.
- iii) Council will grant approval to commence site de-watering to the stormwater based on the water quality results received.
- iv) It is the responsibility of the applicant to ensure during de-watering activities, the capacity of the stormwater system is not exceeded, there are no issues associated with erosion or scouring due to the volume of water pumped; and turbidity readings must not at any time exceed the ANZECC recommended 50ppm (parts per million) for receiving waters.

(Reason: To ensure compliance with legislation and to protect the surrounding natural environment.)

44. **EXCAVATION – SHORING (CC)**

Where any shoring for excavation is to be located on or is supporting Council's property, or any adjoining private property, engineering drawings and specifications certifying the shoring will be adequate for their intended purpose and must be submitted to the Council/Principal Certifying Authority for approval with the Construction Certificate. The documentation prepared and certified by an appropriately qualified and practicing structural engineer is to show all details, including the extent of encroachment and the method of removal and de-stressing of shoring elements. A copy of this documentation must be provided to the Council for record purposes at the time of Construction Certificate application.

(Reason: To ensure the protection of existing public infrastructure and adjoining properties.)

45. **NOISE – VIBRATION (CC)**

The construction of the development and preparation of the site, including operation of vehicles, must be conducted so as to avoid unreasonable noise or vibration and cause no interference to adjoining or nearby occupations. Special precautions must be taken to avoid

nuisance in neighbouring residential areas, particularly from machinery, vehicles, warning sirens, public address systems and the like.

(Reason: Noise attenuation.)

46. **NOISE – PLANT (CC)**

All works carried out on site during construction/demolition/excavation or earthworks shall comply with the NSW Protection of the Environment Operations Act 1997. Approved and effective silencing measures shall be provided and maintained on all power-operated plant used on site if required.

(Reason: Safety and amenity.)

47. **NOISE – CONSTRUCTION CC)**

All works carried out on site during construction/demolition/excavation/earthworks shall comply with the NSW Protection of the Environment Operations Act 1997, the Department of Environment and Climate Changes “Interim construction noise guideline” and AS 2436-2010 – “Guide to noise and vibration control on construction, demolition and maintenance sites” for the control of construction noise which specifies that:

- Construction period of 4 weeks and under – The L90 Level measured over a period of not less than 15 minutes when the construction site is operating must not exceed the background level by more than 20 dB(A) at the boundary.
- Construction period greater than 4 weeks but not exceeding 26 weeks – The L90 level measured over a period of not less than 15 minutes when the construction site is operating must not exceed the background level by more than 10 dB(A) at the boundary.
- Construction period exceeding 26 weeks – The L90 level measured over a period of not less than 15 minutes when the construction site is operating must not exceed the background level by more than 5 dB(A) at the boundary.

Should complaints of a noise nuisance be substantiated, Council may require the acoustic treatment of the premises to ensure compliance with the NSW Department of Environment and Climate Changes “Interim construction noise guideline” and AS 2436-2010 – “Guide to noise and vibration control, demolition and maintenance sites” for the control of construction noise. A further acoustic assessment and report will be required to be provided to Council assessing the premises in working order.

(Reason: Noise attenuation.)

48. **SECTION 7.11 CONTRIBUTION PAYMENT - DIRECT CONTRIBUTIONS PLAN (CC)**

In accordance with the provisions of Section 7.13 of the Environmental Planning and Assessment Act 1979 and the Strathfield Direct Development Contributions Plan 2010-2030, a contribution in the form of cash, cheque or credit card (financial transaction fee applies) shall be paid to Council for the following purposes:

Provision of Major Open Space	\$156,400.07
Provision of Local Open Space	\$101,934.43
Administration	\$3,018.25
TOTAL	\$261,352.75

The total amount of the contribution is valid as at the date of determination and is subject to

quarterly indexation. Contributions shall be indexed at the time of payment in accordance with clause 2.14 of the Strathfield Direct Development Contributions Plan 2010-2030.

Contributions must be receipted by Council and submitted to the Accredited Certifier, prior to the issue of any Construction Certificate.

Please present a copy of this condition when paying the contribution at the Customer Service Centre so that it can be recalculated.

Note: A copy of Strathfield Council's Section 7.11 Direct Development Contributions Plan may be downloaded from Council's website.

(Reason: To enable the provision of public amenities and services required/anticipated as a consequence of increased demand resulting from the development.)

49. **SECURITY PAYMENT - DAMAGE DEPOSIT FOR COUNCIL INFRASTRUCTURE (CC)**

A security (damage deposit) of **\$33,000** (calculated in accordance with Council's adopted Fees and Charges) shall be paid to Council, prior to the issue of a Construction Certificate.

The deposit is required as security against any damage to Council property during works on the site. The applicant must bear the cost of all restoration works to Council's property damaged during the course of this development. All building work must be carried out in accordance with the Building Code of Australia.

Payment may be accepted in the form of cash, bank guarantee, cheque or credit card (financial transactions fees apply). Note: Additional fees apply for the lodgement of a bank guarantee in lieu of cash bond applies in accordance with Council's adopted Fees and Charges.

Any costs associated with works necessary to be carried out to rectify any damages caused by the development, shall be deducted from the Damage Deposit.

Note: Should Council property adjoining the site be defective e.g. cracked footpath, broken kerb etc., this should be reported in writing, or by photographic record, submitted to Council at least seven (7) days prior to the commencement of any work on site. This documentation will be used to resolve any dispute over damage to infrastructure. It is in the applicant's interest for it to be as full and detailed as possible.

The damage deposit shall be refunded upon completion of all works upon receipt of a Final Occupation Certificate stage and inspection by Council.

(Reason: Protection of Council infrastructure.)

50. **TRAFFIC - CONSTRUCTION TRAFFIC MANAGEMENT PLAN (CC)**

A Construction Traffic Management Plan (CTMP) is to be prepared by an appropriately qualified Traffic Management Consultant and submitted to and approved by Council's Engineering Section, prior to the commencement of any works including demolition.

The following matters should be addressed in the CTMP (where applicable):

- i) description of the demolition, excavation and construction works;
- ii) site plan/s showing the site, roads, footpaths, site access points and vehicular movements;
- iii) size, type and estimated number of vehicular movements (including removal of

- excavated materials, delivery of materials and concrete to the site);
- iv) proposed route(s) from the arterial (state) road network to the site and the proposed route from the site back to the arterial road network;
- v) impacts of the work and vehicular movements on the road network, traffic and pedestrians and proposed methods to safely manage pedestrians and construction related vehicles in the frontage roadways;
- vi) any Traffic Control Plans (TCP's) proposed to regulate traffic and pedestrian movements for construction activities (such as concrete pours, crane installation/removal etc.);
- vii) proposed hours of construction related activities and vehicular movements to and from the site;
- viii) current/proposed approvals from other Agencies and Authorities (including Roads and Maritime Services, Police and State Transit Authority);
- ix) any activities proposed to be located or impact upon Council's road, footways or any public place;
- x) measures to maintain public safety and convenience;
- xi) any proposed road and/or footpath closures;
- xii) turning areas within the site for construction and spoil removal vehicles, allowing a forward egress for all construction vehicles on the site;
- xiii) locations of work zones (where it is not possible for loading/unloading to occur on the site) in the frontage roadways accompanied by supporting documentation that such work zones have been approved by the Local Traffic Committee and Council;
- xiv) location of any proposed crane and concrete pump and truck standing areas on and off the site (and relevant approvals from Council for plant on road);
- xv) a dedicated unloading and loading point within the site for all construction vehicles, plant and deliveries;
- xvi) material, plant and spoil bin storage areas within the site, where all materials are to be dropped off and collected;
- xvii) on-site parking area for employees, tradespersons and construction vehicles as far as possible;
- xviii) proposed areas within the site to be used for the storage of excavated material, construction materials and waste and recycling containers during the construction period; and
- xix) how it is proposed to ensure that soil/excavated material is not transported onto surrounding footpaths and roadways.

(Reason: To mitigate traffic impacts on the surrounding area during the construction period.)

51. **VEHICULAR CROSSINGS - WORKS PERMIT FOR CONSTRUCTION OF (CC)**

Full-width, heavy-duty concrete vehicular crossing(s) shall be provided across the footpath at the entrance(s) and/or exit(s) to the site and designed in accordance with Council's guidelines and specifications. In this regard, a Works Permit is to be obtained (available from Council's Customer Services Centre or downloaded from Council's website), and the appropriate fees and charges paid, prior to the lodgement of a Construction Certificate.

(Reason: To ensure appropriate access to the site can be achieved.)

52. **WASTE AND RECYCLING STORAGE ROOMS (CC)**

Waste (including grease arrestor rooms) and recycling storage rooms must meet all of the following conditions:

- i) The waste and recycling storage room must be of adequate dimensions to comfortably accommodate the required number of waste and recycling bins

- 240L bin must have 1.1m² of space per bin
 - 660L bin must have 2.03m² of space per bin
- ii) The layout of the waste and recycling storage room must allow easy unobstructed access to all bins (stacked bin arrangements are not acceptable) and allow the bins to be easily removed for servicing purposes.
 - iii) A smooth concrete floor graded and drained to a floor waste connected to the sewer of the Water Board.
 - iv) The walls being cement rendered with the intersection of the walls and floor being coved to a radius of not less than 25mm.
 - v) The door being close fitting to prevent the access of rats and mice.
 - vi) A cold water hose cock being provided for the cleaning of containers and the room itself.
 - vii) Ventilation being provided by means of direct connection to the outside air to the satisfaction of Council.
 - viii) The ceiling of all waste storage rooms must be constructed of a rigid smooth faced non-absorbent material. The ceiling must be a minimum of 2.4m high to accommodate Councils standard bins. This enables access for use, cleaning and enables the lids of bins to be fully opened.
 - ix) Contain a sign, minimum size 600mm x 600mm, directing residents not to place recyclables in garbage carts and encouraging residents to recycle. Sample artwork and signs available from Council.
 - x) Arrangements must be in place regarding the regular maintenance and cleaning of waste management facilities.
 - xi) A caretaker or individual(s) shall be nominated as being responsible for transferring the bins to the collection point and back into the waste storage room/area.
 - xii) Detailed plans of waste and recycling storage rooms must be submitted along with Waste Management Plan and Waste and Recycling Storage Room/Area Design Checklist.

(Reason: To keep garbage rooms in a clean and sanitary condition to protect public health.)

53. **WATER SUSTAINABILITY - WATER SENSITIVE URBAN DESIGN (CC)**

Details of the Water Sensitive Urban Design (WSUD) components (stormwater treatment measures) shall be submitted to and approved by the Principal Certifying Authority prior to the issue of a Construction Certificate. Details shall demonstrate compliance with the water conservation and stormwater quality targets set out under Sections 3.1 and 3.2 respectively under Part N of the SDCDP 2005, and be prepared by a suitably qualified professional engineer.

(Reason: To promote Water Sensitive Urban Design.)

54. **WORKS WITHIN THE ROAD RESERVE (CC)**

Detailed drawings including long and short sections and specifications of all works within existing roads (including but not limited to structures, road works, driveway crossings, footpaths and stormwater drainage) shall be submitted to and approved by Council under Section 138 of the Roads Act 1993 and all fees and charges paid, prior to the issue of a Construction Certificate.

Detailed drawings and specifications are to be prepared and certified by an appropriately qualified Civil Engineer.

Upon completion of the works, the Applicant is to provide to Council with electronic copies of 'Work as Executed Plans'. The plans are to show relevant dimensions and finished levels and are to be certified by a surveyor.

The Applicant is to provide to Council, in an approved format, details of all public infrastructure created as part of the works.

All civil engineering works adjacent/near/outside 195 Parramatta Road, Homebush West are to be fully supervised by Council. A maintenance period of six (6) months shall apply to the work, after it has been completed and approved. In that period, the Applicant shall be liable for any part of the work which fails to perform in the manner outlined in Council's specifications, or as would reasonably be expected under the design conditions.

(Reason: To ensure compliance of engineering works/Council assets are constructed to acceptable standards for engineering works.)

55. WORKS ZONE - APPROVAL BY COUNCIL'S TRAFFIC COMMITTEE (CC)

An application for a 'Works Zone' must be submitted to and approved by the Strathfield Council Traffic Committee prior to the commencement of any site work (including demolition).

The suitability of the proposed length and duration of the Works Zone is to be demonstrated in the application for the Works Zone. The application for the Works Zone must be submitted to Council at least six (6) weeks prior to the commencement of work on the site to allow for assessment and tabling of agenda for the Strathfield Council Traffic Committee.

The requirement for a Works Zone may be varied or waived only if it can be demonstrated in the Construction Traffic Management Plan (to the satisfaction of Council) that all construction related activities (including all loading and unloading operations) can and will be undertaken wholly within the site. The written approval of Council must be obtained to provide a Works Zone or to waive the requirement to provide a Works Zone prior to the commencement of any site work.

(Reason: Council requirement.)

CONDITIONS TO BE SATISFIED PRIOR TO THE COMMENCEMENT OF WORKS (CW)

56. STAGE 2 DETAILED INVESTIGATION FOR CONTAMINATION

Prior to demolition and prior to any excavation, the person with the benefit of the consent is to undertake a Stage 2 detailed investigation of the site in accordance with the Contaminated Lands Management Act 1997, SEPP 55– Remediation of Land and "Sampling Design Guidelines for Contaminated Sites" NSW EPA.

(Reason: Council requirement.)

57. REMEDIATION WORKS & VALIDATION REPORT

If the Stage 2 detailed site investigation report identifies that remediation works are required, a Remediation Action Plan (RAP) is to be prepared by a suitably qualified person and submitted to the Principal Certifying Authority (PCA) and the RAP must be implemented according to the Contaminated Lands Management Act 1997 & SEPP 55 – Remediation of Land.

On completion of the remediation works identified on Stage 2 detailed site investigation, a validation report shall be prepared by suitably qualified person and be submitted to Principle Certifying Authority. Validation report shall be prepared in accordance with the Contaminated Lands Management Act 1997 & SEPP 55 – Remediation of Land.

(Reason: Council requirement.)

58. APPOINTMENT OF A PRINCIPAL CERTIFYING AUTHORITY (PCA) (CW)

No work shall commence in connection with this Development Consent until:

- i) A construction certificate for the building work has been issued by the consent authority or a Principal Certifying Authority.
- ii) The person having the benefit of the development consent has appointed a principal certifying authority for the building work, and notified the principal certifying authority that the person will carry out the building work as an owner/builder, if that is the case.
- iii) The principal certifying authority has, no later than 2 days before the building work commences:
 - notified the Council of his or her appointment, and
 - notified the person having the benefit of the development consent of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- iv) The person having the benefit of the development consent, if not carrying out the work as an owner-builder, has:
 - appointed a principal contractor for the building work who must be the holder of a contractor licence if any residential building work is involved;
 - notified the principal certifying authority of such appointment; and
 - unless that person is the principal contractor, notified the principal contractor of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- v) The person having the benefit of the development consent has given at least 2 days' notice to the Council of the person's intention to commence the erection of the building.

Note: If the principal certifying authority is the Council, the nomination will be subject to the payment of a fee for the service to cover the cost of undertaking all necessary inspections and the issue of the appropriate certificates.

Under the Environment Planning and Assessment (Quality of Construction) Act, 2003, a sign must be erected in a prominent position on the work site showing the name, address and telephone number of the principal certifying authority; the name of the principal contractor (if any) for the building work and a telephone number at which that person may be contacted outside working hours. That sign must also state that unauthorised entry is prohibited. The sign must not be removed until all work has been completed.

(Reason: Statutory requirement.)

59. NOTICE OF COMMENCEMENT (CW)

No work shall commence until the following details are submitted to Council:

- i) a Notice of Commencement (form will be attached with issue of a Construction Certificate or available from our website) within two (2) days of the date on which it is proposed to commence works associated with the Development Consent;
- ii) details of the appointment of a Principal Certifying Authority (either Council or another Principal Certifying Authority); and
- iii) details of the name, address and licence details of the Builder.

(Reason: Statutory requirement.)

60. HERITAGE – TEMPORARY PROTECTION PLAN (CW)

Prior to the commencement of works, a temporary protection plan must be developed for the site that identifies the potential risks and outlines measures to reduce the potential for damage to heritage fabric for the duration of the works.

CONDITIONS TO BE SATISFIED DURING DEMOLITION AND BUILDING WORKS (DW)**61. CONTAMINATED LAND UNEXPECTED FINDS (DW)**

In the instance works cause the generation of odours or uncovering of unexpected contaminants works are to immediately cease, Council is to be notified and a suitably qualified environmental scientist appointed to further assess the site.

The contaminated land situation is to be evaluated by the supervising environmental consultant and an appropriate response determined in consultation with the applicant, which is agreed to by Strathfield Council's Environmental Services Manager.

Note: Council may also request that a NSW EPA accredited site auditor is involved to assist with the assessment of the contaminated land situation and review any new contamination information. The applicant must also adhere to any additional conditions which may be imposed by the accredited site auditor.

(Reason: To ensure compliance with statutory requirements.)

62. FILL MATERIAL (DW)

The only waste derived material which may be received at the development site is:

- i) Virgin excavated material (within the meaning of the Protection of the Environment Operations Act 1997), and
- ii) any other waste-derived material the subject of a resource recovery exemption under cl.51A of the Protection of the Environment Operations (Waste) Regulation 2005 that is permitted to be used as fill material.

Any (b)-type material received at the development site must be accompanied by documentation certifying by an appropriately qualified environmental consultant the materials compliance with the exemption conditions; and this documentation must be provided to the Principal Certifying Authority on request.

(Reason: To ensure imported fill is of an acceptable standard for environmental protection purposes.)

63. FOOD PREMISES - CONSTRUCTION AND FIT-OUT OF (DW)

The construction and fit-out of the food premises must comply with the following:

- iii) The Food Act 2003;
- iv) Food Regulation 2015;
- v) Australia and New Zealand Food Standards Code;
- vi) Australian Standard AS 4674 – 2004 (Design, construction and fit-out of a food premises); and
- vii) The Building Code of Australia.

Details demonstrating compliance shall be submitted to the Principal Certifying Authority for approval, prior to any occupation of the premises.

(Reason: Compliance with food premises legislation and standards.)

64. HERITAGE - HISTORIC RELICS FOUND DURING WORKS (DW)

Should any potentially historic relics be discovered on the site during excavation, all excavation or disturbance to the area is to stop immediately and the Heritage Division of the NSW Department of Environment and Heritage should be informed in accordance with Section 146 of the Heritage Act 1977. 'Relics' are any deposit, artefact, object or material evidence that relates to the settlement of the area that comprises New South Wales, not being Aboriginal settlement, and are of State or local heritage significance.

Should any potentially significant Aboriginal material be discovered on the site, all excavation or disturbance of the area is to stop immediately and the Heritage Division of the NSW Department of Environment and Heritage is to be informed in accordance with Section 91 of the National Parks and Wildlife Act 1974.

(Reason: To ensure the proper management and preservation of potentially significant archaeological material.)

65. OBSTRUCTION OF PUBLIC WAY NOT PERMITTED DURING WORKS (DW)

The public way must not be obstructed by any materials, vehicles, refuse, skips or the like, under any circumstances, without the prior approval of Council.

(Reason: To maintain public access and safety.)

66. PUBLIC INFRASTRUCTURE AND SERVICES (DW)

The applicant must comply with the requirements (including financial costs) of any relevant utility provider (e.g. Energy Australia, Sydney Water, Telstra, RMS, Council etc.) in relation to any connections, works, repairs, relocation, replacements and/or adjustments to public infrastructure or services affected by the development.

(Reason: To maintain public infrastructure and/or services.)

67. SURVEY REPORT OF APPROVED LEVELS DURING AND POST CONSTRUCTION (DW)

A Survey Certificate to Australian Height Datum shall be prepared by a Registered Surveyor as follows:

- i) At the completion of the first structural floor level prior to the pouring of concrete indicating the level of that floor and the relationship of the building to the boundaries.
- ii) At the completed height of the building, prior to the placement of concrete form work, or the laying of roofing materials.
- iii) At the completion of the development.

Progress certificates in response to points (1) through to (3) shall be provided to the Principal Certifying Authority at the time of carrying out relevant progress inspections. Under no circumstances is work allowed to proceed until such survey information is submitted to and approved by the Principal Certifying Authority.

(Reason: To ensure compliance with the approved plans.)

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF AN OCCUPATION CERTIFICATE (OC)**68. CAR PARKING - SURPLUS VEHICULAR CROSSINGS (OC)**

All surplus vehicular crossings and/or kerb laybacks must be removed and reinstated with concrete kerb and gutter or to the existing edging profile as specified by Council. The nature strip is to be restored and the footpath area reinstated. All of the above are to be restored to the satisfaction of Council's Engineer and at full cost to the applicant, prior to the issue of any Occupation Certificate.

(Reason: Maintenance of public infrastructure.)

69. CAR PARKING - VISITOR CAR PARKING SIGNAGE (OC)

A sign shall be erected in a suitable location on the property near the driveway entrance indicating where visitor parking is available on the site. Signage shall also be erected above the visitor parking itself. Details demonstrating compliance shall be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: Adequate access and egress.)

69A CAR PARKING - VEHICULAR CIRCULATION, AISLE AND RAMP WIDTHS (OC)

The aisle widths, internal circulation, ramp widths and grades of the car park shall comply with the Roads and Traffic Authority Guidelines and AS/NZS 2890.1:2004 - Off-Street Car Parking Code.

Vehicular manoeuvring paths are to be prepared demonstrating that all vehicles can enter or depart the site in a forward direction without encroaching on required car parking spaces.

(Reason: To ensure compliance with Australian Standards relating to manoeuvring, access and parking of vehicles.)

69B. CAR PARKING - COMPLIANCE WITH AS/NZS 2890.1:2004 (OC)

Car parking dimensions must comply with the Australian/New Zealand Standard AS/NZS 2890.1:2004 - Parking facilities - Off-street car parking.

(Reason: To ensure compliance with Australian Standards relating to parking of vehicles.)

70. ENGINEERING WORKS (CERTIFICATION OF)

Prior to occupation of the premises, a Work As Executed (WAE) Plan of all engineering and/or drainage works is to be submitted to the Principal Certifying Authority. The WAE Plan is to be certified by a suitably Qualified Engineer, with Corporate Membership standing in the Institution of Engineers Australia and registered on the National Professional Engineers Register (NPER) under the appropriate professional category, demonstrating that:

- i) the stormwater drainage system; and/or
- ii) the car parking arrangement and area; and/or
- iii) any related footpath crossing works; and/or
- iv) the proposed basement pump and well system; and/or
- v) the proposed driveway and layback; and/or
- vi) any other civil works

have been constructed in accordance with the approved plans and any relevant Standards and Council policies/specifications.

For major works, such as subdivisions, works within the road reserve (requiring separate S138 approval) and as where specified by Council, a Part 4A Certificate will be required. It is strongly recommended that an Engineer supervise all engineering related works.

Where Council is not the Principal Certifying Authority, an electronic copy of the above documents is to be provided to Council, prior to the issue of any Occupation Certificate.

(Reason: Asset management.)

71. FOOD PREMISES - REGISTRATION REQUIREMENTS (OC)

Prior to the issue of any Occupation certificate, a Registration of Food Premises Form must be completed and submitted to Council, and the appropriate fees paid. The form is available online via council's website. In the instance details on the original registration form change, Council is to be notified of the change within seven (7) days of the change occurring.

(Reason: Registration and notification to relevant authorities.)

72. FIRE SAFETY CERTIFICATION (OC)

A fire safety certificate shall be obtained in accordance with Part 9, Division 4 of the Environmental Planning and Assessment Regulation 2000, prior to the issue of any Occupation Certificate.

A fire safety certificate is a certificate issued by the owner of a building to the effect that each essential fire safety measure specified in the current fire safety schedule for the part of the building to which the certificate relates:

- i) has been assessed by a properly qualified person; and
- ii) was found, when it was assessed, to be capable of performing to at least the standard required by the current fire safety schedule for the building for which the certificate is issued.

An interim fire safety certificate must be provided before an interim occupation certificate can be used for a building under Clause 153(2) of the Environmental Planning & Assessment Regulation 2000.

A final fire safety certificate must be provided before an interim occupation certificate can be used for a building under Clause 153(1) of the Environmental Planning & Assessment Regulation 2000.

A copy of the fire safety certificate and fire safety schedule shall be:

- i) submitted to Strathfield Council;
- ii) submitted to the Commissioner of the New South Wales Fire Brigade; and
- iii) prominently displayed in the building.

(Reason: Fire safety and statutory requirement.)

73. OCCUPATION OF BUILDING (OC)

A person must not commence occupation or use (or change of use where an existing building) of the whole or any part of a new building (within the meaning of section 109H (4) of the Act) unless an Interim Occupation Certificate or Final Occupation Certificate has been issued in relation to the building or part.

The Principal Certifying Authority is required to be satisfied, amongst other things, that:

- i) all required inspections (including each applicable mandatory critical stage inspection) have been carried out; and
- ii) any preconditions to the issue of the certificate required by a development consent have been met.

Note: New building includes an altered portion of, or an extension to, an existing building.

(Reason: Statutory requirement.)

74. STORMWATER - CERTIFICATION OF THE CONSTRUCTED DRAINAGE SYSTEM (OC)

The constructed stormwater system shall be certified by a suitably qualified person, in accordance with Council's Stormwater Management Code, prior to the issue of any Occupation Certificate.

(Reason: Adequate stormwater management.)

75. STORMWATER - COVENANT AND RESTRICTION AS TO USER FOR STORMWATER CONTROLLED SYSTEMS (OC)

Prior to the issue of any Occupation Certificate, the applicant shall register a Positive Covenant and a Restriction as to User under section 88E of the Conveyancing Act as appropriate in favour of Council, ensuring the ongoing retention, maintenance and operation of the stormwater facility on-site detention and water sensitive urban devices.

(Reason: To ensure the on-site detention and/or pump system is maintained to an appropriate operational standard.)

76. SYDNEY WATER - SECTION 73 CERTIFICATE (SC)

A Section 73 Compliance Certificate under the Sydney Water Act 1994 must be obtained before the issue of the Subdivision Certificate. An application must be made through an authorised Water Servicing Coordinator (refer www.sydneywater.com.au).

Following receipt of the application a 'Notice of Requirements' will be issued detailing water and sewer extensions to be built and charges to be paid. Please make early contact with the Water Servicing Coordinator, as building of water/sewer extensions can be time consuming and may impact on other services and building, driveway or landscape design.

Sydney Water written advice that you have obtained the Notice of Requirements must be submitted to the Principal Certifying Authority.

The Section 73 Compliance Certificate must be submitted to the Principal Certifying Authority prior to release of the Subdivision Certificate/any occupation of the premises.

(Reason: To comply with the statutory requirements of Sydney Water.)

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF A SUBDIVISION CERTIFICATE (SC)

77. COVENANT – FLOOR SPACE RATIO (SC)

Prior to the issue of a Subdivision Certificate, a covenant is to be registered against the title of proposed Lot 10 restricting the gross floor area (GFA) of future development of that lot to a maximum of 2,118m² GFA. For the purposes of this condition, gross floor area (GFA) is to be defined in accordance with the dictionary referred to in Clause 1.4 of Strathfield Local Environmental Plan 2012.

The covenant shall not be varied without the approval of Council.

(Reason: To prevent 'double dipping' the floor space ratio standard.)

78. SUBDIVISION - LODGEMENT OF FINAL PLAN OF SUBDIVISION (SC)

Once a Subdivision Certificate is issued by the Principal Certifying Authority, the Final Plan of Subdivision must be registered with Land and Property Information. Documentary evidence that the linen plan has been registered with Land and Property Information must be submitted to Strathfield Council as soon as practicable.

(Reason: Statutory requirement.)

CONDITIONS TO BE SATISFIED DURING ONGOING USE OF THE PREMISES (OU)**79. FIRE SAFETY ANNUAL STATEMENT (OU)**

Pursuant to Part 9, Division 5 of the Environmental Planning and Assessment Regulation (as amended) the owner of the building shall provide to Council an Annual Fire Safety Statement from an appropriately qualified person certifying the essential fire safety measures in the building. The Annual Fire Safety Statement shall be submitted within 12 months of the issue of the fire safety certificate, and then on an annual basis.

A copy of the Fire Safety Statement obtained and Fire Safety Schedule shall also be:

- i) Forwarded to the Commissioner of the New South Wales Fire Brigade; and
- ii) Prominently displayed in the building.

(Reason: Fire safety.)

80. FOOD PREMISES - ONGOING USE OF (OU)

The ongoing operation and fit out of the premises must be maintained in accordance with the following requirements:

- i) Food Act 2003;
- ii) Food Regulations 2004;
- iii) Australian Standard AS4674-2004: Construction and fit out of food premises;
- iv) Australia and New Zealand Food Standards Code 3.2.3: Food Premises and Equipment; and
- v) Australia and New Zealand Food Standards Code 3.2.2: Food Safety Practices and General Requirements.

(Reason: To ensure compliance with legislation and to protect public health and safety.)

81. SIGNAGE - PORTABLE SIGNS PROHIBITED ON PUBLIC FOOTWAY (OU)

Portable signs including sandwich boards, goods or the like shall not be placed on the public footway or other public areas.

(Reason: To ensure pedestrian safety.)

82. HOURS OF OPERATION – NEW HOTEL (OU)

The hours of operation (i.e. hours open for business) of the sports bar and gaming room on the ground floor level of the new hotel building must not exceed the following, without the prior approval of Council:

Days	Approved hours of operation
Mon-Saturday	7am – 12midnight
Sunday	7am – 10pm

(Reason: To ensure the business operates between the approved hours.)

83. VEHICULAR ACCESS (OU)

The Parramatta Road access shall only be used between the hours of 10pm and 6am. During this period, there is to be no vehicular access via the new vehicular crossings in Flemington Road and Park Road (except for service vehicle access in the case of the new vehicular crossing in Park Road). The vehicular crossing in Park Road is to be signposted for service vehicle access only.

84. DELIVERIES (OU)

All deliveries must not occur before 7.00am or after 8.00pm weekdays and before 8.00am or after 5.00pm weekends and public holidays, to avoid noise disruption to the surrounding area.

(Reason: To control noise impacts.)

85. LICENSED PREMISES - NOISE REQUIREMENTS (OU)

The LA10 noise level emitted from the licensed premises shall not exceed the background noise level in any octave band centre frequency (31.5Hz - 8 Hz inclusive) by more than 5dB (A) between 7am and 12 midnight at the boundary of any affected residence

Notwithstanding compliance with the above, the noise from the licensed premises shall not be audible within any habitable room in any residential premises between the hours of 12 midnight and 7am.

(Reason: Environmental health.)

86. LOADING AND UNLOADING - NO OBSTRUCTION OF PUBLIC ROAD OR FOOTWAY (OU)

All loading and unloading operations including fork lift trucks or other similar loading, lifting and/or carrying appliances used in conjunction with the premises, shall be carried out wholly within the boundaries of the site, at all times. There shall be no obstruction of any public roadway or footway at any time, without the prior

(Reason: Public safety.)

87. NOISE - NO AMPLIFIED MUSIC (OU)

Music and other amplified sound played on the premises shall not give rise to offensive noise as defined under the provisions of the Protection of the Environment Operations Act 1997. The sound level output shall not exceed 5 dB(A) above the ambient background level at the received boundary.

Speakers must not be installed and music must not be played in any of the outdoor areas associated with the premises including the public domain. Speakers located within the premises must not be placed so as to direct the playing of music towards the outdoor areas associated with the premises.

(Reason: Environmental amenity.)

88. NOISE - SIGNAGE TO PATRONS EXITING THE PREMISES (OU)

A clearly visible sign shall be permanently erected immediately adjacent to the entry/exit doors indicating that patrons are to leave in an orderly fashion and shall leave the vicinity of the premises in a manner that does not disturb the quiet and good order of the neighbourhood.

(Reason: Public interest.)

89. COMPLAINT RESPONSE (OU)

In the event of a complaint being received from a neighbouring resident with respect to disturbance to the quiet and good order of the neighbourhood, hotel management shall respond to such a complaint in a proactive and effective manner.

(Reason: To maintain neighbourhood amenity)

90. WASTE AND RECYCLING COLLECTION (COMMERCIAL AND INDUSTRIAL) (OU)

- i) The collection of commercial and industrial waste and recycling must only occur between 6.00am and 8.00pm weekdays and 9.00am and 5.00pm on weekends and public holidays, to avoid noise disruption to the surrounding area.
- ii) Commercial and industrial garbage and recycling must be collected on site unless expressly agreed to in OC.
- iii) Where consent is given for commercial and industrial garbage and recycling to be placed kerbside for collection bins must not be placed on the kerbside more than one hour before the scheduled collection time. Bins and containers are to be removed from the kerbside within one (1) hour of collection and returned to the designated garbage storage area(s).
- iv) The garbage and recyclable storage area and bins must be adequate to contain the volume and type of garbage and recyclable matter of the food premises.
- v) All garbage and recyclable matter must be enclosed in the waste bins with lids completely closed at all times.
- vi) Recycling options must be provided for all commercially recyclable waste products including but not limited to paper, cardboard, oil, food waste, plastics, metals, chemicals etc.

(Reason: To regulate noise and garbage collection arrangements.)

91. CONTROL OF LITTER (OU)

The occupant or person in control of the premises must take all practicable steps to ensure that the area of public footpath or public area adjacent to the premises is maintained in a

clean and tidy condition.

A litter management plan must be included with all applications, litter management plan must include the below:

- i) All steps being taken to prevent, reduce and collect any litter produced by the site
- ii) Measures such as cleaner to conduct litter collection within a 50m radius to be included.

(Reason: To manage litter throughout the LGA.)

92. CAR PARKING - DISABLED CAR PARKING SPACES (OU)

Car parking for people with disabilities shall be provided in accordance with the Building Code of Australia, relevant Australian Standards and with regard to the Disability Discrimination Act 1992.

(Reason: To ensure adequate parking for persons with a disability.)

93. CAR PARKING - REQUIREMENTS FOR MULTIPLE USE BUILDINGS (OU)

The following car parking and service vehicle requirements apply:-

- i) Car spaces shall be provided on the development site at the rate determined by the Council approved Traffic and Parking Study. Car spaces are to be allocated to both the new hotel building and the existing licensed premises comprising the Wentworth Hotel.
- ii) All car spaces shall be allocated and marked according to this requirement.
- iii) If the development is to be strata subdivided, the car park layout must reflect the above allocation and thereafter be regarded as part of the entitlement of that strata lot.
- iv) Under no circumstances shall parking spaces be sold, let or otherwise disposed of for use other than in accordance with this condition.
- v) Each car parking space shall have minimum dimensions in accordance with the relevant Australian Standard and be provided on-site in accordance with the approved plans.
- vi) The parking bays shall be delineated by line marking.
- vii) Visitor spaces shall be clearly line marked and/or signposted and shall only be used by persons visiting residents of the property or commercial/business/retail premises located within the development. Visitor spaces shall not be allocated as permanent residential parking spaces. Access to visitor parking spaces shall not be restricted without development approval and a sign shall be erected at the vehicular entrance indicating the availability of visitor parking.
- viii) The following traffic control measures shall be implemented on site:-
 - Signage indicating 'Entry Only' shall be prominently displayed at the entrance to the development.
 - Signage indicating 'Exit Only' shall be prominently displayed at the exit to the development.
 - One-Way directional arrows shall be painted on the driveway pavement to indicate the required vehicular directional movement through the car parking area.

(Reason: To ensure car parking provision in accordance with this consent.)

RESOLUTION/REASONS

The Panel notes the applicant tabled an amended Clause 4.6 request to vary to floor space ratio control and the re-calculations were agreed to by Council's Planners.

The Panel is satisfied that the amended Clause 4.6 request to contravene the floor space ratio under Clause 4.4 of the SLEP2012 is well founded and the variation is justified in the circumstances of the case and the objectives of the standard and zone are met.

The Panel is also satisfied that the Clause 4.6 request to vary the height standard under Clause 4.3 of the SLEP2012 is well founded and a contravention in the circumstances of this case is well founded and meets the standards objective and zone objectives.

Having considered the Council Officer's report and recommendation and submissions made during the exhibition and with the benefit of a site inspection the Panel has determined the application be **APPROVED** subject to a **DEFERRED COMMENCEMENT** requiring amended plans to satisfy the parking access and landscaping requirements detailed in the officer's recommended conditions. This is to provide certainty in the final built form as the plans will require amending to satisfy the Deferred Commencement conditions.

DEFERRED COMMENCEMENT APPROVAL

This is a Deferred Commencement Consent under Section 4.16(3) of the Environmental Planning and Assessment (EP&A Act, 1979. This consent does not become operative until the applicant has satisfied the conditions listed under Schedule A below. All conditions shall be satisfactorily resolved within a period of twelve (12) months from the Determination Date that is shown on this consent. Upon compliance with the conditions under SCHEDULE A and written confirmation of this from Council, the consent shall become operative from the 'Date of Endorsement' (to be included on the written notice of determination).

(Reason: A deferred commencement consent stipulates conditions that must be satisfied before the consent operates in accordance with Section 4.16(3) of the EP&A Act 1979)

a. TRAFFIC & PARKING ASSESMENT

An amended report is to be submitted to and approved by Council to satisfy the following:

- i. Updated traffic and parking study;
- ii. Servicing Arrangements;
- iii. Basement car parking requirements;
- iv. Disabled car parking spaces;
- v. Vehicular circulation, aisle and ramp widths;

The amended traffic assessment report and amended plans are to comply with Car parking dimensions and must comply with the Australian/New Zealand Standard AS/NZS 2890.1:2004 - Parking facilities - Off-street car parking. Details demonstrating compliance are to be submitted to Council for approval.

b. ACOUSTIC ASSESSMENT

The acoustic assessment (Revision 2 and dated 6 August 2018) as prepared by Acoustic Logic is to be amended to address the following criteria and demonstrate compliance with the relevant Industrial Policy for Noise, Liquor & Gaming NSW guidelines and relevant requirements of the NSW Department of Planning's *Developments near Rail Corridors or Busy Roads – Interim Guideline*.

- i. Confirm the location of the unattended noise measurement location within Figure 1 of the acoustic report.
- ii. Figure 1 of the acoustic report and the corresponding legend are not coherent. Ensure the items in the figure correspond to the legend.
- iii. Confirm which Industry Policy for Noise was used during the assessment, INP 2000 or Noise Policy for Industry 2017. New development and assessments after October 2017 must be conducted in accordance with the Noise Policy for Industry 2017.
- iv. Specify the specific location of the residential receivers for residences on Flemington Road. For example, was there a noise logger at the front of each property? Or was there only one receiver to average for each residence?
- v. Define "Section 0" as mentioned in S.6.1 and S.8

The above information is to be submitted to council's satisfaction, prior to issue of any Construction Certificate for the development.

c. **LANDSCAPE PLAN**

The landscape plan (Issue C and dated 7 February 2018) as prepared by Paul Scrivener is to be amended to reflect the revisions to the site landscaping as detailed on the approved architectural drawings. This plan is to be prepared by a qualified landscape architect or landscape consultant to a scale of 1:100 or 1:200 and in conformity with all relevant conditions of consent.

The plan must include the following information:

- i) The retention of the 3 Melaleuca Trees numbers 5, 6 and 7 (amended plans and arborist report as to how these will be protected during construction).
- ii) details demonstrating compliance with SCDCP 2005 in relation to landscaping requirements;
- iii) location of all existing and proposed landscape features including materials to be used;
- iv) all trees to be retained, removed or transplanted;
- v) existing and proposed finished ground levels;
- vi) top and bottom wall levels for both existing and proposed retaining and free standing walls; and
- vii) a detailed plant schedule which includes proposed species listed by botanical (genus and species) and common names, quantities of each species, pot sizes and the estimated size at maturity. A minimum of 25% of species shall be locally sourced indigenous species. Species shall be predominantly selected from Council's Recommended Tree List.

The above information and amended plans are to be submitted to council's for approval.

The Operational conditions require consequential amendments.

On the satisfaction of the above deferred commencement conditions the consent then becomes operational with the Conditions below as stated in Schedule B.

FOR: J.Murrell, E.Armstrong, I.Stapleton, R. Jolliffe

AGAINST: Nil

**** End Minutes - Report No. 2****

TO: Strathfield Local Planning Panel Meeting - 1 November 2018
REPORT: SLPP – Report No. 3
SUBJECT: DA2018/080 - 14 FRANCIS STREET, STRATHFIELD
LOT 15 SECTION 1 DP 12467
DA NO. DA2018/080

RECOMMENDATION

That Development Application No. DA2018/080 for demolition of existing structures and construction of new two (2) storey dwelling with basement level, front fence and in-ground swimming pool at 14 Francis Street, Strathfield be **APPROVED**, subject to the following conditions:

SPECIAL CONDITIONS (SC)

1. BUILDING HEIGHT (SC)

The building height for the front portion (North-western Corner) of the dwelling shall be reduced by a minimum of 500mm such that it does not exceed on RL25.040 based on the Australian Height Datum. Details are to be indicated on the plans and approved by Council, prior to the issue of a Construction Certificate.

(Reason: To reduce the overall bulk of the building.)

2. DEEP SOIL SOFT LANDSCAPING (SC)

The Landscape plan is to be amended to provide a 8-10 metre canopy tree to front setback area to Council satisfaction a minimum of 31m² of deep soil landscaping is to be added to the subject site. Details are to be indicated on the plans and signed off and approved by Council prior to the issue of a Construction Certificate..

(Reason: The canopy Tree is required to compliment the dwelling and the streetscape and to ensure compliance with Part A of the SCDP 2005.)

3. VISUAL PRIVACY MEASURES (SC)

The first floor windows except the northern bedroom and the stair windows located of the south-east and the north-west elevation of the dwelling are to be modified such that they have a way where each window is to have a minimum sill height of 1.5m from the first floor level. Details are to be indicated on the plans and approved by Council, prior to the issuing of a Construction Certificate.

(Reason: To minimise potential overlooking of the neighbouring properties.)

3b. DELETION OF NORTHERN BEDROOM BALCONY (SC)

Delete the balcony of the northern bedroom as shown on Revision D in the plans.

(Reason: This was a later addition and has not been notified)

4. STORAGE BASEMENT (SC)

(The storage and service room within the basement is not to be used as a habitable room

as defined by the BCA.)

(Reason: To ensure compliance with Clause 4.4C of the SLEP 2012.)

4a. **FENCING (SC)**

The front fence and return in the front set back area is to be a maximum 700mm rendered base surmounted by open palisade to a maximum of 1.2 metres and all other fencing on the site to be a maximum of 1.8 metres above existing ground level.

(Reason: to maintain streetscape amenity)

4b. **Plan Revision prior to Construction Certificate (SC)**

Prior to the issue of the CC, revised plans are to be provided to the Principal Certifying Authority showing the following:

- The flat roofs are to be non-trafficable.
- Design of roof falls and gutters
- Schedule of external materials and finishes
- Nomination of room uses
- Dimensions of all rooms are to be detailed
- The 500mm reduction for the front portion of the dwelling
- RLs of all floor, ceiling and roof parapet levels

(Reasons: to improve/clarify the architectural drawings)

5. **APPROVED PLANS AND REFERENCE DOCUMENTATION (GC)**

The development, except where modified by a condition(s) of consent, is to be carried out in accordance with the following plans and reference documentation:

Plans affixed with Council's 'Development Consent' stamp relating to Development Consent No. DA2018/080:

Drawing No.	Title/Description	Prepared by	Issue / Revision & Date	Date received by Council
DA6002	Demolition Plan	Urban Link	Project No. 18/048, Rev 'B', dated 27/07/2018	31/07/2018
DA2001	Basement Plan	Urban Link	Project No. 18/048, Rev 'D', dated 16/10/2018	17 October 2018
DA2002	Ground Floor Plan	Urban Link	Project No. 18/048, Rev 'D', dated 16/10/2018	17 October 2018
DA2003	First Floor Plan	Urban Link	Project No. 18/048, Rev 'D', dated 16/10/2018	17 October 2018
DA2004	Roof Plan	Urban Link	Project No. 18/048, Rev 'B', dated 27/07/2018	17 October 2018
DA3001	Elevations	Urban Link	Project No. 18/048, Rev 'D', dated 16/10/2018	17 October 2018
DA4001	Sections	Urban Link	Project No. 18/048, Rev 'D', dated 16/10/2018	17 October 2018
L-01	Landscape Plan	Rfa landscape architects	Project No. 4380b, Rev 'B', dated 23/07/2018	31 July 2018

Reference Documentation affixed with Council's 'Development Consent' stamp relating to Development Consent No. DA2018/080:

Title / Description	Prepared by	Issue/Revision & Date	Date received by Council
Arboricultural Impact Assessment	Redgum Horticultural	Ref: 4514, dated 24 July 2018	31/07/2018
Flood Risk Management Plan	Australian Consulting Engineers	Project No. ACE180488, Rev 'A', dated April 2018	06/06/2018
Waste Management Plan	Urban Link		06/06/2018
BASIX Certificate	Designview	Cert No. 930588S	06/06/2018

In the event of any inconsistency, the conditions of this consent shall prevail.

(Reason: To ensure that the form of the development undertaken is in accordance with the determination of Council.)

6. CONSTRUCTION HOURS (GC)

No construction or any other work related activities shall be carried out on the site outside the hours of 7.00 am to 5.00 pm Mondays to Fridays and 8am to 1pm Saturdays.

No building activities are to be carried out at any time on a Sunday or public holiday.

Where the development involves the use of jackhammers/rock breakers and the like or other heavy machinery, such equipment may only be used between the hours of 7.00 am - 5.00 pm Monday to Friday only.

(Reason: To maintain amenity to adjoining land owners.)

7. CONSTRUCTION WITHIN BOUNDARIES (GC)

The development including but not limited to footings, walls, roof barges and guttering must be constructed wholly within the boundary of the premises. No portion of the proposed structure shall encroach onto the adjoining properties. Gates must be installed so they do not open onto any footpath or adjoining land.

(Reason: Approved works are to be contained wholly within the subject site.)

8. DEMOLITION – GENERALLY (GC)

Alteration and demolition of the existing building is limited to that documented on the approved plans (by way of notation). No approval is given or implied for removal and/or rebuilding of any portion of the existing building which is not shown to be altered or demolished.

(Reason: To ensure compliance with the approved development.)

9. DEMOLITION - SITE SAFETY FENCING (GC)

Site fencing is to be erected to a minimum height of 1.8m complying with WorkCover Guidelines, to exclude public access to the site, prior to any demolition works occurring and maintained for the duration of the demolition works.

If applicable, a separate Hoarding Application for the erection of an A class (fence type) or

B class (overhead type) hoarding/fencing along the street frontage(s) complying with WorkCover requirements must be obtained including:

- payment to Council of a footpath occupancy fee based on the area of footpath to be occupied and Council's Schedule of Fees and Charges before the commencement of work; and
- provision of a Public Risk Insurance Policy with a minimum cover of \$10 million in relation to the occupation of and works within Council's road reserve, for the full duration of the proposed works, must be obtained with a copy provided to Council.

(Reasons: Statutory requirement and health and safety.)

10. **LANDSCAPING ADJACENT SWIMMING POOLS/SPAS (GC)**

A minimum one (1) metre wide landscape strip is to be provided between the swimming pool and adjacent common boundaries. The landscape strip is to be planted with a continuous row of evergreen shrubs of a minimum five (5) litre container size and capable of achieving a minimum mature height of three (3) metres. Details of the selected plants shall be submitted to and approved by the Principal Certifying Authority. Compliance with this condition shall be certified by the Principal Certifying Authority, prior to occupation of the premises.

(Reason: Privacy amenity of adjoining properties.)

11. **LANDSCAPING - CANOPY TREES IN FRONT SETBACK (GC)**

New development shall provide at least two (2) canopy trees within the front setback adjacent the front boundary (existing trees may be included). New canopy trees shall be at least three (3) metres high at the time of planting and capable of reaching a mature height of 10m.

Species shall be selected from Council's Recommended Tree List (Available from Council's website or from the Customer Service Centre). Compliance with this condition is to be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: To ensure the landscape character of the locality is maintained.)

12. **ENVIRONMENTAL PROTECTION – TREE (GC)**

All street trees and trees on private property that are protected under Council's controls, shall be retained except where Council's prior written consent has been obtained. The felling, lopping, topping, ringbarking, wilful destruction or removal of any tree/s unless in conformity with this approval or subsequent approval is prohibited.

All healthy trees and shrubs identified for retention on the approved drawings are to be suitably protected in accordance with Section 4, Tree protection measures, and Appendix C Tree Protection Zone Sign, of Australian Standard AS4970 - 2009, Protection of Trees on Development Sites, prior to the commencement of any works (including any demolition and excavation) and maintained for the duration of the works.

In this regard the street tree and all protected trees on or adjacent to the site will be protected as described below;

- i. A Tree Protection (Management) Plan prepared by a AQF Level 5 Arborist is to be available on site at all times prior to the issue of the Construction

- Certificate, for all demolition and site works. This Tree Protection (Management) Plan must be shown on the demand of Authorised Council staff.
- ii. Protective perimeter fencing must be consistent with AS 4687, using metal fence posts greater than 20mm diameter and solid or chain wire mesh 2 metres in height supported on concrete pads/feet at 2-2.5 metre spacing. Fencing placement should not be closer than 2.5 metres from the trunk of each protected tree, or at a distance as specified by the approved Tree Protection (Management) Plan and approved by Council's Tree Management Officer. Shade cloth is to be used to prevent entry of dust and contaminated liquids into the root protection area.
 - iii. Signs must be placed on the Fencing. These signs must comply with AS1319. The signs must state the purpose of the fencing and the name and contact details of the builder and the appointed AQF Level 5 consultant arborist.
 - iv. Root protection is to be provided in the form of mulching to a depth of 50-100mm, inside of the fenced tree protection zone.
 - v. Ground (Root) Trunk and Branch Protection must comply with the diagram of Figure 4 of AS4970 – 2009. Ground protection within the tree protection zone and drip line should be in the form of heavy steel plates or timber rumble boards over mulch or aggregate. Trunk and branch protection should be to a minimum height of 2 metres and must include measures to protect the tree/s against damage from the movement of trucks, plant equipment and materials at greater heights above ground level.
 - vi. Temporary signs, cables, wires must not be attached to, or suspended, on any street tree or protected tree.
 - vii. Above ground utilities must not be placed within the canopy of an existing protected tree, or create the future need for clearance pruning.
 - viii. Below ground utilities/services must not be located inside the fenced tree protection zone.
 - ix. Scaffolding must not be located in the fenced tree protection zone unless authorised by the approved Tree Protection (Management) Plan and Council's Tree Management Officer
 - x. Council must be notified in writing within 24 hours, for all temporary removal of the tree protection fencing ground (root) trunk and branch protection within the root protection area.
 - xi. Pruning of a street tree is prohibited without the written consent of Council.

(Reason: To ensure the protection of trees to be retained on the site.)

13. MATERIALS – CONSISTENT WITH SUBMITTED SCHEDULE (GC)

All external materials, finishes and colours are to be consistent with the schedule submitted and approved by Council with the development application.

(Reason: To ensure compliance with this consent.)

14. PRINCIPAL CERTIFYING AUTHORITY (PCA) IDENTIFICATION SIGN (GC)

Prior to commencement of any work, signage must be erected in a prominent position on the work site identifying:

- i) the Principal Certifying Authority (PCA) by showing the name, address and telephone number of the PCA;
- ii) the Principal Contractor by showing the Principal Contractor's name, address and telephone number (outside of work hours) for that person; and

- iii) the sign must state that unauthorised entry to the work site is prohibited.

Any such sign is to be maintained while the work is being carried out, but must be removed when the work has been completed.

This clause does not apply to building work, subdivision work or demolition work that is carried out inside an existing building that does not affect the external walls of the building.

(Reason: Statutory requirement.)

15. **SITE MANAGEMENT (DURING DEMOLITION AND CONSTRUCTION WORKS)**

All of the following are to be satisfied/complied with during demolition, construction and any other site works:

- i) All demolition is to be carried out in accordance with Australian Standard AS 2601-2001.
- ii) Demolition must be carried out by a registered demolition contractor.
- iii) A single entrance is permitted to service the site for demolition and construction. Protection pads are to be installed to the kerb, gutter and nature strip where trucks and vehicles enter the site.
- iv) No blasting is to be carried out at any time during construction of the building.
- v) Care must be taken during demolition/ excavation/ building/ construction to prevent any damage to adjoining buildings.
- vi) Adjoining owner property rights and the need for owner's permission must be observed at all times, including the entering onto land for the purpose of undertaking works.
- vii) Any demolition and excess construction materials are to be recycled wherever practicable.
- viii) The disposal of construction and demolition waste must be in accordance with the requirements of the Protection of the Environment Operations Act 1997.
- ix) All waste on the site is to be stored, handled and disposed of in such a manner as to not create air pollution (including odour), offensive noise or pollution of land and/or water as defined by the Protection of the Environment Operations Act 1997. All excavated material should be removed from the site in an approved manner and be disposed of lawfully to a tip or other authorised disposal area.
- x) All waste must be contained entirely within the site.
- xi) A site plan including temporary waste storage locations, construction material storage areas and vehicular access to and from the site must be included with application.
- xii) Section 143 of the Protection of the Environment Operations Act 1997 requires waste to be transported to a place which can lawfully accept it. All non-recyclable demolition materials are to be disposed of at an approved waste disposal depot in accordance with legislation.
- xiii) Details as to the method and location of disposal of demolition materials (weight dockets, receipts, etc.) should be kept on site as evidence of approved methods of disposal or recycling and must be presented to Council and/or Principal Certifying Authority upon request.
- xiv) All materials on site or being delivered to the site are to generally be contained within the site. The requirements of the Protection of the Environment Operations Act 1997 must be complied with when placing/stockpiling loose material, disposing of concrete waste, or other activities likely to pollute drains or water courses.
- xv) Any materials stored on site must be stored out of view or in such a manner so as not to cause unsightliness when viewed from nearby lands or roadways.
- xvi) Public footways, include nature strips and roadways adjacent to the site must be maintained and cleared of obstructions during construction. No building materials,

waste containers or skips may be stored on the road reserve or footpath without prior separate approval from Council, including payment of relevant fees.

- xvii) Building operations such as brick-cutting, washing tools or paint brushes, and mixing mortar not be performed on the roadway or public footway or any other locations which could lead to the discharge of materials into the stormwater drainage system.
- xviii) All site waters during excavation and construction must be contained on site in an approved manner to avoid pollutants entering into waterways or Council's stormwater drainage system.
- xix) Any work must not prohibit or divert any natural overland flow of water.
- xx) Toilet facilities for employees must be provided in accordance with WorkCover NSW.

(Reason: To ensure that demolition, building and any other site works are undertaken in accordance with relevant legislation and policy and in a manner which will be non-disruptive to the local area.)

16. **STORMWATER MANAGEMENT PLAN - CERTIFICATION REQUIREMENT (GC)**

A detailed Stormwater Management Plan (SWMP) in line with Council's Stormwater Management Code is to be prepared and certified by a practicing Chartered Professional Engineer on the National Professional Engineer's Register (NPER) at Engineers Australia and submitted to the Principal Certifying Authority and Council, prior to the issue of a Construction Certificate. The SWMP is to be based on the approved development as modified by any conditions of consent.

(Reason: To ensure appropriate provision is made for the disposal and management of stormwater generated by the development, and to ensure public infrastructure in Council's care and control is not overloaded.)

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF A CONSTRUCTION CERTIFICATE (CC)

17. **BASIX COMMITMENTS (CC)**

The approved BASIX Certificate shall be submitted to the Principal Certifying Authority with the application for a Construction Certificate.

Where a change or changes are proposed in the BASIX commitments, the applicant must submit a new BASIX Certificate to the Principal Certifying Authority and Council. If any proposed change in the BASIX commitments is inconsistent with the development consent the applicant will be required to submit a modification to the development consent to Council under Section 4.55 of the Environmental Planning and Assessment Act 1979.

All commitments in the BASIX Certificate must be shown on the plans accompanying the Construction Certificate.

(Reason: Statutory compliance.)

18. **BUILDING CODE OF AUSTRALIA - COMPLIANCE WITH (CC)**

All architectural drawings, specifications and related documentation shall comply with the Building Code of Australia (BCA). All work must be carried out in accordance with the requirements of the Building Code of Australia (BCA).

In the case of residential building work for which the Home Building Act 1989 requires there to be a contract of insurance in force in accordance with Part 6 of that Act, such a contract

of insurance is to be in force before any building work authorised to be carried out by the consent commences.

Details demonstrating compliance with this condition are to be submitted to the Principle Certifying Authority, prior to issue of the Construction Certificate.

(Reason: This is a 'prescribed' condition under clause 98(1) of the Environmental Planning and Assessment Regulation 2000.)

19. CAR PARKING - BASEMENT CAR PARKING REQUIREMENTS (CC)

Details demonstrating compliance with the following is to be submitted to the Principal Certifying Authority, prior to issue of the Construction Certificate:

- i) Minimal internal clearance of the basement is 2.2m in accordance with BCA requirements.
- ii) Driveways shall comply with Australian/New Zealand Standard AS/NZS 2890.1:2004 - Parking facilities - Off-street car parking and achieve a maximum gradient of 1:4.
- iii) Basement entries and ramps/driveways within the property are to be no more than 3.5m wide.
- iv) Provision of pump-out systems and stormwater prevention shall be in accordance with Council's Stormwater Management Guide.

(Reason: To ensure suitable development.)

20. CAR PARKING - VEHICULAR ACCESS RAMPS (CC)

Vehicular access ramps shall comply with the provisions of AS/NZS 2890.1:2004. Plans to be submitted shall contain the following details:

- i) Longitudinal section along the extreme wheel paths of each driveway/access ramp at a scale of 1:25 demonstrating compliance with the scraping provisions of AS/NZS 2890.1:2004. It shall include all levels and grades, including those levels stipulated as boundary levels, both existing and proposed. It shall extend from the centre-line of the roadway through to the parking area.
- ii) Sections showing the clearance to the underside of any overhead structure (minimum headroom requirements 2200mm minimum for standard headroom clearance or 2400mm where disabled access provisions are to be provided) demonstrating compliance with the provisions of AS/NZS 2890.1:2004.
- iii) Longitudinal section along the gutter line showing how it is intended to transition the vehicular crossing into the existing kerb and gutter. Boundary levels shall generally run parallel with the kerb levels.
- iv) Location of verge trees, street furniture and service installations.
- v) Superimposition of vehicle turning circles for access into parking spaces.
- vi) Certification that the design complies with AS/NZS 2890.1:2004 by a Qualified Engineer.

The certification referred to in (vi) above shall be submitted to the Principal Certifying Authority prior to the issue of a Construction Certificate (for the design) and to the Principal Certifying Authority prior to the issue of any Occupation Certificate for the 'as-built works'.

(Reason: To ensure adequate vehicular access can be achieved.)

21. COMMENCEMENT OF WORKS (NO WORKS UNTIL A CC IS OBTAINED)

Building work, demolition or excavation must not be carried out until a Construction

Certificate has been issued by either Strathfield Council or a Principal Certifying Authority.

Demolition of any part of a building triggers 'commencement of erection of building' pursuant of section 4.19 of the EP&A Act 1979. Accordingly, demolition works must not commence until a Construction Certificate has been issued, a Principal Certifying Authority has been appointed and a Notice of Commencement has been issued.

(Reason: To ensure compliance with statutory provisions.)

22. CONSTRUCTION AND ENVIRONMENTAL MANAGEMENT PLAN (CC)

The applicant must prepare and submit a Construction and Environmental Management Plan (CEMP) to the Principal Certifying Authority, including:

- i) Detailed information on any approvals required from other authorities prior to or during construction.
- ii) Traffic management, including details of:
 - ingress and egress of vehicles to the site;
 - management of loading and unloading of materials;
 - the location of heavy vehicle parking off-site; and
 - designated routes for vehicles to the site.
- iii) The proposed areas within the site to be used for a builder's site office and amenities, the storage of excavated material, construction materials and waste containers during the construction period.
- iv) Erosion and sediment control, detailing measures and procedures consistent with the requirements of Council's guidelines for managing stormwater, including:
 - the collection and treatment of stormwater and wastewater generated on site prior to discharge; and
 - procedures to prevent run-off of solid material and waste from the site.
- v) Waste management, including:
 - details of the types and estimated volumes of waste materials that will be generated;
 - procedures for maximising reuse and recycling of construction materials; and
 - details of the off-site disposal or recycling facilities for construction waste.
- vi) Dust control, outlining measures to minimise the generation and off-site transmission of dust and fine particles, such as watering or damp cloth fences.
- vii) A soil and water management plan, which includes:
 - measures to minimise the area of soils exposed at any one time and conserve top soil;
 - identification and protection of proposed stockpile locations;
 - preservation of existing vegetation and revegetation;
 - measures to prevent soil, sand, sediments leaving the site in an uncontrolled manner;
 - measures to control surface water flows through the site in a manner that diverts clean run-off around disturbed areas, minimises slope gradient and flow distance within disturbed areas, ensures surface run-off occurs at non-erodible velocities, and ensures disturbed areas are promptly rehabilitated;
 - details of sediment and erosion control measures in place before work commences;
 - measures to ensure materials are not tracked onto the road by vehicles entering or leaving the site; and
 - details of drainage to protect and drain the site during works.
- viii) Asbestos management procedures:
 - Anyone who removes, repairs or disturbs bonded or a friable asbestos material must hold a current removal licence from Workcover NSW holding either a

Friable (Class A) or a Non- Friable (Class B) Asbestos Removal License which ever applies and a current WorkCover Demolition License where works involve demolition. To find a licensed asbestos removalist please see www.workcover.nsw.gov.au

- Removal of asbestos by a person who does not hold a Class A or Class B asbestos removal license is permitted if the asbestos being removed is 10m² or less of non-friable asbestos (approximately the size of a small bathroom). Friable asbestos materials must only be removed by a person who holds a current Class A asbestos license.
- Before starting work, a work site-specific permit approving each asbestos project must be obtained from WorkCover NSW. A permit will not be granted without a current WorkCover licence. All removal, repair or disturbance of or to asbestos material must comply with the following:
 - The Work Health and Safety Act 2011;
 - The Work Health and Safety Regulation 2011;
 - How to Safety Remove Asbestos Code of Practice – WorkCover 2011; and
 - Safe Work Australia Code of Practice for the Management and Control of Asbestos in the Workplace.
- Following completion of asbestos removal works undertaken by a licensed asbestos removalist re-occupation of a workplace must not occur until an independent and suitably licensed asbestos removalist undertakes a clearance inspection and issues a clearance certificate.
- The developer or demolition contractor must notify adjoining residents at least two (2) working days (i.e. Monday to Friday exclusive of public holidays) prior to the commencement of asbestos removal works. Notification is to include, at a minimum:
 - the date and time when asbestos removal works will commence;
 - the name, address and business hours contact telephone number of the demolisher, contractor and/or developer;
 - the full name and license number of the asbestos removalist/s; and
 - the telephone number of WorkCover's Hotline 13 10 50
 - warning signs informing all people nearby that asbestos removal work is taking place in the area. Signs should be placed at all of the main entry points to the asbestos removal work area where asbestos is present. These signs should be weatherproof, constructed of light-weight material and adequately secured so they remain in prominent locations. The signs should be in accordance with AS 1319-1994 Safety signs for the occupational environment for size, illumination, location and maintenance; and
 - appropriate barricades installed as appropriate to prevent public access and prevent the escape of asbestos fibres. Barricades must be installed prior to the commencement of asbestos removal works and remain in place until works are completed.

(Reason: Safety, amenity and protection of public infrastructure and the environment.)

23. COUNCIL PERMITS – FOR ALL ACTIVITIES ON COUNCIL LAND (CC)

Works Permit

(as per Section 68 of the Local Government Act 1993 and Section 138 and 139 of the Roads Act 1993)

A Works Permit is required for construction of a vehicular crossing (driveway), new stormwater down pipe connection to kerb and gutter, new footpath and/or stormwater connection. A Works Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located

on Council's website.

Standing Plant Permit

This permit must be applied for where it is intended to park a concrete pump, crane or other plant on the roadway or footpath. A Standing Plant Permit Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Skip Bin Permit

This permit must be applied for if you intend to place a skip bin on the roadway or footpath. A Skip Bin Application Form is available from Council's Customer Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Temporary Full or Part Road Closure Permit

This permit must be applied for if you require a full or a part road closure to take place to assist in your construction works. Please use the Works Permit Application Form, which is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website. Please note a Road Closure Permit is not required for standing plant.

Hoarding/Fencing Permit

This permit must be applied for if you intend to erect a Class A (fence type) or Class B (overhead type) hoarding/fencing along the street frontage(s). A Hoarding Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Work Zone Permit

This permit must be applied for if you require permanent parking along the kerbside at the front of the site during construction works. A Work Zone Permit Application Form is available from Council's Customer Service Centre or can be downloaded from Council's website. The applicable fees and charges are located on Council's website.

Ground Anchoring Permit

This permit must be applied for, for the installation of ground anchors under Council's footway/road reserve. It does not cover ground anchors under private properties. A separate approval is required to be obtained from Roads and Maritime Services (RMS) if it is proposed to install ground anchors under a State or Classified Regional Road (please refer to the end of this application form for more information).

(Reason: Council requirement.)

24. **EXCAVATION - AFFECTING ADJOINING LAND (CC)**

If an excavation associated with the approved development extends below the level of the base of the footings of a building on an adjoining allotment of land, the person having the benefit of the development consent must, at the person's own expense, comply with the requirements of clause 98E of the Environmental Planning and Assessment Regulation 2000, including:

- i) protect and support the adjoining premises from possible damage from the excavation, and
- ii) where necessary, underpin the adjoining premises to prevent any such damage.

The condition referred to in subclause (i) does not apply if the person having the benefit of the development consent owns the adjoining land or the owner of the adjoining land has given consent in writing to that condition not applying. Details shall be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Structural safety.)

25. ARBORIST REPORT – INITIAL (CC)

The applicant must engage a suitably qualified and experienced arborist (Australian Qualification Framework Level 5 or above) to assess the impact of the proposed works and determine best practices (e.g. minimise compaction, soil build up and or excavation within the Primary Root Zone*) to ensure the longevity of the trees to be retained. The arborist is to prepare and submit, to the satisfaction of the Principal Certifying Authority, a report prior to the issue of a Construction Certificate, documenting the measures to be employed for the additional trees number #5 and #6 (Celtis occidentalis) in the rear yard and certifying that they have been implemented. The report will include all trees both in the site and in adjacent properties in the form of a tree survey and safety audit, a tree impact assessment and a tree protection plan, in accordance with Australian Standard AS4970 - 2009 , Protection of Trees on Development Sites.

- i) *Primary root zone = 10 x trunk diameter 1400mm from ground level (measured as a radius from the centre of the trunk).

(Reason: Qualified assessment of impact of proposed works on trees to be retained on the site.)

26. PRIVACY - OBSCURE GLAZING IN WET AREAS (CC)

All bathroom, ensuite and toilet windows shall be installed with obscure glazing. Plans shall be notated accordingly and details demonstrating compliance submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Privacy amenity.)

27. PROTECTION OF EXISTING TREES (GC)

The masonry brick boundary fence is to be constructed so as to support all brick in-fill panels using a lintel. This lintel is to be installed above ground level along the entire length of each in-fill panel.

(Reason: Environmental protection, protection of existing tree roots and landscape amenity.)

28. SECTION 7.11 CONTRIBUTION PAYMENT - INDIRECT CONTRIBUTIONS PLAN) (CC)

In accordance with the provisions of Section 7.11 of the Environmental Planning and Assessment Act 1979 and the Strathfield Indirect Development Contributions Plan 2010-2030, a contribution in the form of cash, cheque or credit card (financial transaction fee applies) shall be paid to Council for the following purposes:

Local Amenity Improvement Levy	\$13,416.28
--------------------------------	--------------------

The total amount of the contribution is valid as at the date of determination and is subject to

quarterly indexation. The amount of the contribution under this condition shall be indexed in accordance with clause 4.12 of the Strathfield Indirect Development Contributions Plan 2010-2030.

Contributions must be receipted by Council and submitted to the Accredited Certifier, prior to the issue of any Construction Certificate.

A copy of this condition is to be presented to Council's Customer Service Centre when paying the contribution so that it can be recalculated.

Note: A copy of Strathfield Council's Section 7.11 Indirect Development Contributions Plan may be downloaded from Council's website.

(Reason: To enable the provision of public amenities and services required/anticipated as a consequence of increased demand resulting from the development.)

29. DILAPIDATION REPORT - PRE-COMMENCEMENT (CC)

Subject to access being granted, a pre-commencement Dilapidation Report is to be undertaken on all adjoining properties, which in the opinion of a suitably qualified engineer, could be potentially affected by the construction of the project. The Dilapidation Report shall be carried out prior to the issue of a Construction Certificate.

The Dilapidation Report is to be prepared by a suitably Qualified Engineer with current Corporate Membership with the Institution of Engineers, Australia or Geotechnical Practitioner. The report shall include a photographic survey of adjoining properties detailing the physical condition of those properties, both internally and externally, including walls, ceilings, roof, structural members and other such items.

If access for undertaking the dilapidation survey is denied by an adjoining owner, the applicant must demonstrate, in writing, to Council's satisfaction attempts have been made to obtain access and/or advise the affected property owner of the reason for the survey and these attempts have been unsuccessful. Written concurrence must be obtained from Council in such circumstances.

The Report shall cover structural and geotechnical factors likely to arise from the development. A copy of this Report shall be submitted to Council as a record. The person having the benefit of the development consent must, at their own cost, rectify any damage caused to other properties during the construction of the project.

(Reason: To ensure no damage to adjoining properties occurs.)

30. STORMWATER - RAINWATER RE-USE (CC)

A rainwater re-use system shall be provided in accordance with either the BASIX minimum requirements, any relevant Council Rainwater Policy and/or specification of the management of stormwater, whichever is applicable. A detailed stormwater plan showing the proposed re-use system shall be submitted to and approved by the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Compliance and amenity.)

31. STORMWATER DRAINAGE (CC)

The following stormwater precautions are required to be provided on the site:

- i) Grated drains shall be provided along the driveway/basement entry at the vehicular crossing(s) and are to connect to the internal drainage system.
- ii) Overflow paths shall be provided to allow for flows in excess of the capacity of the pipe/drainage system draining the site.
- iii) Allowance shall be made for surface runoff from adjacent properties, and to retain existing surface flow path systems through the site. Any redirection or treatment of these flows shall not adversely affect any other properties
- iv) Boundary fencing shall be erected in such a manner as not to interfere with the natural flow of ground and surface water to the detriment of any other party.

(Reason: To ensure the site is drained appropriately and does not interfere with the natural flow of flood waters.)

32. **SWIMMING POOLS / SPAS (CONSTRUCTION OF)**

The approved swimming pool/spa must comply with all relevant legislation including:

- i) Swimming Pools Amendment Act 1992 (as amended);
- ii) Swimming Pools Regulations 2008; and
- iii) Australian Standard AS1926.1-2012 – Safety Barriers for Swimming Pools.

Details demonstrating compliance with this condition shall be demonstrated to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: Safety and statutory compliance.)

33. **SWIMMING POOLS / SPAS - MECHANICAL PLANT ENCLOSURE (CC)**

Any mechanical plant associated with the swimming pool and spa shall be acoustically treated to comply with the Protection of the Environment Operations Act 1997. Details are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

(Reason: To ensure the acoustic amenity of the neighbouring residents.)

34. **TRAFFIC - CONSTRUCTION TRAFFIC MANAGEMENT PLAN (CC)**

A Construction Traffic Management Plan (CTMP) is to be prepared by an appropriately qualified Traffic Management Consultant and submitted to and approved by Council's Engineering Section, prior to the commencement of any works including demolition.

The following matters should be addressed in the CTMP (where applicable):

- i) description of the demolition, excavation and construction works;
- ii) site plan/s showing the site, roads, footpaths, site access points and vehicular movements;
- iii) size, type and estimated number of vehicular movements (including removal of excavated materials, delivery of materials and concrete to the site);
- iv) proposed route(s) from the arterial (state) road network to the site and the proposed route from the site back to the arterial road network;
- v) impacts of the work and vehicular movements on the road network, traffic and pedestrians and proposed methods to safely manage pedestrians and construction related vehicles in the frontage roadways;
- vi) any Traffic Control Plans (TCP's) proposed to regulate traffic and pedestrian movements for construction activities (such as concrete pours, crane

- installation/removal etc.);
- vii) proposed hours of construction related activities and vehicular movements to and from the site;
 - viii) current/proposed approvals from other Agencies and Authorities (including Roads and Maritime Services, Police and State Transit Authority);
 - ix) any activities proposed to be located or impact upon Council's road, footways or any public place;
 - x) measures to maintain public safety and convenience;
 - xi) any proposed road and/or footpath closures;
 - xii) turning areas within the site for construction and spoil removal vehicles, allowing a forward egress for all construction vehicles on the site;
 - xiii) locations of work zones (where it is not possible for loading/unloading to occur on the site) in the frontage roadways accompanied by supporting documentation that such work zones have been approved by the Local Traffic Committee and Council;
 - xiv) location of any proposed crane and concrete pump and truck standing areas on and off the site (and relevant approvals from Council for plant on road);
 - xv) a dedicated unloading and loading point within the site for all construction vehicles, plant and deliveries;
 - xvi) material, plant and spoil bin storage areas within the site, where all materials are to be dropped off and collected;
 - xvii) on-site parking area for employees, tradespersons and construction vehicles as far as possible;
 - xviii) proposed areas within the site to be used for the storage of excavated material, construction materials and waste and recycling containers during the construction period; and
 - xix) how it is proposed to ensure that soil/excavated material is not transported onto surrounding footpaths and roadways.

(Reason: To mitigate traffic impacts on the surrounding area during the construction period.)

35. **CAR PARKING - VEHICULAR CROSSING WIDTH AT PROPERTY BOUNDARY (CC)**

Vehicular crossings are to have a maximum width of 3m at the property boundary. Details demonstrating compliance are to be submitted to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

The vehicular crossing (and all associated excavation works) must not be constructed closer than 2 metres from a retained protected street tree.

(Reason: Compliance with SCDCP 2005.)

36. **TREE BONDS (CC)**

A tree bond of **\$6,600** (calculated in accordance with Council's adopted Fees and Charges) shall be paid to Council, prior to the issue of a Construction Certificate.

The deposit is required as security against any damage to existing trees to be retained on Council's road reserve, during works on the site. The applicant must bear the cost of all restoration works to Council's property damaged during the course of this development.

Payment may be accepted in the form of cash, bank guarantee, cheque or credit card (financial transactions fees apply). Note: Additional fees apply for the lodgement of a bank guarantee in lieu of cash bond applies in accordance with Council's adopted Fees and Charges.

A refund of the Tree Bond must be made in writing.

Tree Bonds may be forfeited if a tree is dead, made dangerous or has been terminally damaged, or will be held until tree/s have fully recovered from the construction damage or were replacement/planted trees have become fully established and are over 6 metres in height.

(Reason: To ensure the protection of trees to be retained on Council's Road Reserve.)

CONDITIONS TO BE SATISFIED PRIOR TO THE COMMENCEMENT OF WORKS (CW)

37. APPOINTMENT OF A PRINCIPAL CERTIFYING AUTHORITY (PCA) (CW)

No work shall commence in connection with this Development Consent until:

- i) A construction certificate for the building work has been issued by the consent authority or a Principal Certifying Authority.
- ii) The person having the benefit of the development consent has appointed a principal certifying authority for the building work, and notified the principal certifying authority that the person will carry out the building work as an owner/builder, if that is the case.
- iii) The principal certifying authority has, no later than 2 days before the building work commences:
 - notified the Council of his or her appointment, and
 - notified the person having the benefit of the development consent of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- iv) The person having the benefit of the development consent, if not carrying out the work as an owner-builder, has:
 - appointed a principal contractor for the building work who must be the holder of a contractor licence if any residential building work is involved;
 - notified the principal certifying authority of such appointment; and
 - unless that person is the principal contractor, notified the principal contractor of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- v) The person having the benefit of the development consent has given at least 2 days' notice to the Council of the person's intention to commence the erection of the building.

Note: If the principal certifying authority is the Council, the nomination will be subject to the payment of a fee for the service to cover the cost of undertaking all necessary inspections and the issue of the appropriate certificates.

Under the Environment Planning and Assessment (Quality of Construction) Act, 2003, a sign must be erected in a prominent position on the work site showing the name, address and telephone number of the principal certifying authority; the name of the principal contractor (if any) for the building work and a telephone number at which that person may be contacted outside working hours. That sign must also state that unauthorised entry is prohibited. The sign must not be removed until all work has been completed.

(Reason: Statutory requirement.)

38. HOME BUILDING COMPENSATION FUND (CW)

No residential building work within the meaning of the Home Building Act 1989 may

commence until:

- i) A contract of insurance in accordance with Part 6 of the Home Building Act 1989 is entered into and in force, where such a contract is required under that Act (this is a prescribed condition of consent pursuant to clause 981(b) Environmental Planning and Assessment Regulation 2000.
- ii) The PCA is satisfied that the principal contractor for the work is the holder of the appropriate licence and is covered by the appropriate insurance, in each case if required by the Home Building Act 1989 (unless the work is to be carried out by an owner-builder).
- iii) If the work is to be carried out by an owner builder, that the owner builder is the holder of any owner -builder permit required under the Home Building Act 1989.
- iv) Written notice of the following information has been provided to Council (this is a prescribed condition of consent pursuant to clause 98B of the Environmental Planning and Assessment Regulation 2000):
 - In the case of work for which a principal contractor is required to be appointed:
 - the name and licence number of the principal contractor; and
 - the name of the insurer by which the work is insured under Part 6 of the Home Building Act 1989.
 - In the case of work to be done by an owner-builder:
 - the name of the owner-builder; and
 - if the owner-builder is required to hold an owner-builder permit under the Home Building Act 1989, the number of the owner-builder permits.

Where Council is not the PCA, the PCA is responsible for notifying Council of the above matters.

Note: Where arrangements for doing residential building work change while the work is in progress so that the above information becomes out of date, the PCA (where not the Council) must provide Council with written notice of the updated information.

(Reason: Statutory requirement.)

39. NOTICE OF COMMENCEMENT (CW)

No work shall commence until the following details are submitted to Council:

- i) a Notice of Commencement (form will be attached with issue of a Construction Certificate or available from our website) within two (2) days of the date on which it is proposed to commence works associated with the Development Consent;
- ii) details of the appointment of a Principal Certifying Authority (either Council or another Principal Certifying Authority); and
- iii) details of the name, address and licence details of the Builder.

(Reason: Statutory requirement.)

CONDITIONS TO BE SATISFIED DURING DEMOLITION AND BUILDING WORKS (DW)

40. CONTAMINATED LAND UNEXPECTED FINDS (DW)

In the instance works cause the generation of odours or uncovering of unexpected contaminants works are to immediately cease, Council is to be notified and a suitably qualified environmental scientist appointed to further assess the site.

The contaminated land situation is to be evaluated by the supervising environmental consultant and an appropriate response determined in consultation with the applicant,

which is agreed to by Strathfield Council's Environmental Services Manager.

Note: Council may also request that a NSW EPA accredited site auditor is involved to assist with the assessment of the contaminated land situation and review any new contamination information. The applicant must also adhere to any additional conditions which may be imposed by the accredited site auditor.

(Reason: To ensure compliance with statutory requirements.)

41. **FILL MATERIAL (DW)**

The only waste derived material which may be received at the development site is:

- i) Virgin excavated material (within the meaning of the Protection of the Environment Operations Act 1997), and
- ii) any other waste-derived material the subject of a resource recovery exemption under cl.51A of the Protection of the Environment Operations (Waste) Regulation 2005 that is permitted to be used as fill material.

Any (b)-type material received at the development site must be accompanied by documentation certifying by an appropriately qualified environmental consultant the materials compliance with the exemption conditions; and this documentation must be provided to the Principal Certifying Authority on request.

(Reason: To ensure imported fill is of an acceptable standard for environmental protection purposes.)

CONDITIONS TO BE SATISFIED PRIOR TO THE ISSUE OF AN OCCUPATION CERTIFICATE (OC)

42. **ENGINEERING WORKS (CERTIFICATION OF)**

Prior to occupation of the premises, a Work As Executed (WAE) Plan of all engineering and/or drainage works is to be submitted to the Principal Certifying Authority. The WAE Plan is to be certified by a suitably Qualified Engineer, with Corporate Membership standing in the Institution of Engineers Australia and registered on the National Professional Engineers Register (NPER) under the appropriate professional category, demonstrating that:

- i) the stormwater drainage system; and/or
- ii) the car parking arrangement and area; and/or
- iii) any related footpath crossing works; and/or
- iv) the proposed basement pump and well system; and/or
- v) the proposed driveway and layback; and/or
- vi) any other civil works

have been constructed in accordance with the approved plans and any relevant Standards and Council policies/specifications.

For major works, such as subdivisions, works within the road reserve (requiring separate S138 approval) and as where specified by Council, a Part 4A Certificate will be required. It is strongly recommended that an Engineer supervise all engineering related works.

Where Council is not the Principal Certifying Authority, an electronic copy of the above documents is to be provided to Council, prior to the issue of any Occupation Certificate.

(Reason: Asset management.)

43. **LANDSCAPING - ARBORIST'S FOLLOW UP REPORT OF TREE/S TO BE RETAINED (OC)**

As part of the on-going assessment of the tree/s to be retained, the consulting arborist engaged by the applicant is to assess their health and any impacts suffered by them as a result of the proposed approved development, prior to the issue of an Occupation Certificate. Findings are to be compiled in a detailed report and submitted to the Principle Certifying Authority, which documents the following:

- i) methods of excavation or construction used to carry out the works;
- ii) any damage sustained by the tree/s as a result of the works;
- iii) any subsequent remedial works required to be carried out by the consulting arborist as a result of the damage; and
- iv) any future or on-going remedial work required to be carried out to ensure the long term retention of the tree/s.

(Reason: To ensure the survival of trees to be retained.)

44. **OCCUPATION OF BUILDING (OC)**

A person must not commence occupation or use (or change of use where an existing building) of the whole or any part of a new building (within the meaning of section 109H (4) of the Act) unless an Interim Occupation Certificate or Final Occupation Certificate has been issued in relation to the building or part.

The Principal Certifying Authority is required to be satisfied, amongst other things, that:

- i) all required inspections (including each applicable mandatory critical stage inspection) have been carried out; and
- ii) any preconditions to the issue of the certificate required by a development consent have been met.

Note: New building includes an altered portion of, or an extension to, an existing building.

(Reason: Statutory requirement.)

45. **RAINWATER TANKS (OC)**

Rainwater tanks must be installed on residential properties by a suitably qualified and licensed plumber and in accordance with the following:

- i) Australian/New Zealand Standard AS/NZS 3500:2003;
- ii) NSW Code of Practice Plumbing and Drainage, 2006 produced by Committee on Uniformity of Plumbing and Drainage Regulations in NSW (CUPDR); and
- iii) Council's rainwater tank policy.

Details demonstrating compliance with this condition are to be submitted to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: To protect public health and amenity.)

46. **STORMWATER - CERTIFICATION OF THE CONSTRUCTED DRAINAGE SYSTEM (OC)**

The constructed stormwater system shall be certified by a suitably qualified person, in

accordance with Council's Stormwater Management Code, prior to the issue of any Occupation Certificate.

(Reason: Adequate stormwater management.)

47. STORMWATER - COVENANT AND RESTRICTION AS TO USER FOR STORMWATER CONTROLLED SYSTEMS (OC)

Prior to the issue of any Occupation Certificate, the applicant shall register a Positive Covenant and a Restriction as to User under section 88E and or section 88B of the Conveyancing Act as appropriate in favour of Council, ensuring the ongoing retention, maintenance and operation of the stormwater facility (on-site detention, pump-out, charged lines, etc).

Where any drainage line or service conduit is to traverse any property other than that which it serves, an appropriate easement will be required. In this case, the applicant shall register an easement no less than 1200mm wide over the proposed drainage line or service concurrently with any subdivision registration.

The wording on the 88E and/or the 88B Instrument is to make reference to the Council file where the Construction plans and the Work As Executed (as built), plans are held. Typical wording can be obtained from Council's Specification for the Management of Stormwater document.

(Reason: To ensure the on-site detention and/or pump system is maintained to an appropriate operational standard.)

48. SWIMMING POOLS / SPAS - REGISTRATION AND REQUIREMENTS (OC)

The approved swimming pool/spa must comply with all relevant legislation including:

- i) Swimming Pools Amendment Act 1992 (as amended);
- ii) Swimming Pools Regulations 2008; and
- iii) Australian Standard AS1926.1-2012 – Safety Barriers for Swimming Pools.

Swimming pool owners must register their swimming pool or spa on the NSW Swimming Pool Register. A copy of a valid certificate of compliance or relevant occupation certificate must be attached to new residential tenancy agreements to rent property with a swimming pool or spa pool. Note: This requirement does not apply to a lot in strata or community title schemes with more than two lots.

A copy of a valid certificate of compliance or relevant occupation certificate must be attached to new residential tenancy agreements to rent property with a swimming pool or spa pool. Note: This requirement does not apply to a lot in strata or community title schemes with more than two lots; or for any off the plan contacts.

Details demonstrating compliance with this condition shall be demonstrated to the Principal Certifying Authority, prior to the issue of any Occupation Certificate.

(Reason: Safety and statutory compliance.)

regulations/standards.)

49. AIR-CONDITIONING UNIT (SC)

All air-conditioning units are to be installed as follows:

- a) Only residential grade air conditioners are to be installed;
- b) Installed to comply with the Protection of the Environment Operations Act 1997 and Protection of the Environment Operations (Noise Control) Regulations 2008; and
- c) If located less than 3m from any property boundary then the unit is to be placed in an acoustic dampening enclosure.

Documentation demonstrating compliance with the above measures is to be submitted and approved by Principal Certifying Authority **prior to the issue of the Occupation Certificate.**

(Reason: Acoustic privacy)

50. **LANDSCAPING – CERTIFICATION OF COMPLETED LANDSCAPING AND TREE PLANTING (OC)**

Prior to the issue of the Occupation Certificate an AQF Level 5 Landscape Designer, or Landscape Architect, is to certify that all landscape works and tree planting has been carried out in accordance with the approved landscape design and conditions of development consent. Additionally the certification is to include a statement that all plants are healthy and that the landscaped areas are well maintained, safe and free of biosecurity issues (pests, diseases and weeds).

(Reason: Tree preservation and environmental amenity.)

RESOLUTION

The question was raised about whether the Panel has delegation to determine this application. The Panel has been advised that the Department of Planning and Environment has approved the Deputy CEO/General Manager Planning, Environment & Urban Services the ability to refer development applications that he deems appropriate.

This application be **APPROVED** subject to the recommended conditions, and as amended by the panel.

REASONS:

The Panel is satisfied that the dwelling will sit comfortably in this streetscape which is in transition and already has variety of housing styles and architecture.

FOR: J.Murrell, E.Armstrong, I.Stapleton, R. Jolliffe

AGAINST: Nil

**** End Minutes - Report No. 3****

TO: Strathfield Local Planning Panel Meeting - 1 November 2018
REPORT: SLPP – Report No. 4
SUBJECT: DA2017/051/01 - 14-18 PILCHER STREET, STRATHFIELD SOUTH
 LOT 17-19 IN DP 11432
DA NO. DA2017/051/01

RECOMMENDATION

Pursuant to Section 4.55(2) of the Environmental Planning and Assessment Act 1979, the proposed modification(s) to Development Consent No. 2017/051 for the use of the site as a powder coating facility at 14-18 Pilcher Street, Strathfield South be **APPROVED**, subject to:

1. The original conditions of consent as approved by IDAP on 7 June 2017 for use of the site as a powder coating facility (DA2017/051).
2. As modified by the Section 4.55(2) application (DA2017/051/01) to alter the approved hours of operation and increase staff numbers to the approved powder coating facility as follows:
 - Alteration to Condition No. 8 regarding hours of operation;
 - Amendment to Condition No. 9 regarding maximum staff numbers;
 - Addition of Condition No. of
 - 11A Complaints – Air and noise pollution
 - 13 Spray Booth Requirements
 - 14 Spray Booth Plan of Management
 - 15 Storage of Materials Externally
 - 16 Vehicles
 - 17 Swept Path

GENERAL CONDITIONS (GC)

1. APPROVED PLANS AND REFERENCE DOCUMENTATION (GC)

The development, except where modified by a condition(s) of consent, is to be carried out in accordance with the following plans and reference documentation:

Plans affixed with Council's 'Development Consent' stamp relating to Development Consent No. DA2017/029:

Drawing No.	Title/Description	Prepared by	Issue / Revision & Date	Date received by Council
A01	Site Analysis Plan	Ergo Designs	A	11 April 2017
A02	Ground Floor Plan	Ergo Designs	A	11 April 2017
A03	Front Elevation	Ergo Designs	A	11 April 2017
A04	Sections	Ergo Designs	A	11 April 2017
A05	Notes and Calculations	Ergo Designs	A	11 April 2017

Reference Documentation affixed with Council's 'Development Consent' stamp relating to Development Consent No. DA2017/029:

Title / Description	Prepared by	Issue/Revision & Date	Date received by Council
Waste Management Plan	Peter Chao		15 April 2017

In the event of any inconsistency between the approved plans and supplementary documentation, the plans will prevail. However, the conditions of this consent shall prevail to the extent of any inconsistency.

(Reason: To ensure that the form of the development undertaken is in accordance with the determination of Council.)

2. WASTE BINS

All waste storage bins are to be located within the warehouse and not in the parking lot. The amended waste management plan with location of waste bins being internal to the building must be submitted to PCA prior to **Occupation Certificate**.

(Reason: To minimise visual impacts of the development.)

3. OPERATIONAL CAPACITY

At no time is the facility to process more than 10,000 tonnes of metal per year. A register of materials processed upon the site is to be maintained and kept upon the site at all times.

(Reason: Further supporting documentation is required to support development beyond this threshold.)

4. STREET TREES

A minimum of two (2) street trees shall be provided within Council's nature strip in Pilcher St in accordance with the following:

- (a) Trees are to conform to the *NATSPEC guide* and *Guide for assessing the quality of and purchasing of landscape trees* by Ross Clarke, 2003.
- (b) Trees shall be minimum 50 litre container size. Trees are to be true to type, healthy and vigorous at time of delivery and planting, shall be pest and disease free, free from injury and wounds and self-supporting. Supplied trees are to have an appropriate stem taper. Roots shall generally grow in an outwards (radial) or downwards direction.
- (c) Trees must be selected from Council's Recommended Tree List.
- (d) All trees are to be staked and tied with a minimum of three (3) hardwood stakes. Ties are to be hessian and fixed firmly to the stakes, one tie at half the height of the main stem, others as necessary to stabilise the plant.
- (e) Root deflection barriers having a minimum depth of 600mm are to be installed adjacent to all footpaths and driveways.
- (f) Apply soil conditioner/fertilizer/moisture retention additive/s in accordance with manufacturer's recommendations, and mix into the backfilling soil after planting tree/s.
- (g) Minimum 75mm depth of organic mulch shall be placed within an area 0.5m from the base of the tree.

(Reason: Environmental amenity)

5. LANDSCAPING – MAINTAINENCE

General maintenance of Council's nature strip adjoining the development site, including regular lawn mowing, edging, irrigation of the lawn and street trees and restricting the storage of materials, rubbish and parking or driving of vehicles on the nature strip, must be carried out during the ongoing operation of the site.

(Reason: Tree preservation and environmental amenity.)

6. FIRE SAFETY (CERTIFICATION)

A fire safety certificate shall be obtained in accordance with Part 9, Division 4 of the Environmental Planning and Assessment Regulation 2000, prior to the issue of any Occupation Certificate.

An fire safety certificate is a certificate issued by the owner of a building to the effect that each essential fire safety measure specified in the current fire safety schedule for the part of the building to which the certificate relates:

- (i) has been assessed by a properly qualified person; and
- (ii) was found, when it was assessed, to be capable of performing to at least the standard required by the current fire safety schedule for the building for which the certificate is issued.

An interim fire safety certificate must be provided before an interim occupation certificate can be used for a building under Clause 153(2) of the *Environmental Planning & Assessment Regulation 2000*.

A final fire safety certificate must be provided before an interim occupation certificate can be used for a building under Clause 153(1) of the *Environmental Planning & Assessment Regulation 2000*.

A copy of the fire safety certificate and fire safety schedule shall be:

- (i) submitted to Strathfield Council;
- (ii) submitted to the Commissioner of the New South Wales Fire Brigade; and
- (iii) prominently displayed in the building.

7. WASTE MANAGEMENT PLAN

Full compliance is to be given to the endorsed Waste Management Plan (WMP) All requirements of the approved Waste Management Plan must be implemented during the on-going use of the premises.

The WMP must identify the types of waste that will be generated and all proposals to re-use, recycle or dispose of the waste. The WMP is to be submitted to the Principal Certifying Authority, prior to issue of the Construction Certificate.

(Reason: To ensure appropriate management of waste.)

8. HOURS OF OPERATION (INDUSTRIAL PREMISES)

The hours of operation of the approved industrial premises must not exceed the following, without the prior approval of Council:

<i>Days</i>	<i>Approved hours of operation</i>
Monday – Friday	7:00am to 6:00pm
Saturday	7:30am to 4:30pm

The premises shall remain closed on Sundays or Public Holidays.

This condition does not apply in respect of refrigeration equipment/or machinery, unless

they create a nuisance or were not part of the original consent.

(Reason: Noise control and amenity.)

9. STAFF NUMBERS

A maximum of twelve (12) staff members are to be present upon the subject site at any time.

(Reason: To ensure the development operates as proposed.)

10. NOISE - REQUIREMENTS FOR INDUSTRIAL PREMISES

The use of the premises shall comply with the requirements of the NSW Environment Protection Authority Industrial Noise Policy 2000 and shall not give rise to the transmission of offensive noise as defined in the Protection of the Environment Operation Act 1997 (NSW)

(Reason: Noise control and amenity.)

11. POLLUTION - COMPLIANCE WITH PEOA 1997 GENERALLY

The activities carried out on site shall not constitute a nuisance in relation to noise, air or water pollution as specified under the Protection of the Environment Operations Act 1997.

(Reason: Environmental protection.)

11A. COMPLAINTS – AIR AND NOISE POLLUTION

In the event of Council receiving complaints regarding air pollution, noise pollution or odour from the premises, the person(s) in control of the premises shall at their own cost arrange for an Air Quality Impact Assessment or Acoustic Impact Assessment, or other environmental investigation specified in writing by Council to be carried out (by a suitably qualified person) and submit a report to Council specifying the proposed methods for the control of odour or noise emanating from the premises. Such measures are to be installed at no cost to Council and may require further development consent from Council.

(Reason: Environmental protection)

12. WASTEWATER CONTROL

The applicant shall contact Sydney Water, to determine the requirements for the disposal of wastewater and liquid trade waste (including grease traps or grease arrestors). The applicant must provide a copy of the Authority to connect to the sewer system prior to the issue of a Construction Certificate.

There is to be no discharge of wastewater to the stormwater system.

(Reason: To ensure suitable disposal of waste water.)

13. DELETED

14. DELETED

15. STORAGE OF MATERIALS EXTERNALLY

No permanent storage of goods, material, equipment, machinery, refuse, or refuse bins (except as indicated on the approved plans) shall take place in any area external to the building, between the building and the street alignment and nor shall the same be stored or placed within the road reserve except in accordance with Council's Materials on the Footpath Policy.

(Reason: To ensure car parking provision and amenity)

16. DELETED**17. DELETED****18. ACCESS - ACCESS FOR PEOPLE WITH DISABILITIES**

Access for people with disabilities must be provided in accordance with the requirements of the Building Code of Australia, relevant Australian Standards and with regard to the Disability Discrimination Act 1992. Certification saying by suitably qualified person is to be provided to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

Note: Disability (Access to Premises - Buildings) Standards 2010 - As of 1 May 2011, if access is provided to the extent covered by this Standard, then such access cannot be viewed as unlawful under the Disability Discrimination Act 1992.

(Reason: To provide equitable access for people(s) with disabilities in accordance with the relevant legislation and Australian Standards.)

19. ACCESS - DISABLED TOILETS

Disabled toilet/s complying with the relevant Australian Standards, the Building Code of Australia, and with regard to the Disability Discrimination Act 1992 are to be provided. Certification saying by suitably qualified person is to be provided to the Principal Certifying Authority, prior to the issue of a Construction Certificate.

Note: Disability (Access to Premises - Buildings) Standards 2010 - As of 1 May 2011, if access is provided to the extent covered by this Standard, then such access cannot be viewed as unlawful under the Disability Discrimination Act 1992.

(Reason: To provide equitable access for people(s) with disabilities in accordance with the relevant legislation and Australian Standards.)

20. APPOINTMENT OF A PRINCIPAL CERTIFYING AUTHORITY

No work shall commence in connection with this Development Consent until:

- i) A construction certificate for the building work has been issued by the consent authority or a Principal Certifying Authority.
- ii) The person having the benefit of the development consent has appointed a principal certifying authority for the building work, and notified the principal certifying authority that the person will carry out the building work as an owner/builder, if that is the case.

- iii) The principal certifying authority has, no later than 2 days before the building work commences:
- notified the Council of his or her appointment, and
 - notified the person having the benefit of the development consent of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- iv) The person having the benefit of the development consent, if not carrying out the work as an owner-builder, has:
- appointed a principal contractor for the building work who must be the holder of a contractor licence if any residential building work is involved;
 - notified the principal certifying authority of such appointment; and
 - unless that person is the principal contractor, notified the principal contractor of any critical stage inspections and other inspections that are to be carried out in respect of the building work.
- v) The person having the person having the benefit of the development consent has given at least 2 days notice to the Council of the person's intention to commence the erection of the building.

Note: If the principal certifying authority is the Council, the nomination will be subject to the payment of a fee for the service to cover the cost of undertaking all necessary inspections and the issue of the appropriate certificates.

Under the Environment Planning and Assessment (Quality of Construction) Act, 2003, a sign must be erected in a prominent position on the work site showing the name, address and telephone number of the principal certifying authority; the name of the principal contractor (if any) for the building work and a telephone number at which that person may be contacted outside working hours. That sign must also state that unauthorised entry is prohibited. The sign must not be removed until all work has been completed.

(Reason: Statutory requirement.)

ADVISORY NOTE:

Should substantiated complaints or breaches of noise regulations occur, a suitably qualified acoustic consultant shall be engaged by Council to measure noise emanating from the building/premises and to recommend appropriate action. The cost of such an appointment shall be borne by the operator/owner and any works recommended by the acoustic consultant shall also be borne by the operator/owner and carried out within a time frame set by Council.

RESOLUTION

Having considered the Council Officer's report and recommendation and submissions made during the exhibition and with the benefit of a site inspection the Panel has determined the application by the granting of **APPROVAL** to the extended hours and number of employees subject to the conditions contained in the report as amended:

REASONS:

The Panel is satisfied that the additional hours of operation and increasing number of employees will not have adverse impacts on the amenity of the area subject to the conditions.

FOR: J.Murrell, E.Armstrong, I.Stapleton, R. Jolliffe

AGAINST: Nil

**** End Minutes - Report No. 4****